

**FLOOR/CEILING SYSTEMS WOOD-FRAMED**

GA FILE NO. FC 5105

PROPRIETARY

1 HOUR FIRE

55 (0.54) STC SOUND



**GYPSUM WALLBOARD, RESILIENT CHANNELS, WOOD JOISTS**

One layer 1/2" proprietary type X gypsum wallboard or gypsum veneer base applied at right angles to resilient furring channels 24" o.c. with 1" Type S drywall screws 12" o.c. Gypsum board and joints located midway between continuous channels and attached to additional pieces of channel 60" long with screws at 12" o.c. Resilient channels applied at right angles to 2 x 10 wood joists 16" o.c. with 6d common nails. Wood joists supporting 1 1/2" plywood and 1" proprietary sanded gypsum underlayment.

STC rated with 3 1/2" glass fiber insulation in joist spaces and with carpet and pad. Second layer of gypsum wallboard required to achieve 1 hour fire resistance rating when glass fiber insulation is used.

**PROPRIETARY GYPSUM BOARD**

American Gypsum Company	-	1/2" TYPE X PLUS
Celotex Corporation	-	1/2" FI-ROK PLUS™
Continental Gypsum	-	1/2" MoreRock® FireBar® Type C (CGTC-C)
G-P Gypsum	-	1/2" GyProc® Fireguard® C
James Hardie Gypsum	-	1/2" Hardirock® Brand Max™ C™™ Gypsum Panels
Lafarge Gypsum	-	1/2" Firecheck® Type C
Pabco Gypsum	-	1/2" FLAME CURB® Super 'C'
Temple-Inland Forest Products Corporation	-	1/2" FIRE-RATED™



Approx. Ceiling Weight: 2 psf  
 Fire Test: UL R6352, 4-21-71, UL Design L502  
 Sound Test: G&H BW-10 MT, 10-13-70  
 IIC & Test: (73 C & P) G&H BW-10 MT, 10-13-70

GA FILE NO. FC 5107

PROPRIETARY

1 HOUR FIRE

65 (0.54) STC SOUND

**GYPSUM WALLBOARD, RESILIENT CHANNELS, WOOD JOISTS, GYPSUM FLOOR UNDERLAYMENT**

One layer 5/8" proprietary type X gypsum wallboard or gypsum veneer base applied at right angles to resilient furring channels 24" o.c. with 1" Type S drywall screws 12" o.c. Gypsum board and joints located midway between continuous channels and attached to additional pieces of channel 54" long with screws at 12" o.c. Resilient furring channels applied at right angles to 2 x 10 wood joists 16" o.c. with 1 1/4" Type W screws. Wood joists supporting 1 1/2" plywood subfloor and 3/4" 1000 psi sanded gypsum floor underlayment.

**PROPRIETARY GYPSUM BOARD**

Celotex Corporation	-	5/8" FI-ROK PLUS™
Continental Gypsum	-	5/8" MoreRock® FireBar® Type C (CGTC-C)
G-P Gypsum	-	5/8" GyProc® Fireguard® C
James Hardie Gypsum	-	5/8" Hardirock® Brand Max™ C™™ Gypsum Panels
Lafarge Gypsum	-	5/8" Firecheck® Type C
Pabco Gypsum	-	5/8" FLAME CURB® Super 'C'
United States Gypsum Company	-	5/8" SHEETROCK® Brand Gypsum Panels, FIRECODE® C Core



Approx. Ceiling Weight: 3 psf  
 Fire Test: UL R1319-65, 11-16-64, UL Design L514  
 Field Sound Test: INTEST 5-761-3, 12-5-77

GA FILE NO. FC 5110

GENERIC



1 HOUR FIRE

50 (0.54) STC SOUND

**WOOD JOISTS, GYPSUM LATH, GYPSUM PLASTER, RESILIENT CHANNELS**

1/2" 1:2-1:3 gypsum-sand plaster applied over 3/8" type X gypsum lath applied at right angles to resilient furring channels 16" o.c. with three 3/4" Type S drywall screws at each furring channel 3" wide woven wire strips applied over gypsum lath and parallel to and directly over resilient channels with 7/8" Type S drywall screws with diamond washers 16" o.c. Resilient channels applied at right angles to 2 x 10 wood joists 16" o.c. with 6d coated nails, 17/8" long, 0.0915" shank, 1/4" heads. Wood joists supporting 1" nominal wood subfloor and 1" nominal wood finish floor.

Sound tested with 3" glass fiber insulation batts in joist space, sound deadening felt, and carpet and pad.



Approx. Ceiling Weight: 6.25 psf  
 Fire Test: SFT-42, 5-7-66  
 Sound Test: CK 6712-5, 6-9-67  
 IIC & Test: (68 C & P) CK 6712-5, 6-9-67

† Contact the manufacturer for more detailed information on proprietary products.