


CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400



**NOTICE OF VIOLATION AND ORDER TO CORRECT**

July 18, 2017

<b>Responsible Party 1:</b> Daniluk Daryn 837 CONGRESS ST # 3 PORTLAND, ME 04102		
<b>Location</b> 837 CONGRESS ST	<b>CBL</b> 053 C022001	<b>Inspection Date</b> 6/21/2017
<b>Inspector</b> Edward Doughty	<b>Inspection Type</b> FP Routine Inspection	<b>Status</b> Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 8/15/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

<b>Violation</b>	<b>Proposed Date of Completion</b>
<b>NFPA 101- 7.5.1.1 AND 7.5.1.1.1 OBSTRUCTED EGRESS;</b> Exits shall be located and exit access shall be arranged so that exits are readily accessible at all times (7.5.1.1). Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4 (7.5.1.1.1). Materials in the Hallways / Stairwells that need to be removed.	7/31/17
<b>NFPA 101- 7.5.1.1 AND 7.5.1.1.1 OBSTRUCTED EGRESS;</b> Exits shall be located and exit access shall be arranged so that exits are readily accessible at all times (7.5.1.1). Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4 (7.5.1.1.1). Material in the Rear Stairwell	7/31/17
<b>NFPA 101- 7.2.1.8.1 DOORS SHALL BE SELF-CLOSING &amp; SELF-LATCHING;</b> A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise specified by 7.2.1.8.3. Fire Doors must be self closing	11/25/17
<b>NFPA 101- 31.3.4.5.1 SMOKE DETECTOR EACH SLEEPING ROOM;</b> In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.	7/31/17

Violation	Proposed Date of Completion
<b>CITY ORDINANCE HARDWIRED CARBON MONOXIDE ALARMS REQUIRED;</b> The owner shall install, or cause to be installed, by the manufacturer's requirements at least one approved carbon monoxide detector in each area within, or giving access to, bedrooms in: Each unit in any building of multifamily occupancy Any addition to or restoration of an existing single-family dwelling Any conversion of a building to a single-family dwelling A carbon monoxide detector must be powered both by the electrical service in the building or dwelling and by battery.	11/25/17
<b>FINAL DATE OF COMPLETED VIOLATION(S)</b>	11 / 25 / 17
<b>FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)</b>	_ / _ / _

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.


**VIOLATOR CERTIFICATION**

*I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.*

*I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.*

*If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.*

8/30/17  
 \_\_\_\_\_  
 Date


  
 \_\_\_\_\_  
 Responsible Party

\_\_\_\_\_  
 Date

\_\_\_\_\_  
 Responsible Party

**SEEN AND AGREED**

10/30/17  
 \_\_\_\_\_  
 Date

  
 \_\_\_\_\_  
 Fire Prevention Bureau