

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
 Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> SURRETTE DONALD E		<b>Inspector</b> Marland Wing	<b>Inspection Date</b> 2/23/2005
<b>Locatation</b> 837 CONGRESS ST	<b>CBL</b> 053 C022001	<b>Status</b> Re-Inspect 30 Days	<b>Inspection Type</b> Housing-Housing Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-108.5	Interior		cellar	Basement	
<b>Violation:</b>	Chimneys, flues and vent.				
<b>Notes:</b>	Missing Chimney Cleanout				
2) 6-113.5	Interior	1	2	Bedroom	
<b>Violation:</b>	Maintenance of lighting fixtures				
<b>Notes:</b>	bedroom receptacle open ground				
3) 6-113.5	Interior	1	2	Hallway	
<b>Violation:</b>	Maintenance of lighting fixtures				
<b>Notes:</b>	Hallway wall exposed wiring				
4) 6-113.5	Interior	3		Attic	
<b>Violation:</b>	Maintenance of lighting fixtures				
<b>Notes:</b>	Attic wall missing junction box cover				
5) 6-113.5	Interior	2		Hall	
<b>Violation:</b>	Maintenance of lighting fixtures				
<b>Notes:</b>	Front hall wall loose receptacle				
6) 6-113.5	Interior	1	2	Living Room	
<b>Violation:</b>	Maintenance of lighting fixtures				
<b>Notes:</b>	Livingroom Wall broken Receptacle cover				

**Comments:**