



Portland Fire Department

6/24/2019

GEORGE SPRAGUE
14 PARK ST
BATH, ME 04530
george_sprague@yahoo.com

DESTIE & GEORGE SPRAGUE
14 PARK ST
BATH, ME 04530
george_sprague@yahoo.com

CERTIFIED MAIL

RE: 34 DEERING AVE
PORTLAND, ME

053 C027001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 5/22/2017 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 7/1/2019 1:00:00PM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-4.5.3.2, 7.1.10.1	The means of egress shall remain free and unobstructed.	IMMEDIATELY remove all obstructions to the means of egress, mattress on the second floor fire escape and apt # 3 fire escape partially blocked	6/22/2017
NFPA 101-31.3.2	Boiler and fuel-fired heaters serving more than one dwelling unit must have 1-hour separation or sprinkler protection.	furnace and gas hot water heaters	11/1/2017