

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
 Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> PAGANO JEAN WALLACE REVOCABLE		<b>Inspector</b> Jodine Adams	<b>Inspection Date</b> 03/19/2004
<b>Location</b> 817 CONGRESS ST	<b>CBL</b> 053 C034001	<b>Status</b> Re-Inspect 30 Days	<b>Inspection Type</b> Complaint-Housing Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-116.5	Interior	1	12	Hall	
<b>Violation:</b> Fire Protection					
<b>Notes:</b> smoke detector in kitchen must be moved to hall					
2) 6-113.5	Interior	1	2	Bathroom	
<b>Violation:</b> Maintenance of lighting fixtures					
<b>Notes:</b> open ground GFI					
3) 6-108.3	Interior	2	4	Bathroom	
<b>Violation:</b> Exterior windows, doors and skylights					
<b>Notes:</b> screen ripped					
4) 6-108.3	Interior	2	4	Bedroom	
<b>Violation:</b> Exterior windows, doors and skylights					
<b>Notes:</b> window pull broken, window will not stay in up position					

**Comments:**