CITY OF PORTLAND, MAINE

Dept. of Planning & Urban Development
City Hall
389 Congress Street
Portland, Maine 04101

FACSIMILE MESSAGE COVER SHEET

Return Fax #

(207) 874-8716

Date: 1/13/48

Time: /// 3

11:35 Am

To the Attention of:

RICHARD GEORGE

Company/Entity:

We contry, Inc.

Message From:

MIRBORL A. Couries

MIEF ELECTRICAL Prop.

Department:

PRISPECTIONS

Phone #:

874-8300 (X &694)

Receiving FAX #:

773-5120

Total # of Pages including cover sheet:

2

Message: FYI, This plan review was sent to you with the building permit.

(#7, #8 ARE Very clean)!!

Inspection Services P. Samuel Hoffses Chief



Planning and Urban Development Joseph E. Gray Jr. Director

CITY OF PORTLAND

To: Samuel P. Hoffses, Chief of Inspections

From: Michael A. Collins, Chief Electrical Inspector

RE: Maine Medical Center, Additions/Alterations-PROJECT NO. 3013

ELECTRICAL PLAN AND SPECIFICATIONS REVIEW 4/10/97

1. No secondary transformer(s), shall be mounted above any ceiling area(s). All transformers shall be floor mounted only.

2. All panels shall be located as to maintain clearances at or about the equipment. No electrical panel shall be located in a storage area or room, or in an area or room containing other than electrical panels or electrical equipment.

3. All panel schedules shall be typed or computer generated

4. Where flexibility of wiring is necessary, hospital grade type MC cable may be used, ei; fixture connection, or to supply fixed equipment. Otherwise conduit shall be used as specified throughout this project.

5. All transformers shall be permanently labeled, with phenolic labels, as follows: FED FROM(ie; panel, disconnect), or SERVES WHAT or FEEDS TO(ie; panel, disconnect or similar load(s).)

6. All electrical rooms shall have their entrance door(s) labeled as follows: DANGER, ELECTRICAL ROOM, AUTHORIZED PERSONNEL ONLY.

- 7. All fire alarm cable shall be plenum rated/fire resistive, or approved equivalent.
- 8. All low-voltage cables shall be plenum rated/fire resistive, or approved equivalent.

cc: Tammy Munson, Lt McDougall