

AIR DISTRIBUTION SYMBOLS

	RECTANGULAR DUCT. (FIRST NUMBER IS SIDE SHOWN) DIMENSIONS IN INCHES
	12 INCH ROUND DUCT
	MOTORIZED DAMPER
	FLEXIBLE DUCT
	DUCT FLEXIBLE CONNECTOR (FC)
	DUCT DROPS AND RISES IN DIRECTION OF AIR FLOW
	RETURN DUCT TURNED UP OR DOWN (DASHED)
	SUPPLY DUCT TURNED UP OR DOWN (DASHED)
	EXHAUST DUCT TURNED UP OR DOWN (DASHED)
	ACOUSTICAL LINING (DUCT DIM. FOR NET FREE AREA)
	ROUND DUCT ELBOW DOWN
	ROUND DUCT ELBOW UP
	SQUARE TO ROUND TRANSITION
	CAP (DUCT AND/OR PIPE)
	INDICATES DUCT, PIPING, EQUIPMENT TO BE REMOVED.
	EA EXHAUST AIR
	RA RETURN AIR
	SA SUPPLY AIR
	VOLUME DAMPER
	FIRE DAMPER
	SMOKE DAMPER TAG NO.
	COMBINATION SMOKE/FIRE DAMPER TAG NO.
	RECTANGULAR ELBOW W/TURNING VANES
	DIRECTION OF AIR FLOW (IN) DIRECTION OF AIR FLOW (OUT)
	HUMIDISTAT OR HUMIDITY SENSOR
	THERMOSTAT (T'STAT) OR TEMP. SENSOR
	SMOKE DETECTOR
	5-3 DIFFUSER, REGISTER OR GRILLE TAG 300 CFM AIR FLOW QUANTITY TYP. 3
	FTR-2 FINNED TUBE TAG 20 LENGTH OF FINNED ELEMENT
	A1 DETAIL NO. M401 SHEET NO. WHERE DETAIL IS LOCATED
	CUH EQUIPMENT TAG 2 EQUIPMENT NO.
	LIMITS OF DEMOLITION
	CONNECT TO EXISTING

PIPING SYSTEMS

	CD CONDENSATE DRAIN		HG HOT GAS		RL REFRIGERANT LIQUID
	CHWS CHILLED WATER SUPPLY		HPS HIGH PRESSURE STEAM		RS REFRIGERANT SUCTION
	CHWR CHILLED WATER RETURN		HPR HIGH PRESSURE CONDENSATE RETURN		TWS TEMPERED CHILLED WATER SUPPLY
	CWS CONDENSER WATER SUPPLY		HWS HOT WATER SUPPLY		TWR TEMPERED CHILLED WATER RETURN
	CWR CONDENSER WATER RETURN		HWR HOT WATER RETURN		ZB ZONE VALVE BOX
	DB DISTRIBUTION VALVE BOX		LPS LOW PRESSURE STEAM		
	FCS FREE COOLING SUPPLY		LPR LOW PRESSURE RETURN		
	FCR FREE COOLING RETURN		MPS MEDIUM PRESSURE STEAM		
	FOS FUEL OIL SUPPLY		MPR MEDIUM PRESSURE RETURN		
	FOR FUEL OIL RETURN		NPW NON POTABLE COLD WATER		
	FOV FUEL OIL VENT		PCWR PROCESS COOLING WATER RETURN		
	GCR GRAVITY STEAM CONDENSATE RETURN		PC PUMPED STEAM CONDENSATE		
	GLY GLYCOL		PD PUMPED DISCHARGE		
	HCR HOT/ CHILLED WATER RETURN		PW POTABLE WATER		
	HCS HOT/ CHILLED WATER SUPPLY		R RELIEF LINE		

PIPING SYMBOLS

	UNION		ORIFICE FLOWMETER
	FLANGE		FLEXIBLE PIPE CONNECTOR
	PIPE ANCHOR		EXPANSION JOINT
	PIPE GUIDE OR SLEEVES		STEAM TRAP (FLOAT AND THERMOSTATIC INDICATED T.T. THERMOSTAT, B.T. BUCKET TRAP, T.D. THERMODYNAMIC TRAP)
	PIPE ELBOW TURNED DOWN		CONCENTRIC REDUCER/INCREASER
	PIPE ELBOW TURNED UP		ECCENTRIC REDUCER/INCREASER
	PIPING TEE-DOWN		DIRECTION OF FLOW
	PIPING TEE-UP		PUMP
	PIPE RISER		FINNED TUBE BASEBOARD
	PIPE PITCHES DOWN		HUMIDIFIER
	GENERIC VALVE, SEE SPECIFICATIONS FOR TYPE		DIFFERENTIAL PRESSURE TRANSMITTER
	GATE VALVE		
	BALL VALVE		
	BUTTERFLY VALVE (MANUAL)		
	2-WAY CONTROL VALVE		
	3-WAY CONTROL VALVE		
	BALANCING VALVE (CIRCUIT SETTER)		
	CHECK VALVE		
	PLUG VALVE		
	GLOBE VALVE		
	NEEDLE VALVE		
	BACK FLOW PREVENTER		
	SOLENOID VALVE		
	PRESSURE REDUCING OR REGULATING VALVE		
	PRESSURE RELIEF VALVE		
	STRAINER		
	STRAINER W/BLOWDOWN		
	MANUAL AIR VENT		
	AUTOMATIC AIR VENT		
	PRESSURE SWITCH		
	FLOW SWITCH		
	PRESSURE GAUGE AND COCK		
	THERMOMETER AND WELL		
	TEMPERATURE & PRESSURE TAP (PETE'S PLUG)		
	HOSE END DRAIN VALVE WITH CAP		

ABBREVIATIONS



AAV	AUTOMATIC AIR VENT	ENC	ENCLOSURE	PSE	PROCESS SOLVENT EXHAUST
ACC	AIR COOLED CONDENSER	ER	EXHAUST REGISTER	PP	POLY-PROPYLENE
ACU	AIR CONDITIONING UNIT	(E)	EXISTING	PPE	PRE PURCHASED EQUIPMENT
ACV	AUTOMATIC CONTROL VALVE	EXIST.	EXISTING	PRS	PRESSURE REDUCING STATION
AD	ACCESS DOOR	FBO	FURNISHED BY OWNER	PRV	PRESSURE REDUCING VALVE
AE	ACID EXHAUST	FBP	FACE AND BYPASS	PVD	PNEUMATIC VOLUME DAMPER
AFF	ABOVE FINISHED FLOOR	FC	FLEXIBLE CONNECTION	(R)	REMOVE
AFMS	AIR FLOW MEASURING STATION	FD	FIRE DAMPER	RA	RETURN AIR
AHU	AIR HANDLING UNIT	FG	FIBERGLASS	(REL.)	RELOCATED
ATC	AUTOMATIC TEMPERATURE CONTROL	F & T	FLOAT AND THERMOSTATIC	RF	RETURN FAN
AV	AIR VENT	FO	FLAT OVAL	RG	RETURN GRILLE
BB	BASEBOARD	FTR	FINNED TUBE RADIATION	RHC	REHEAT COIL
BDD	BACKDRAFT DAMPER	FS	FLOW SWITCH	RM	ROOM
BG	BLAST GATE	GC	GENERAL CONTRACTOR	RR	RETURN REGISTER
BLDG	BUILDING	GPM	GALLONS PER MINUTE	RV	RELIEF VALVE
BOD	BOTTOM OF DUCT	H	HUMIDIFIER	SA	SUPPLY AIR
BOP	BOTTOM OF PIPE	HB	HOSE BIB	SCV	SELF CONTAINED VALVE
BTU	BRITISH THERMAL UNIT	HRU	HEAT RECOVERY UNIT	SD	SMOKE DETECTOR
CBD	COUNTER BALANCED DAMPER	HTR	HEATER	SF	SUPPLY FAN
CD	CEILING DIFFUSER	H & V	HEATING AND VENTILATION	SG	SUPPLY GRILLE
COFF	CAPPED FOR FUTURE	HVAC	HEATING, VENTILATING AND AIR CONDITIONING	SR	SUPPLY REGISTER
CFM	CUBIC FEET PER MINUTE	HW	HOT WATER	SS	STAINLESS STEEL
CLG	CEILING	HX	HEAT EXCHANGER	TE	TEMPERATURIZED ELEMENT (SENSOR)
CONT	CONTINUATION	IN WG	INCHES WATER GAUGE	TG	TRANSFER GRILLE
COORD	COORDINATE	LD	LINED DUCT	TOD	TOP OF DUCT
CP	CONDENSATE PUMP & RECEIVER	MAU	MAKE UP AIR UNIT	TOP	TOP OF PIPE
CT	COOLING TOWER	MAX	MAXIMUM	TTS	TIGHT TO STEEL
CTE	CONNECT TO EXISTING	MBH	1000 BTU/HR.	TV	TURNING VANE(S)
CU	COPPER	ME	MECHANICAL ENGINEER	TYP	TYPICAL
CUH	CABINET UNIT HEATER	MFR	MANUFACTURER	UH	UNIT HEATER
CV	CONTROL VALVE	MIN	MINIMUM	UIC	UP IN CHASE
CW	COLD WATER	MD	MOTOR OPERATED DAMPER	UIW	UP IN WALL
DC	DOUBLE CONTAINED	MPV	MULTI-PURPOSE VALVE	UV	UNIT VENTILATOR
DDC	DIRECT DIGITAL CONTROL	MTD	MOUNTED	VAV	VARIABLE AIR VOLUME BOX
DIA	DIAMETER	MUA	MAKE UP AIR	VB	VACUUM BREAKER
DIC	DOWN IN CHASE	NPW	NON-POTABLE WATER	VTR	VENT THRU ROOF
DIW	DOWN IN WALL	NTS	NOT TO SCALE	VD	MANUAL VOLUME DAMPER
DN	DOWN	OA	OUTSIDE AIR	VCF	VALVED AND CAPPED FOR FUTURE
DT	DROP AND TRANSITION	OBD	OPPOSED BLADE DAMPER	VFD	VARIABLE FREQUENCY DRIVE
DWG	DRAWING	OED	OPEN ENDED DUCT	VOC	VOLATILE ORGANIC COMPOUNDS
DWH	DOMESTIC WATER HEATER	PAE	PROCESS ACID EXHAUST	W/	WITH
EA	EXHAUST AIR	PHE	PROCESS HEAT EXHAUST		
EF	EXHAUST FAN				

GENERAL NOTE

1. ALL GENERAL NOTES, SYMBOL LISTS, AND DETAILS ARE TO BE CONSIDERED AS APPLICABLE TO ALL HVAC AND PLUMBING DRAWINGS FOR THIS PROJECT. SYMBOLS AND ABBREVIATIONS SHOWN ON THIS SHEET ARE FOR REFERENCE ONLY AND DO NOT INDICATE THEIR INCORPORATION INTO THE DESIGN.

144 Fore Street/P.O. Box 610
Portland, Maine 04104
Tel. (207) 772-3846
Fax. (207) 772-1070
www.smartinc.com

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING



MAINE MEDICAL CENTER
NUCLEAR MEDICINE RENOVATIONS - PHASE 2
PORTLAND, MAINE
ISSUED FOR CONSTRUCTION
10-10-14

REV	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	10-10-14

GRAPHIC SCALE:
0" 1"

SCALE: NOT TO SCALE
PROJECT MANAGER: DJV
JC/DRAWN BY: FV
A/E OF RECORD: KDD
CAD FILE: M-001-14113
PROJECT NO: 14113
DATE: 10-10-14

SHEET TITLE:
LEGEND & ABBREVIATIONS

SHEET No.
M-001
© COPYRIGHT 2013 SMART INC.