

## DRAWING KEYNOTES

- TAG NOTES
- 2 7"ø SUPPLY DUCT UP IN CHASE TO INTERMEDIATE MECHANICAL
- MOUNT SUPPLY GRILL IN FACE OF ARCHITECTURAL SOFFITT.
- 6"ø SUPPLY DUCT UP IN CHASE TO INTERMEDIATE FLOOR.
  1 1/2"ø HWS/R UP IN CHASE TO INTERMEDIATE FLOOR.
- SEE VAV TERMINAL REHEAT COIL PIPING DETAIL FOR HOOKUP. (TYP.)
- DUCTWORK & PIPE ROUTING TO RICHARDS 3rd FLOOR PLAN (WEST) SOILED UTILITY ROOM. DUCT & PIPE LOCATION IS DIAGRAMMATIC. CEILING SPACE IS CONGESTED. CONTRACTOR TO VERIFY IN FIELD.

1 20"X16" EXHAUST DUCT UP IN CHASE TO INTERMEDIATE MECHANICAL FLOOR.

**NEILL & GUNTER, Inc.**Design and Consulting Engineers
Scarborough, Maine

ARCHITECTS

INTERIORS

PLANNERS

PORTSMOUTH, NH 03801

55 GREEN STREET

T 603.436.2551 F 603.436.6973


www.jsainc.com

**RENOVATIONS TO** RICHARD'S 3rd FLOOR

MAINE MEDICAL CENTER Portland, Maine

MAY 25, 2004

Revisions:



CONSTRUCTION **DOCUMENTS** 

**M-2A** © Copyright 2002, JSA, Inc

