



- LIGHTING NOTES:**
- ① RE-INSTALL EXISTING DEVICE.
  - ② USE LISTED BACK BOX AND LIGHTING CONTROL PANEL PROVIDED BY PATIENT LIGHT FIXTURE MANUFACTURER. MOUNT SWITCH AT NO MORE THAN 30' FROM FIXTURE (35' CABLE PROVIDED) AT 48" A.F.F.



Neill and Gunter

**LIGHTING PLAN**  
CAD FILE 25488F002