



<u>GE</u>	<b>NERAL NOTES:</b>
1.	REFER TO G-001 FOR PROJE

JECT GENERAL NOTES AND ABBREVIATIONS.

## REFLECTED CEILING NOTES:

- UNLESS INDICATED OTHERWISE, CENTER CEILING GRIDS IN ROOMS. USE HALF TILES OR GREATER AT PERIMETERS WHERE POSSIBLE.
- ALIGN CEILING ITEMS AS SHOWN, WITH COMMON CENTERLINES, TYPICALLY. CENTER ITEMS IN CEILING, OR IN AREAS UNLESS INDICATED OTHERWISE.
- 3. REFER TO ROOM FINISH SCHEDULE FOR CEILING FINISHES TO BE PROVIDED.
- 4. FIRE SPRINKLERS SHALL BE CENTERED IN CEILING TILE SQUARES.
- FIRE SPRINKLERS SHALL BE LOCATED IN ALIGNMENT WITH OTHER CEILING ITEMS
- FIRE SPRINKLERS SHALL BE PLACED TO COORDINATE WITH LIGHT FIXTURE POSITIONS INDICATED.
- 7. REFER TO FLOOR PLANS FOR EQUIPMENT SCHEDULE.
- 8. VERIFY LEVELNESS OF SALB WITH REGARD TO REQUIRED UNIFORM CEILING HEIGHT. COORDINATE WITH EQUIPMENT REQUIREMENTS AND TOLERANCES.

## SYMBOLS LEGEND:

2X2 SUSPENDED CEILING PANEL AND GRID ASSEMBLY

2x2 LAY-IN LIGHT FIXTURE



3 SOFFIT DETAIL 1 1/2" = 1'-0"

2x4 LAY-IN LIGHT FIXTURE

SUPPLY AIR GRILLE

DOWN LIGHT

CEILING MOUNTED EXIT LIGHT

RETURN AIR GRILLE

EXHAUST AIR GRILLE

**VEILLEUX** 

ore Street
Portland,
tel. (20
fax. (20

PROJECT NORTH

ISSUED FOR CONSTR 06.14.11

ramhall Radiology
ANGIO BI-PLANE RENOVATIONS

GRAPHIC SCALE: PROJECT MANAGER: A/E OF RECORD: PROJECT NO:

- 3-5/8" METAL STUD FRAMING @ 16" O.C. TO STRUCTURE ABOVE.

CEILING TYPE AS SCHEDULED. SEE RCP FOR HEIGHT.

- 3-5/8" METAL STUD CEILING FRAMING @ 16" O.C.

5/8" GWB PTD TYP.

- 5/8" GWB PTD TYP.

DATE: 06.14
SHEET TITLE:
BASEMENT LAYOUT AND REFLECTED CEILING PLAN

A-101

EQL	IIPMENT AND ACCESSORIES SCH	<u>IEDULE</u>		
TAG	DESCRIPTION	PROVIDE	(12)	CONTRAST WARMER
1	PHONE	O/C	(13)	COMPUTER
2	COMPUTER CART	0/0	(14)	LEAD APRON RACK
3	CART	0/0	15	SOAP DISPENSER
4	WALL MOUNTED COMPUTER W/WALL BRACKET	0/0	16	WHITE BOARD (2' X 3')
5	ELECTRICAL PANEL	C/C	(17)	PAPER TOWEL DISPENSER
6	PHYSIO BOX COVER	C/C	18	PAR EX
7	TRASH BIN/CLEAN/SOILED HAMPER	0/0	(19)	CEILING MOUNTED MEDGAS/POWER COLUMN
8	STORAGE CABINET (E - EXISTING)	0/0	20	MED GAS OUTLETS (SEE MECH. FOR QUANTITY)
9	PYXIS	0/0	21	PATIENT LIFT & RAIL
(10)	VENDOR EQUIPMENT	0/V	(22)	LEAD SHIELD & POST MOUNT
(11)	COPY/PRINT/FAX (U/C)	E	23)	MED GAS SHUT OFF

24)	PHILIPS PRINTER	0/V	
25)	HEPARIN CLOCK & CONTROLS	O/C	
26	SYNCHRONIZED CLOCK	0/0	
27)	MECHOSHADE	O/C	
C/C:	CONTRACTOR FURNISHED/CONTRACTOR INSTALLED		
O/C: OWNER FURNISHED/CONTRACTOR INSTALLED			
0/0:	OWNER FURNISHED/OWNER INSTALLED		
O/V: OWNER FURNISHED/VENDOR INSTALLED			
E:	EXISTING	-	

0/0

0/0

O/C

O/C

O/C

O/C

C/C

O/V

O/V

C/C

