

PROCESS COOLING WATER RETURN

PC PUMPED STEAM CONDENSATE

PD PUMPED DISCHARGE

PW POTABLE WATER

RELIEF LINE

FUEL OIL VENT

GLYCOL

———— GCR ———— GRAVITY STEAM CONDENSATE RETURN

----- HCR ----- HOT/CHILLED WATER RETURN

HCS HOT/CHILLED WATER SUPPLY

## ORIFICE FLOWMETER FLEXIBLE CONNECTOR EXPANSION JOINT STEAM TRAP (FLOAT AND THERMOSTATIC INDICATED T.T. THERMOSTAT, B.T. BUCKET TRAP, T.D. THERMODYNAMIC TRAP) CONCENTRIC REDUCER/INCREASER DIRECTION OF FLOW PUMP FINNED TUBE BASEBOARD DIFFERENTIAL PRESSURE TRANSMITTER

## **ABBREVIATIONS**

AAV AUTOMATIC AIR VENT	ENC ENCLOSURE	PSE PROCESS SOLVENT EXHAUST
ACC AIR COOLED CONDENSER	ER EXHAUST REGISTER	PP POLY-PROPYLENE
ACU AIR CONDITIONING UNIT	(E) EXISTING	PPE PREPÜRCHASED ÉQUIPMENT
AD ACCESS DOOR	EXIST. EXISTING	PRS PRESSURE REDUCING STATION
AE ACID EXHAUST	FBO FURNISHED BY OWNER	PRV PRESSURE REDUCING VALVE
AFF ABOVE FINISHED FLOOR	FBP FACE AND BYPASS	PVD PNEUMATIC VOLUME DAMPER
AFMS AIR FLOW MEASURING STATION	FC FLEXIBLE CONNECTOR	(R) REMOVE
AHU AIR HANDLING UNIT	FD FIRE DAMPER	RA RETURN AIR
ATC AUTOMATIC TEMPERATURE CONTROL	FG FIBERGLASS	(REL.) RELOCATED
AV AIR VENT	F&T FLOAT AND THERMOSTATIC	RF RETURN FAN
BB BASEBOARD	FO FLAT OVAL	RG RETURN GRILLE
BDD BACKDRAFT DAMPER	FTR FINNED TUBE RADIATION	RHC REHEAT COIL
BG BLAST GATE	FS FLOW SWITCH	RM ROOM
BLDG BUILDING	GC GENERAL CONTRACTOR	RR RETURN REGISTER
BOD BOTTOM OF DUCT	GPMGALLONS PER MINUTE	RV RELIEF VALVE
BOPBOTTOM OF PIPE	H HUMIDIFIER	SA SUPPLY AIR
BTU BRITISH THERMAL UNIT	HB HOSE BIBB	SCV SELF CONTAINED VALVE
CBD COUNTER BALANCED DAMPER	HRU HEAT RECOVERY UNIT	SD SMOKE DETECTOR
CD CEILING DIFFUSER	HTR HEATER	SF SUPPLY FAN
CFF CAPPED FOR FUTURE	H & V HEATING AND VENTILATING	SG SUPPLY GRILLE
CFM CUBIC FEET PER MINUTE	HVAC HEATING, VENTILATING AND AIR CONDITIONING	SR SUPPLY REGISTER
CLG CEILING	HW HOT WATER	SS STAINLESS STEEL
CONT CONTINUATION	HX HEAT EXCHANGER	TE TEMPERATURIZED ELEMENT (SENSOR)
COORD COORDINATION	IN WG INCHES WATER GAUGE	TG. TRANSFER GRILLE
CT COOLING TOWER	MAUMAKEUP AIR UNIT	TOD TOP OF DUCT
CTE CONNECT TO EXISTING	MAXMAXIMUM	TOP TOP OF PIPE
CU COPPER	MBH1000 BTU/HR	TTS TIGHT TO STEEL
CUH CABINET UNIT HEATER	MD MOTORIZED DAMPER	TV TURNING VANE(S)
CV CONTROL VALVE	ME MECHANICAL ENGINEER	TYP TYPICAL
CW COLD WATER	MFR MANUFACTURER	UH UNIT HEATER
DC DOUBLE CONTAINED	MIN MINIMUM	UIC UP IN CHASE
DDC DIRECT DIGITAL CONTROL	MPVMULTI-PURPOSE VALVE	UIW UP IN WALL
DIA DIAMETER	MTD MOUNTED	UV UNIT VENTILATOR
DIC DOWN IN CHASE	MUAMAKE ÜP AIR	VAV VARIABLE AIR VOLUME BOX
DIW DOWN IN WALL	NPWNON-POTABLE WATER	VB VACUUM BREAKER
DN DOWN	NTS NOT TO SCALE	VCFF VALVED AND CAPPED FOR FUTURE
DT DROP AND TRANSITION	OA OUTSIDE AIR	VD MANUAL VOLUME DAMPER
DWGDRAWING	OBD OPPOSED BLADE DAMPER	VFD VARIABLE FREQUENCY DRIVE
DWHDOMESTIC WATER HEATER	OED OPEN ENDED DUCT	VOC VOLITILE ORGANIC COMPOUND
EA EXHAUST AIR	PAE PROCESS ACID EXHAUST	VTR VENT THROUGH ROOF
EF EXHAUST FAN	PHE PROCESS HEAT EXHAUST	W/ WITH

## **GENERAL NOTE:**

1. ALL GENERAL NOTES, SYMBOL LISTS, AND DETAILS ARE TO BE CONSIDERED AS APPLICABLE TO ALL MECHANICAL DRAWINGS FOR THIS PROJECT. SYMBOLS AND ABBREVIATIONS SHOWN ON THIS SHEET ARE FOR REFERENCE ONLY AND DO NOT INDICATE THEIR INCORPORATION INTO THE DESIGN.

ore Street/P.C.
Portland, Mai
tel. (207);
fax. (207); WIND OF MALE ) FOR PERMITTING 01.27.12 MAINE MEDICAL CENTER ANGIO SINGLE PLANE - ROOM GRAPHIC SCALE: SCALE: NOT TO SCALE PROJECT MANAGER: JC/DRAWN BY: A/E OF RECORD: PROJECT NO: SHEET TITLE: LEGEND AND **ABBREVIATIONS** 

M-001