

NOTE:
 1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

KEYED NOTES:

① IN EXISTING PANELBOARD EBB2 FURNISH & INSTALL A NEW 150A, THREE POLE CIRCUIT BREAKER TO FEED NEW SYMBIA T SPECT/CT POWER CONDITIONER. SEE PARTIAL ONE LINE DIAGRAM ON EP401 FOR WIRE SIZES.



② IN EXISTING PANELBOARD EQDP-CB UTILIZE AN EXISTING SPARE 15 AMP, SINGLE POLE CIRCUIT BREAKER TO FEED NEW PUMP P-1.

③ IN EXISTING PANELBOARD LPBAC1 UTILIZE FOUR EXISTING 20 AMP, SINGLE POLE CIRCUIT BREAKERS TO FEED NEW LIGHTS AND RECEPTACLES IN SPECT/CT AND HOT LAB. FURNISH & INSTALL ONE NEW 20 AMP, SINGLE POLE CIRCUIT BREAKER TO FEED NEW MED GAS ALARM PANEL.

④ IN EXISTING PANELBOARD LB REMOVE FOUR 20 AMP SINGLE POLE BREAKERS (CIRCUITS 7, 19, 21 AND 23) AND A 20 AMP, TWO POLE CIRCUIT BREAKER (CIRCUITS 9 AND 11) AND REPLACE WITH TWO NEW 15 AMP, THREE POLE CIRCUIT BREAKERS TO FEED NEW AIR HANDLER AND EXHAUST FAN.

144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 Tel. (207) 772-3846
 Fax. (207) 772-1070
 www.smartinc.com

ARCHITECTURE
 ENGINEERING
 PLANNING
 INTERIOR DESIGN
 COMMISSIONING



**MAINE MEDICAL CENTER
 NUCLEAR MEDICINE RENOVATIONS**
 PORTLAND, MAINE

**ISSUED FOR CONSTRUCTION
 3-13-14**

CURRENT ISSUE STATUS:

REV	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	3-13-14

GRAPHIC SCALE:
 0" 1"

SCALE: 1/8"=1'-0"
 PROJECT MANAGER: DJV
 JC/DRAWN BY: CDS
 A/E OF RECORD: DJT
 CAD FILE: E-100-12118
 PROJECT NO: 13128
 DATE: 3-13-14

SHEET TITLE:
**OVERALL
 PLAN**

SHEET No.
E-100
 © COPYRIGHT 2013 SMART INC.

A1 FLOOR PLAN

1/8"=1'-0"