





# Fire Protection Products



ENGINEERING JUDGMENT FOR:
01/05/15
Michael Palmacci
General Insulation
378 Commercial Street
Malden, MA 02148
Fax: (781) 321-5350

<b>Project:</b> Maine Med Bean 2	<b>Contractor:</b> Roland's Drywall
<b>Fire Stopping Category:</b> Joints / Head of Wall	<b>Hourly Rating Requested/ Type:</b> 1 and 2 Hour / F
<b>Joint Type:</b> Construction	<b>Maximum Joint Width:</b> 2 in.
<b>Floor Assembly:</b> Fluted Steel Deck/Concrete Floor	<b>Wall Assembly:</b> Gypsum Wallboard Assembly
<b>Type of Movement:</b> Dynamic	

<b>Special Conditions:</b> Field condition like UL System HW-D-0384 with deviation of max 8 in. joint between the wall and beam with spray applied fire resistive material (SFRM).	
<b>Application Details:</b> To firestop this application, install in accordance with UL System HW-D-0384 with the following modifications/clarifications: <ul style="list-style-type: none"> <li>1. Install a minimum 20 ga. steel cover plate to the bottom side of the beam to reduce the joint width to max 6 in. Steel cover plate to overlap onto beam a min. of 3 in. Cover plate to be mechanically fastened to beam using steel fasteners with minimum 75 lb pull out strength in conjunction with 1-1/4 in. steel washers every 4 in. on center.</li> </ul>	
<b>3M Fire Barrier Material:</b> FireDam Spray 200	
<b>Based On:</b> HW-D-0384	
This Engineering Judgment (EJ) is based upon the sole and exclusive use of 3M brand Fire Protection Products as described within. Modification of any of the parameters of this EJ, including, without limitation, the use of non-3M brand Fire Protection Products, shall render this EJ null and void. This fire-resistive joint design is expected to achieve the hourly rating indicated above. This engineering judgment is based on performance results obtained in testing with independent laboratories and / or internal 3M fire tests, which have been tested in accordance to ASTM E 1966 (UL 2079).	
Engineering Judgment Prepared By:  Carrie Meis Technical Service Technician	Reviewed By:  563994 cc: Ryan Fenstermaker

## 3M Building and Commercial Services Division

3M Center, Building 223-2N-20  
St. Paul, MN 55144-1000