

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

MAINE MEDICAL CENTER /Hebert Construction LLC

Located at

22 BRAMHALL ST

PERMIT ID: 2014-01647

ISSUE DATE: 08/20/2014

CBL: 053 D007001

has permission to **Alterations (Pavilion A - Ground Floor), which consist of relocating the existing boutique to the vacant conference room/lunch room area (510 SF).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Hospital

Building Inspections

Use Group: I-2

Type: 1A

Hospital

ENTIRE

MUBEC 2009

Fire Department

PERMIT ID: 2014-01647

Located at: 22 BRAMHALL ST

CBL: 053 D007001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Above Ceiling Inspection
Close-in Plumbing/Framing w/Fire & Draft Stopping
Electrical Close-in w/Fire & Draftstopping
Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-01647	Date Applied For: 07/24/2014	CBL: 053 D007001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Hospital	Proposed Project Description: Alterations (Pavilion A - Ground Floor), which consist of relocating the existing boutique to the vacant conference room/lunch room area (510 SF).			
Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 08/04/2014	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
Dept: Building	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 08/07/2014	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions shall be effectively and permanently identified with signs or stenciling per IBC Sec. 703.6				
2) Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
4) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 08/19/2014	
Note:				Ok to Issue: <input type="checkbox"/>
Conditions:				
1) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.				
2) All construction shall comply with City Code Chapter 10.				
3) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.				
4) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.				
5) Shall comply with NFPA 101, Chapter 19, Existing Health Care Occupancies.				
6) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model				