



**Revisions**

NO	ISSUE	DATE
1	ISSUED FOR PERMIT	06.11.14
1	ADDENDUM #1	07.28.14
1	ISSUE FOR BID	07.11.14
NO	ISSUE	DATE

  

Sheet Information	
Date	JULY 11, 2014
Job #	132188.010
Drawn	GN
Checked	RAC
Approved	XXX

**ELECTRICAL  
POWER PLAN**

**POWER GENERAL NOTES:**

1. REFER TO SHEET E-000 FOR LEGEND, SYMBOLS, ABBREVIATIONS, AND GENERAL NOTES

**POWER KEYED NOTES:**

- ① ELECTRICAL CONTRACTOR SHALL PROVIDE DEDUCT ALTERNATE TO UTILIZE ALL CIRCUITS MADE SPARE FROM DEMOLITION AND CONFIRM QUANTITIES OF SPARE CIRCUITS (FROM DEMOLITION) MATCH QUANTITY OF NEW CIRCUITS INDICATED ON POWER PLAN
- ② FIELD COORDINATE EQUIPMENT CONNECTION TYPE.
- ③ DEVICES TO BE MOUNTED WITHIN DESK, COORDINATE MOUNTING REQUIREMENTS WITH ARCHITECTURAL PLANS AND DETAILS.
- ④ COORDINATE CAMERA LOCATIONS WITH AMG SECURITY GROUP AND ARCHITECT. (TYPICAL)
- ⑤ CIRCUIT NUMBERS SHOWN TO DENOTE LIMITS OF CIRCUIT ONLY. EXACT CIRCUIT NUMBERS SHALL BE FIELD VERIFIED. FURNISH NEW CIRCUIT BREAKERS AS INDICATED. CIRCUIT BREAKER CHARACTERISTICS SHALL BE FIELD VERIFIED. ALL CIRCUITS SHALL BE INSTALLED WITHIN AC RATING THAT MEET OR EXCEEDS THE AVAILABLE FAULT AND EQUIPMENT AT THE POINT OF INSTALLATION.

