



**Revisions**

NO.	ISSUED FOR PERMIT	DATE
1	ISSUED FOR PERMIT	08.11.14
1	ADDENDUM #1	07.28.14
NO	ISSUE FOR BID	07.11.14
NO	ISSUE	DATE

  

Sheet Information	
Date	JULY 11, 2014
Job #	1524168.010
Drawn	TU
Checked	DKR
Approved	DKR

**MECHANICAL  
PIPING PLAN**

- GENERAL NOTES:**
1. RELOCATE EXISTING T-STAY TO LOCATION SHOWN ON PLAN (TYP.)
  2. MAINTAIN ACCESS TO ALL NEW AND EXISTING VALVES, FIRE DAMPERS AND VAV BOXES.
  3. LOCATE ALL NEW VAV CONTROL AND ISOLATION VALVES IN SAME ROOM CEILING AS VAV BOX.

- DRAWING KEY NOTES:**
- RE-BALANCE EXISTING SA VAV BOX AS INDICATED BELOW.

**SUPPLY TERMINAL BOXES:**

①	②	③	④
001	002	003	004
0.3	0.6	1.2	1.0
0.3	0.6	1.2	1.0
VAV-1	(E) VAV	(E) VAV	(E) VAV
(NEW)			

