

**Building Inspections - Sprinkler Permit Application for 22 Bramhall St ME Medical Center
Central Sterile Dept Renovation**

From: Derek Narvaez <dnarvaez@deanandallyn.com>
To: Building Inspections <buildinginspections@portlandmaine.gov>
Date: 11/9/2014 9:57 AM
Subject: Sprinkler Permit Application for 22 Bramhall St ME Medical Center Central Sterile
Dept Renovation
Attachments: MMC CSD FP-00 REV 0.pdf; SKMBT_42014110906370.pdf

Please submit for approval the attached Sprinkler Permit application.
The scope of work is limited to the relocation of existing sprinkler drops and addition of 10 sprinkler heads per NFPA 13.
The additional sprinkler heads do not affect the existing design demand for the existing system and therefore the attached sprinkler plan is being submitted without hydraulic calculations, thank you.

Derek Narvaez
Estimator
Dean & Allyn, Inc.
P - 207-657-5646
F - 207-657-5647
Certified D/WBE