

Temporary Certificate of Use for Medical Gas Systems
(Valid Until Final Report is Received)

Facility: <u>Maine Medical</u>	Date: <u>2/12/16</u>
Area of Facility: <u>OR #6</u>	Location: <u>Portland, ME</u>


The following tests and inspections were performed for Certification of the Medical Gas Systems as required by NFPA 99, current edition and per the requirements of NFPA 55, current edition.

- 1.) The standing pressure test was completed as required by Section 5.1.12.3.2.
- 2.) There were no cross connections within the medical gas pipeline system as required by Section 5.1.12.3.3.
- 3.) All new valves were tested to verify proper operation and room or areas of control as required by Section 5.1.4. and 5.1.12.3.4.
- 4.) All components installed were properly labeled as required by Section 5.1.12.3.13.
- 5.) A piping purge test as required by Section 5.1.12.3.6 was conducted on each portion of the positive pressure pipeline system installed and a piping particulate test was performed as required by Section 5.1.12.3.7. The gas that was dispensed was of the proper concentration as required by Section 5.1.12.3.11 and within the levels required by Section 5.1.12.3.12 for new medical air systems.
- 6.) Each portion of the positive pressure medical gas system used for patient application installed was tested for particulate contaminants as required by Section 5.1.12.3.7 and piping purity as required by 5.1.12.3.8.
- 7.) The medical gas alarm systems installed were tested as required by Section 5.1.12.3.5.
- 8.) A final tie-in test was completed as required by Section 5.1.12.3.9.
- 9.) An operational pressure test was completed as required by Section 5.1.12.3.10.
- 10.) Labeling and signage was verified as required by Section 5.1.12.3.13 and 5.1.13.2.

Systems Tested and Inspected: The installation of new outlets & inlets and associated new zone and service valves, new piping that serve OR #6

Oxygen System	<input checked="" type="checkbox"/>	Medical Air System	<input checked="" type="checkbox"/>	Nitrous Oxide System	<input checked="" type="checkbox"/>
Nitrogen System	<input checked="" type="checkbox"/>	Carbon Dioxide System	<input checked="" type="checkbox"/>	Medical Vacuum System	<input checked="" type="checkbox"/>
WAGD Vacuum System	<input checked="" type="checkbox"/>	Other:		Other:	

The final report will consist of all test data and a comprehensive review of the medical gas system verification. All parties should read this report carefully. Only areas identified in the report are included in this certification. This certification shall be voided if at anytime adjustments, modifications, or maintenance is performed on the systems identified above.

Verified By:  Date: 2/12/16
 ASSE 6030 Certified Medical Gas Systems Verifier