DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

MAINE MEDICAL CENTER

Located at

22 BRAMHALL ST

PERMIT ID: 2016-00307 **ISSUE DATE:** 03/24/2016

CBL: 053 D007001

has permission to Finish upgrades to an administrative area and add a window. ESB Building; Ground Floor, room G928

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED. A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning Hospital **Building Inspections**

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Framing Only Electrical - Commercial Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

| City of Portland, Maine - Building or Use Permit | | Permit No: | Date Applied For: | CBL: |
|---|----------|---|--------------------------------------|----------------------------------|
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87 | 74-8716 | 2016-00307 | 02/10/2016 | 053 D007001 |
| Proposed Use: Proposed Project Description: | | | | |
| Maine Medical Hospital | | pgrades to an adn g; Ground Floor, r | ninistrative area and a noom G928 | ıdd a window. ESB |
| Dept: Zoning Status: Approved Re | eviewer: | Christina Stacey | Approval Da | te: 03/01/2016 |
| Note: | | j | | Ok to Issue: 🔽 |
| Conditions: | | | | |
| | | | | |
| Dept: Building Inspecti Status: Approved w/Conditions Revenue Note: Revenue | eviewer: | Tammy Munson | Approval Da | te: 03/03/2016 Ok to Issue: ☑ |
| Conditions: | | | | |
| 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. | | | | |
| 2) All fire separation partitions, barriers and horizontal assemblies at adjacent occupancies or dwelling units shall maintain rating and continuity. | | | | |
| 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. | | | | |
| Dept: Engineering DPS Status: Not Applicable Ro | eviewer: | Rachel Smith | Approval Da | te: 02/16/2016 |
| Note: | | | | Ok to Issue: |
| Conditions: | | | | |
| 1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and | | | | |
| Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov | | | | |
| Dept: Fire Status: Approved w/Conditions Re | eviewer: | Craig Messinger | Approval Da | te: 03/22/2016 |
| Note: | | | | Ok to Issue: 🗹 |
| Conditions: | | | | |
| 1) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation. | | | | |
| 2) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation. | | | | |
| 3) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve. | | | | |
| 4) Shall comply with NFPA 101, Chapter 39, Existing Business Occupancies. | | | | |
| 5) All construction shall comply with City Code Chapter 10. | | | | |
| 6) All construction shall comply with City Code Chapter 10. | | | | |