

TH SPRINKLER

~~~	

	SMOKE BARRIER WITH TWO HOUR MIN. FIRE RATED CONSTRUCTION
	SMOKE BARRIER WITH ONE HOUR MIN. FIRE RATED CONSTRUCTION
• •	LIMIT TRANSFER OF SMOKE (NO FIRE-RESISTANT RATING)
	TWO HOUR FIRE RATED BUILDING SEPARATION
_	TWO HOUR FIRE BARRIER
_	ONE HOUR FIRE BARRIER
	NEW PARTITION
	EXISTING PARTITION
	WATER CURTAIN - REFER TO FP DRAWINGS FOR DETAIL
	OUT OF SCOPE
	TRAVEL DISTANCE: LONGEST ROUTE TO AN EXIT
	COMMON PATH: DISTANCE TRAVELED BEFORE AN EXT PATH IS CHOSEN
	MAGNETIC HOLD OPEN
	EXIT / STAIR
	EXIT LOCATION - OCCUPANT LOAD AND WIDTH (IN INCH — ACTUAL CLEAR WIDTH PROVIDED — MAXIMUM ALLOWED OCCUPANTS PER EXIT (IBC 1005.3 — REQUIRED MINIMUM WIDTH PER OCCUPANCY (IBC 100 — CALCULATED ACTUAL OCCUPANTS PER EXIT (IBC 1004

## CODE COMPLIANCE PLAN GENERAL NOTES

ADDRESS: Maine Medical Center 22 Bramhall Street Portland, ME 04102 APPLICABLE CODES AND STANDARDS:

2009 International Building Code

FIRE PREVENTION: NFPA 101: Life Safety Code, 2009 Edition Chapter 19: Existing Health Care Occupanices Portland Fire Prevention Fire Code

2006 NFPA 1 Required Fire Protection Systems:

NFPA 13 sprinkler system (2009 IBC 407.5) Fire alarm system (2009 IBC 407.6) Standpipe system (2009 IBC 905.3.1) Fire extinguishers (2009 IBC 906.1)

ACCESSIBILITY: Maine Human Rights Commission

ELECTRICAL:

MECHANICAL:

ASHRAE 62.2 - 2007

ENERGY CONSERVATION:

2009 International Energy Conservation Code

NFPA 101 Applicable Code Year: 2000 Edition

CONSTRUCTION TYPE:

TYPE II-A (TABLE 601) FIRE SPRINKLERED THROUGHOUT:

OCCUPANCY GROUPS:

IBC - CONSTRUCTION TYPE 1B NFPA 101 - CONSTRUCTION TYPE II(222)

