### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

MAINE MEDICAL CENTER

Located at

22 BRAMHALL ST

**PERMIT ID:** 2016-02720

**ISSUE DATE:** 02/01/2017

CBL: 053 D007001

has permission to Finish upgrades-add positive pressure to 2 patient rooms

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Laurie Leader

Fire Official

**Building Official** 

Type: 1B

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

Use Group: 1-2

Hospital

Building is sprinkled

**6TH FLOOR** 

MUBEC/IBC 2009

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

# Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

**Above Ceiling Inspection** 

Electrical Close-in w/Fire & Draftstopping

Final - Flectric

Final - Fire

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed				Permit No: 2016-02720	Date Applied For: 10/18/2016	CBL: 053 D0070	001
				Proposed Project Description:			
Hospital	- Maine Medical Center		Finish t	ipgrades-add posit	tive pressure to 2 pati	ent rooms	
Dept: Note: Condit	-	Approved	Reviewer:	Jennifer Thompso	• •	ote: 01/17/ Ok to Issue:	_
Dept: Note: Condit				Laurie Leader		Ok to Issue:	_
Condit	arate permits are required for	or any electrical, plumbing, spr		•		ing appliance	ing appliances, including

- approval as a part of this process.
- 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

**Dept:** Engineering DPS **Status:** Not Applicable **Reviewer:** Rachel Smith 10/25/2016 **Approval Date:** Ok to Issue: Note:

#### **Conditions:**

1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801.

**Reviewer:** Michael White 10/26/2016 **Dept:** Fire **Status:** Approved w/Conditions **Approval Date:** Ok to Issue: ✓ Note:

#### **Conditions:**

- 1) A separate Fire Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.
- 2) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.
- 3) The property owner or occupant shall not make changes in the occupancy, the use or process, or the materials used or stored in the building without evaluation of the fire protection systems for their capability to protect the new occupancy, use, or materials. (2009) NFPA 1, Chapter 13.3.4.1.5)
- 4) If applicable, all outstanding code violations shall be corrected prior to final inspection.
- 5) All means of egress to remain accessible at all times.
- 6) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation.
- 7) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).
- 8) All construction shall comply with City Code, Chapter 10.

Located at: 22 BRAMHALL ST **PERMIT ID:** 2016-02720 **CBL:** 053 D007001