.1. MECHANICAL NEW WORK PLAN
M2.0 1/4" = 1'-0"

## MECHANICAL NEW WORK NOTES

- 1 INSTALL TEMPERATURE SENSOR IN LOCATION OF PREVIOUS THERMOSTAT AND CONNECT TO EXISTING CONTROL WIRING.
- 2 RE-BALANCE EXISTING CEILING TERMINAL AIRFLOW TO MAINTAIN PERFORMANCE AS MEASURED PRIOR TO COMMENCEMENT OF WORK. REFER TO DEMOLITION PLAN.

MECHANICAL GENERAL NOTE

RE-BALANCE ASSOCIATED VAV TERMINAL UNIT(S) TO MAINTAIN EXISTING FLOW AS MEASURED PRIOR TO COMMENCEMENT OF WORK, +/- FLOW DIFFERENTIAL RESULTING FROM RENOVATION DESIGN REQUIREMENTS.

## morris Switzer environments for health

Williston, Vermont Boston, Massachusetts Portland, Maine

© 2014 MorrisSwitzer

183 Middle Street
Portland, ME 04101
t 207.773.8841
f 207.773.8840
morrisswitzer.com

DD Approval Signature

Project North

Key Plan N.T.S.

Issued For Construction

Portland, Maine

## Psych Room Renovation

MorrisSwitzer Project Number 201451

Date 1/27/2017

Scale As indicated

Sheet Title and Number

MECHANICAL NEW WORK PLAN

GRAPHIC SCALE

2' 0 4' 8' 12'

SCALE: 1/4" = 1' - 0"