



Glenn Harmon <gharmon@portlandmaine.gov>

22 Bramhall St - Chapel

Stephen Janosco <sjanosco@hebertconstruction.com>

Wed, Nov 29, 2017 at 8:18 AM

To: Glenn Harmon <gharmon@portlandmaine.gov>

Cc: David Moore <dmoore@hebertconstruction.com>, Stephen Janosco <sjanosco@hebertconstruction.com>

Glenn, Demo Plan Attached

The Occupant Load for the space should be 45 for an Assembly Occupancy. (315 sqft/ 7sqft per person)

Not sure what you are looking for regarding the IEBC Category. The renovations are a finishes upgrade. We are not making any alterations to the exterior wall or windows.

Sent from my U.S. Cellular® Smartphone

[Quoted text hidden]

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

 **Chapel Demo plan.pdf**
52K