

MEDICAL GAS ALARM PANEL SCHEDULE										
TAG	MANUFACTURER	LOCATION	O2	MA	MV	N	NO	WAGD	A	REMARKS
AAP-6-1	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-6-2	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-6-3	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-6-4	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-6-5	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-6-6	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-6-7	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-1	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-2	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-3	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-4	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-5	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-6	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	
AAP-7-7	BEACON MED GAS	NURSES STATION	X	X	X	-	-	-	-	

MEDICAL GAS ZONE VALVE BOX SCHEDULE										
TAG	MANUFACTURER	LOCATION	O2	MA	MV	N	NO	WAGD	A	REMARKS
ZVB-6-1	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-6-2	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-6-3	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-6-4	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-6-5	BEACON MED GAS	CORRIDOR	1/2"	3/4"	2"	-	-	-	-	
ZVB-6-6	BEACON MED GAS	CORRIDOR	1/2"	3/4"	2"	-	-	-	-	
ZVB-6-7	BEACON MED GAS	CORRIDOR	1/2"	3/4"	2"	-	-	-	-	
ZVB-7-1	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-7-2	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-7-3	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-7-4	BEACON MED GAS	CORRIDOR	3/4"	3/4"	2"	-	-	-	-	
ZVB-7-5	BEACON MED GAS	CORRIDOR	1/2"	3/4"	2"	-	-	-	-	
ZVB-7-6	BEACON MED GAS	CORRIDOR	1/2"	3/4"	2"	-	-	-	-	
ZVB-7-7	BEACON MED GAS	CORRIDOR	1/2"	3/4"	2"	-	-	-	-	

MEDICAL GAS OUTLET FIXTURE SCHEDULE										
TAG	MANUFACTURER	LOCATION	O2	MA	MV	N	NO	WAGD	SLIDE	REMARKS
A	BEACON MED GAS	PATIENT ROOM HEADWALL	3	3	6	-	-	-	6	

PUMPS SCHEDULE										
TAG	DESCRIPTION	INLET SIZE	TANK SIZE	ELECTRICAL CHARACTERISTICS	CAPACITY	REMARKS				
MVP-50-01	MEDICAL VACUUM PUMP "BEACON MED GAS" NO. VHS010-200V-QV	4"	200 GAL.	(4) 7.5 HP 480 V 3	150 SCFM @ 10" HG (SYSTEM)					

HOT WATER RECIRCULATION PUMP SCHEDULE										
SYMBOL	FLOW	PRESSURE (FT)	ELECTRICAL CHARACTERISTICS				MANUFACTURER & MODEL	REMARKS		
CRG-05-1	15	35'	1/2	208	1	-	GRUNDFOS MODEL CM3-2-ASE-QQE			
CRG-05-2	15	35'	1/2	208	1	-	GRUNDFOS MODEL CM3-2-ASE-QQE			
CRG-05-3	5	15'	1/4	120	1	-	GRUNDFOS MODEL CM1-2-ASE-QQE			

STEAM FIRED DOMESTIC WATER HEATER SCHEDULE										
SYMBOL	DESCRIPTION	LOCATION	QTY	RECOVERY	TEMP	MANUFACTURER & MODEL	REMARKS			
DWH-05-1	DOMESTIC WATER HEATER FOR DIALYSIS LOOP	MECHANICAL 5TH FLOOR	1	22 GPM 80°	120°	PATTERSON KELLY MODEL PH80	SEMI INSTANTANEOUS W/ 10 PSI STEAM ELEVATE CONDENSATE OUTLET AS REQUIRED. THERMAL EXPANSION TANK BELL AND GOSSETT MODEL PTA-12 LAWLER 800 SERIES TMY			

PLUMBING FIXTURE SCHEDULE										
FIXTURES	FIXTURE #			SERVICE CONNECTION				MANUFACTURER AND EQUIPMENT	MODEL NO.	REMARKS
SINKS	SK-1	SK-2	SK-3	S	W	Y	CW	HW	TW	
SOLID SURFACE - PATIENT ROOM SINGLE BOWL	●			-	2"	2"	10"	10"	-	SOLID SURFACES BY ARCHITECT CHICAGO FACET. GOOSENECK, WRISTBLADE HANDLE. 1.5 GPM. 4" FIXED CENTERS. MCGUIRE MANUFACTURING. P-TRAP W/ CLEANOUT. PROVIDE WITH ELKAY MODEL NO. LK55 STRAINER AND TAIL PIECE. PROVIDE MCGUIRE BALL VALVE MODEL NO. LFBV082
SOLID SURFACE - CORRIDOR SINGLE BOWL	●			-	2"	2"	10"	10"	-	SOLID SURFACES BY ARCHITECT CHICAGO FACET. GOOSENECK, WRISTBLADE HANDLE. 1.5 GPM. 4" FIXED CENTERS. MCGUIRE MANUFACTURING. P-TRAP W/ CLEANOUT. PROVIDE WITH ELKAY MODEL NO. LK55 STRAINER AND TAIL PIECE. PROVIDE MCGUIRE BALL VALVE MODEL NO. LFBV082
STAINLESS STEEL SINGLE BOWL UNDERMOUNT	●			-	2"	2"	10"	10"	-	ELKAY LITERATURE 10" X 10" X 12" CHICAGO FACET. GOOSENECK, WRISTBLADE HANDLE. 1.5 GPM. 4" FIXED CENTERS. MCGUIRE MANUFACTURING. P-TRAP W/ CLEANOUT. PROVIDE WITH ELKAY MODEL NO. LK55 STRAINER AND TAIL PIECE. PROVIDE MCGUIRE BALL VALVE MODEL NO. LFBV082
LABORATORIES	L1	L2		S	W	Y	CW	HW	TW	
SOLID SURFACE - PATIENT ROOM (ADA ACCESSIBLE)	●			-	2"	2"	10"	10"	-	SOLID SURFACES BY ARCHITECT CHICAGO FACET. WRISTBLADE HANDLE. 1.5 GPM. TRUESDOR ADA KIT. MCGUIRE MANUFACTURING. GRID DRAIN. MCGUIRE MANUFACTURING. P-TRAP W/ CLEANOUT. PROVIDE WITH ELKAY MODEL NO. LK55 STRAINER AND TAIL PIECE. PROVIDE MCGUIRE BALL VALVE MODEL NO. LFBV082
SOLID SURFACE - PUBLIC (ADA ACCESSIBLE)	●			-	2"	2"	10"	10"	-	SOLID SURFACES BY ARCHITECT CHICAGO FACET. WRISTBLADE HANDLE. 1.5 GPM. TRUESDOR ADA KIT. MCGUIRE MANUFACTURING. GRID DRAIN. MCGUIRE MANUFACTURING. P-TRAP W/ CLEANOUT. PROVIDE WITH ELKAY MODEL NO. LK55 STRAINER AND TAIL PIECE. PROVIDE MCGUIRE BALL VALVE MODEL NO. LFBV082
WATER CLOSET	WC-1	WC-2		S	W	Y	CW	HW	TW	
FLOOR MOUNTED FLUSH VALVE (PRIVATE - ADA ACCESSIBLE)	●			4"	-	2"	5-1/4"	-	-	AMERICAN STANDARD: MADERA ELONGATED SLOAN. MANUAL ROYAL FLUSH VALVE. 1.28 GPF. CHICAGO FACET. FEED. VALVE. BE37PA CLEANER WITH LOOSE KEY BEAMS. ELONGATED COMMERCIAL, OPEN FRONT TOILET SEAT WITH COVER. 3043 001 ROYAL 115-1.28 190-0772-11" MCP 1950 000
FLOOR MOUNTED FLUSH VALVE (PUBLIC - ADA ACCESSIBLE)	●			4"	-	2"	5-1/4"	-	-	AMERICAN STANDARD: MADERA ELONGATED SLOAN. MANUAL FLUSH VALVE. 1.28 GPF. BEAMS. ELONGATED COMMERCIAL, OPEN FRONT TOILET SEAT WITH COVER. 3043 001 ROYAL 115-1.28 1950 000
SHOWER	SH-1	SH-2		S	W	Y	CW	HW	TW	
ROLL IN SHOWER (ADA ACCESSIBLE)	●			-	2"	2"	10"	10"	-	TILE IN PLACE. SYMONS: TRIMPTOL SHOWER & HAND SHOWER SYSTEM. JR SMITH. SQUARE 5"x7" CHROME PLATED STRAINER. 96-500-830-L-V-1.5 2005
PUBLIC SHOWER (ADA ACCESSIBLE)	●			-	2"	2"	10"	10"	-	TILE IN PLACE. SYMONS: TRIMPTOL SHOWER & HAND SHOWER SYSTEM. JR SMITH. SQUARE 5"x7" CHROME PLATED STRAINER. 96-500-830-L-V-1.5 2005
MCP SINK BASIN	MSB-1			S	W	Y	CW	HW	TW	
RECEPTOR	●			-	3"	2"	3/4"	3/4"	-	FLAT. 24" X 24" X 1/4" MOLDED STONE. FAT. BARBERSBURG. MOP HANGER. FAT. HOSE AND HOSE BRACKET. CHICAGO FACET. MSB FACET. INTEGRAL CHECK VALVE. MSB-204 6.7" AL. 889-CC. 832 AA 891 CCP
BOTTLE FILLER	BF-1			S	W	Y	CW	HW	TW	
BOTTLE FILLING STATION (ADA ACCESSIBLE)	●			-	2"	2"	10"	-	-	ELKAY EZHD. IN WALL BOTTLE FILLING STATION. FILTERED 8 GPH STAINLESS. LZ958MK
EMERGENCY EYE WASH	EW-1	EW-2		S	W	Y	CW	HW	TW	
DECK MOUNTED EYEWASH DRAIN HOSE UNIT	●			-	-	-	10"	10"	-	GUARDIAN. EYEWASH/DRENCH HOSE STATION. LEONARD. MIMING VALVE. 09022 TA-300
WALL MOUNTED EYEWASH/DRENCH HOSE UNIT. 12' COILED HOSE	●			-	-	-	10"	10"	-	GUARDIAN. EYEWASH/DRENCH HOSE STATION. LEONARD. MIMING VALVE. 09046 TA-300

DRAIN SCHEDULE												
REVISION	REQUIRED	BODY										REMARKS
		FD-A	●	JR SMITH MODEL 2009B	●							
TD-A	●	INFINITY DRAIN MODEL S-AG 100	●									TRENCH DRAIN
RD-A	●	JR SMITH MODEL 1010E	●									PRIMARY ROOF DRAIN. REFER TO ARCHITECT FOR EXTENSION COLLAR DIMENSIONS. EXTENSION COLLAR SHALL BE ORDERED WITHOUT WEEP HOLES

- NOTES:
- ALL FLOOR DRAINS IN FINISHED AREAS AND ALL ROOF DRAINS SHALL BE LOCATED AS PER THE ARCHITECTURAL DRAWINGS.
 - ALL FLOOR DRAINS IN MECHANICAL EQUIPMENT, BOILER ROOMS, FAN ROOMS ETC. SHALL BE LOCATED IN COORDINATION WITH THE MECHANICAL CONTRACTOR.
 - THE CONTRACTOR SHALL VERIFY THE COMPATIBILITY OF THE DRAINS WITH THE APPROVED ROOFING AND/OR WATER PROOFING SYSTEMS PRIOR TO SUBMITTING SHOP DRAWINGS.
 - THE TOP OF CURVE OF ALL FLOOR DRAINS SHALL BE FLUSH WITH THE ADJACENT FINISHED FLOOR.

PERKINS + WILL
 225 Franklin Street, Suite 1100
 Boston, MA 02110
 617.478.0300
 617.478.0321
 www.perkinswill.com

CLIENT
Maine Medical Center
 MaineHealth

22 Bramhall Street
 Portland, ME 04102

CONSULTANTS
 CIVIL/LANDSCAPE ARCHITECT
Sebago Technics
 75 John Roberts Road, Suite
 1A, South Portland, ME 04106

STRUCTURAL ENG./BUILDING ENVELOPE CONSULTANT
Singston Gumpertz & Hager Inc.
 41 Seaver Street, Building 1, Suite 570
 Waltham, MA 02453

MEP/ELECTRICAL ENGINEER
AKF Group LLC
 99 Bedford Street, 2nd Floor, Boston, MA 02111

CONSTRUCTION MANAGER
Turner Construction
 2 Seaport Lane, Suite 200, Boston, MA 02210

ELEVATOR CONSULTANT
VDA (Van Deusen & Associates)
 101 Summer Street, 4th Floor, Boston MA
 02110

COST ESTIMATOR
D. G. Jones International
 3 Baldwin Green Common, Suite 202, Auburn, MA 01501

PROJECT TITLE
East Tower 6 & 7 Addition
 22 Bramhall Street
 Portland, ME 04102

KEY PLANS
PROJECT KEY PLAN
 1 EAST TOWER
 2 RICHARDS BUILDING

OVERALL KEY PLAN
 1 - GILMAN GARAGE
 2 - CONGRESS STREET
 3 - VISITOR GARAGE
 4 - EAST TOWER
 5 - CENTRAL UTILITY PLANT
 6 - BEAN BUILDING
 7 - RICHARDS BUILDING
 8 - MAINE GENERAL BUILDING

CONSTRUCTION DOCUMENTS
 JANUARY 28, 2018

1	ADDENDUM NO. 1	03/22/18
NO	ISSUE	DATE

Job Number: B150312-000
 Drawn: DCC
 Checked: PJR
 Approved: PJR

TITLE
PLUMBING SCHEDULES
 SHEET NUMBER
P00-11

Copyright 2017 © Perkins+Will

C:\Revit Local Files_B150312\000\MDC East Tower 6&7 MEP17_Constr.plumbing.rvt
 3/23/2018 11:36:12 AM