



WIKIZ ARE SIMPLE SPAN NO MOM. CONN. REQ'D

WIKIZ READORS

TR0 PROVIDE SHAFT DIMS

WIKIZ IS SIMPLE SPAN NO MOM. CONN.

ADD NON-SEISMIC MOMENT CONN.

ATTACH REL TO COLUMNS @ CORNERS

HANG OFF W/2 WITH 12" CAP W/ 2" END

NO C.W. CURTAIN WALL DET. TS-21A7

ADD LOWER LEVEL OF STEEL HANGERS (6'-2") FOR SHAFTS PER ADD #5

TR0 TO VERIFY LOCATIONS OF REL. LS @ SLAB EL.

PROVIDE SHELF L'S @ SLAB ENTIRE PERIMETER EXCEPT @ WALLS PER TS-21A/S103

TR0 PROVIDE EXTENT OF ROOF

SEE SECTIONS IN ADD #5 FOR HANG UNTIL HERE

ONLY ONE BEAM 18-B IS GROUND FLOOR

HANGER, KICKER BEAM TO SUPPORT FIRE DOOR PER ADD #5

WIKI109

COOLING BREAKS WITH RFI OIT

TR0 TO PROVIDE REINFORCING TO EL. @ H.B. TOP EDGE OF BEAM + LENGTH OF CANTILEVER

WIKI108 W/2 HAS 2x3 HANGERS OVER FIRE DOOR SEE ADD #5

SEE 3/SS03 FOR CONNECTION TO CONCRETE. NO HANG UNITS IN THIS AREA

TR0 TO PROVIDE LENGTH OF OVERHANG.

STEEL IS 2" x 8" PROVIDE DET. 10/SS03

VIF + SEE DET. 10/SS03

SEE DET 10/SS03

TR0 TO PROVIDE DIM WHERE REL. L CHANGES EL. DET. 9.9/A/E/S

COORD. WITH ADD #5

ADD 3 HANGERS @ 2" L/21 W/2 FOR HANG W/2 T.M.

TR0 PROVIDE EL TOP OF HANG W/2 FOR MOMENT CONNECTION

PROVIDE SEISMIC MOMENT CONN (F.9)

NON-SEISMIC MOM. CONN.

RECEIVED
MAY 10 2006
Simpson Gumpertz & Heger Consulting Engineers Inc.

APPROVED NOT APPROVED
 APPROVED AS CORRECTED
 REVISE AND RESUBMIT
 RESUBMIT FOR RECORD COPY

Checking is only for conformance with the design concept of the project and compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and controlled at the job site, for information that pertains solely to the fabrication process or to techniques of construction, and for coordination of the work of all trades.

BY: *M. J. [Signature]*
DATE: 19 May 06
SIMPSON GUMPERTZ & HEGER INC.
CONSULTING ENGINEERS
41 SEYON ST., BUILDING 1, SUITE 500
WALTHAM, MA 02453

WILLIAM A. BERRY & SON, INC.
REVIEWED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

"THE SUBCONTRACTOR/VENDOR IS RESPONSIBLE FOR ALL DIMENSIONS, CORRECT FIT AND COORDINATION OF ALL ITEMS TO BE FURNISHED & INSTALLED."

DATE: 5-8-06
JOB # 043100
SUBMISSION # 0512-13
SPEC. DRAWING REF.

REVIEWED FOR CONSTRUCTIBILITY

FOR APPROVAL
MAY 02 2006

NOVEL IRON WORKS
250 Ocean Road
Greenland, NH 03840

No.	Date	Description	Revisions	Notes	By (Lmo)	Hold	ER205	AISC Certified Category III

Project	Maine Medical Center	Date:	Apr-06
Description	2nd Floor Framing Plan	Drawn By:	TD
Architect	TR0	Chk By:	K.J.L.
Engineer	Simpson Gumpertz & Heger Inc.	Job No.:	318
Customer	William Berry & Son Inc.	Sh. No.:	EB