



5th Floor Framing Plan
 Top Of Steel EL. 205'-11 3/4" u/r
 • Indicates Seismic Moment Connection - 1" Dia A490SC Bolts
 • Indicates Non Seismic Moment Connection
 ⊙ Indicates 1" Dia Bolts

TRC TO PROVIDE LOCATIONS WHERE DETAIL 4/EIS APPLIES, IF ANY.

Detail 4/EIS applicable here

SHIFT AS REQ'D

SHIFT W/BEAM TO ALIGN WITH COL SPACE OTHER W/IS E.G. AS SHOWN

W/BEAM TO LOCATE W/IS TO LOCATE IN E/IS. REMOVE BEAM

USE SAME T/S THRU

NO CHANGE REQ'D

TRC TO VERIFY BEAM DETAIL

OK TRC

OK TRC

SEE E 9 T/E

TRC PROVIDE

SEE E/D NOTE

Approved ()
 If checked above, information MAY be undertaken. Approval does not authorize changes to Contract Documents listed in separate letter or Change Order.
 If checked below, information MAY NOT be undertaken. Resubmit contract changes for final approval. Correction shall be limited to those marked.
 Review and Resubmit ()
 Not Approved ()
 Reviewing is only for conformance with the design intent of the project and compliance with the information given in the Contract Documents. The Contractor is responsible for dimensions, fit and coordination of all trades. The Contractor shall be responsible for the coordination of the work of all trades.
 THE FITCHIE ORGANIZATION
 Date: 8/30/06 By: AJO

RECEIVED

AUG 14 2006

Simpson Gumpertz & Heger
 Consulting Engineers Inc.
 APPROVED AS NOT APPROVED
 APPROVED AS CORRECTED
 REVISE AND RESUBMIT
 RESUBMIT FOR RECORD COPY
 Checking is only for conformance with the design concept of the project and compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and correlated at the job site for information that pertains solely to the fabrication process or to techniques of construction and coordination of the work of all trades.
 BY: MJB/duc
 DATE: 29 AUG 06
 SIMPSON GUMPERTZ & HEGER INC.
 CONSULTING ENGINEERS
 41 SEYON ST., BUILDING 1, SUITE 500
 WALTHAM, MA 02453

WILLIAM A. BERRY & SON, INC.
 REVIEWED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
 THE SUBCONTRACTOR/VENDOR IS RESPONSIBLE FOR ALL DIMENSIONS, CORRECT FIT AND COORDINATION OF ALL ITEMS TO BE FURNISHED & INSTALLED.
 BY: MJC
 DATE: 8-3-06
 JOB #: 04-310-0
 JOB NAME: MAC-CHARLES ST.
 SUBMISSION #: 2121-DIG-2
 SPEC. CONT. REF.
 REVIEWED FOR CONSTRUCTABILITY

FOR APPROVAL
 JUL 31 2006

TRC

NOVEL IRON WORKS
 250 Ocean Road
 Greenland, NH 03840

No.	Date	Description	Project	Notes	Drawn By	Checked By	ATSC Certified Category III
1	31-07-06	UPDATED TO SHIT APPROVAL	Maine Medical Center				
			5th Floor Framing Plan				
			Simpson Gumpertz & Heger Inc.				
			WILLIAM BERRY & SON INC.				