



5th Floor Framing Plan
 Top Of Steel EL 205'-11 3/4" u/n
 • Indicates Seismic Moment Connection - 1" Dia A490SC Bolts
 • Indicates Non Seismic Moment Connection - 3/4" Dia A325SC Bolts
 • Indicates 1" Dia A490N Bolts

APPROVED NOT APPROVED
 APPROVED AS CORRECTED
 REVISE AND RESUBMIT
 RESUBMIT FOR RECORD COPY
 Checking is only for conformance with the design concept of the project and compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and controlled at the job site; for information that pertains solely to the fabrication processes or to techniques of construction; and for coordination of the work of all trades.
 BY: *M. Bolduc*
 DATE: 05/09/06
 SIMPSON GUMPERTZ & HEGER INC.
 41 SEVON ST., BUILDING 100
 WALTHAM, MA 01981

WILLIAM A. BERRY & SON, INC.
 REVIEWED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
 THE SUBCONTRACTOR/VENDOR IS RESPONSIBLE FOR ALL DIMENSIONS, CORRECT FIT AND COORDINATION OF ALL ITEMS TO BE FURNISHED & INSTALLED.
 BY: *M. C. 4806* DATE:
 JOB #: 04-310-0 JOB NAME:
 SUBMISSION #: 05121-01331
 SPEC./DRWS. REF:
 REVIEWED FOR CONSTRUCTABILITY

THIS DRAWING TO BE REVIEWED FOR PIECE MEASUREMENT ONLY
 Date: _____
 RECEIVED
 SEP 13 2006
 Simpson Gumpertz & Heger Inc.

See Dwg. E6 For Notes
NOVEL IRON WORKS
 .250 Ocean Road
 Greenland, NH 03840

Revisions		Project	Maine Medical Center	Notes	Category	Date
1	04-09-06	UPDATED TO SUIT APPROVAL			III	APL-06
		Description	5th Floor Framing Plan		Drawn By	W.J.L.
		Architect	TRD		Checked By	
		Engineer	Simpson Gumpertz & Heger Inc.		Job No.	316
		Customer	William Berry & Son Inc.		Sheet No.	E11