



**5th Floor Framing Plan**  
 Top Of Steel EL 205-113 1/4 ±  
 ◆ Indicates Seismic Moment Connection - 1" Dia A490SC Bolts  
 ● Indicates Non Seismic Moment Connection - 3/8" Dia A325SC Bolts  
 ⊗ Indicates 1" Dia A490N Bolts

APPROVED  NOT APPROVED  
 APPROVED AS CORRECTED  
 REVISE AND RESUBMIT  
 RESUBMIT FOR RECORD COPY  
 Checking is only for conformance with the design concept of the project and compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and corrected at the job site for information that pertains solely to the fabrication processes or to techniques of construction; and for coordination of the work of all trades.  
 BY: *MSP/MLC*  
 DATE: 30 Oct 06  
 SIMPSON GUMPERTZ & HEGER INC  
 41 SEYON ST. BUILDING 1, SUITE 500  
 WALTHAM, MA 02453

WILLIAM A. BERRY & SON, INC.  
 REVIEWED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.  
 THE SUBCONTRACTOR/VENDOR IS RESPONSIBLE FOR ALL DIMENSIONS, CORRECT FIT AND COORDINATION OF ALL ITEMS TO BE FURNISHED & INSTALLED.  
 BY: *MBC* DATE: *2006*  
 JOB #: *04-310-0* JOB NAME: *MMC-COMPLET ST.*  
 SUBMISSION #: *0611-01468*  
 SPEC./DWG. REF: *REVISED FOR CONSTRUCTABILITY*

**THIS DRAWING TO BE REVIEWED FOR PIECE MARKS ONLY**  
 Date: SEP 27 2006  
**RECEIVED**  
 OCT 02 2006  
 Simpson Gumpertz & Heger  
 Consulting Engineers Inc.

See Dwg. E6 For Notes  
**NOVEL IRON WORKS**  
 250 Ocean Road  
 Greenland, NH 03840

Revisions		No.	Date	Description	Drawn By	Checked By
1	31-09-06	UPDATED TO SUIT APPROVAL				

  

Project	Maine Medical Center	Date:	Apr-06
Description	5th Floor Framing Plan	Drawn By	AD
Architect	TRD	Chk By	W.J.L
Engineer	Simpson Gumpertz & Heger Inc.	Job No.	316
Customer	William Berry & Son Inc.	Sht. No.	E11