



K1 REMOVALS PLAN-2823

1/4" = 1'-0"




K3 FLOOR PLAN - 2823

1/4" = 1'-0"




K6 REMOVALS PLAN - 2804

1/4" = 1'-0"



K8 FLOOR PLAN - 2804

1/4" = 1'-0"




G11 PROJECT LOCATION PLAN

N.T.S.


SHADING INDICATES AREAS OF WORK

- GENERAL NOTES:**
- DO NOT SCALE DRAWINGS
 - FIELD VERIFY ALL DIMENSIONS PRIOR TO PROCEEDING WITH WORK. IF DISCREPANCIES ARE FOUND, NOTIFY ARCHITECT IN WRITING FOR CLARIFICATION BEFORE PROCEEDING WITH WORK.
 - ALL DIMENSIONS ARE MEASURED TO FACE OF FINISH.
 - PROVIDE 2 HR RATED FIRESTOPPING SYSTEM (U.L. RATED) AT FLOOR PENETRATIONS. SEAL PENETRATIONS AT EXISTING CORRIDOR WALLS TO LIMIT THE TRANSFER OF SMOKE.
 - DOOR JAMBS SHALL BE LOCATED 6" FROM CORNER UNLESS NOTED OTHERWISE. MAINTAIN 18" CLEAR FROM STRIKE SIDE OF DOOR TO ANY OBSTRUCTION ON PULL SIDE. MAINTAIN 12" CLEAR FROM STRIKE SIDE OF DOOR TO ANY OBSTRUCTION ON PUSH SIDE WHERE DOOR HARDWARE INCLUDES CLOSER.
 - PROVIDE BLOCKING FOR ALL CASEWORK, TOILET ACCESSORIES, WALL-MOUNTED DOOR STOPS, AND WALL-MOUNTED EQUIPMENT.
 - PATCH HOLES AND CRACKS IN EXISTING WALLS TO RECEIVE NEW PAINT.
 - PROVIDE FIRESTOPPING AT ALL MECHANICAL, ELECTRICAL AND PLUMBING PENETRATIONS IN FIRE-RATED PARTITIONS AND FLOOR/CEILING ASSEMBLIES. MATCH WALL/FLOOR FIRE RATING.
 - COORDINATE MECHANICAL, PLUMBING AND ELECTRICAL FLOOR AND WALL PENETRATIONS. UNLESS NOTED OTHERWISE, ELECTRICAL CONDUIT AND WIRING, PLUMBING AND MECHANICAL PIPING SHALL BE CONCEALED AND WALL FRAMING SHALL BE OF ADEQUATE DIMENSION TO ACCOMPLISH THIS WITHOUT CHANGES IN WALL PLANE.
 - CONTRACTOR SHALL PROVIDE INFECTION CONTROL ENCLOSURES PER MMC STANDARDS. AVOID ANY IMPACT TO THE AREAS DESIGNATED FOR OWNER USE AND OCCUPANCY.



A1 REMOVALS PLAN

1/4" = 1'-0"



A6 FLOOR PLAN

1/4" = 1'-0"

FOR REFERENCE

- REMOVALS KEY NOTES:**
- REMOVE EXISTING DOOR, FRAME AND HARDWARE.
 - REMOVE EXISTING PARTITION TO 7'-10" AFF.
 - REMOVE EXISTING PARTITION TO HEIGHT OF EXISTING SOFFIT BETWEEN ROOMS 2812 AND 2812A.
 - REMOVE EXISTING PARTITION TO ABOVE CEILING.
 - REMOVE PORTION OF EXISTING PARTITION FOR NEW CASED DOOR OPENING.
 - REMOVE EXISTING LIGHT FIXTURES AND CEILING MOUNTED DEVICES AND RETAIN FOR REUSE.
 - REMOVE EXISTING SOFFITS.
 - REMOVE EXISTING WALL PANELS FOR PAR EX BINS AND RETAIN FOR REUSE.
 - REMOVE WALL PROTECTION AND RETAIN FOR REUSE.
 - REMOVE EXISTING NURSE CALL DUTY STATION AND RETAIN FOR REUSE.
 - REMOVE EXISTING CARD READER AND RETAIN FOR REUSE.
 - REMOVE PORTION OF EXISTING WALL FOR BORROWED LITE.
 - REMOVE EXISTING MED GAS ALARM PANELS AND RETAIN FOR REUSE.
 - REMOVE EXISTING BASE CABINETS AND PLUMBING FIXTURE.
 - REMOVE EXISTING WALL CABINETS/SHELF UNITS AND RETAIN FOR REUSE.
 - REMOVE EXISTING WORK COUNTER.
 - REMOVE EXISTING FLOORING WHERE INDICATED.

- REMOVALS NOTES:**
- ALL BUILDING STRUCTURAL ELEMENTS SHALL REMAIN.
 - PROTECT ALL EXISTING MATERIALS AND FINISHES. ANY MATERIALS OR FINISHES DISTURBED OR DAMAGED DURING DEMOLITION AND NEW WORK SHALL BE REPAIRED OR REPLACED AND FINISHED TO MATCH ADJACENT CONSTRUCTION CONTINUOUSLY TO NEAREST CORNER.
 - DURING DEMOLITION AND NEW WORK, WHERE EXISTING CONDITIONS ARE FOUND TO BE DEFECTIVE, NOTIFY OWNER AND ARCHITECT AND PROVIDE CHANGE PROPOSAL FOR CORRECTION OF THESE CONDITIONS.
- PARTITION TYPES:**
- ALCOVE WALL: 3 5/8" METAL STUDS SPACED 16" O.C. TO 6" ABOVE CEILING. (1) LAYER 5/8" GYP. BD. BOTH SIDES.
 - ACOUSTIC SEPARATION WALL: 3 5/8" METAL STUDS SPACED 16" O.C. FULL HEIGHT TO STRUCTURE. ACOUSTIC BATT INSULATION FULL HEIGHT. (1) LAYER 5/8" GYP. BD. BOTH SIDES. ACOUSTIC SEALANT AT TOP AND BOTTOM OF WALL.
 - INFILL EXISTING WALL OPENING. MATCH EXISTING WALL THICKNESS AND MATERIALS. PROVIDE 1 HOUR RATED WALL CONSTRUCTION WHERE INDICATED.
 - CONFIRM THAT EXISTING WALL MEETS 1 HOUR RATING REQUIREMENTS (TYP AT EXISTING 1 HOUR WALL)

- PLAN NOTES:**
- A CORNER GUARD
 - B END GUARD
 - C WALL GUARD
 - D RELOCATE CARD READER
 - E RELOCATE NURSE CALL DUTY STATION
 - F RELOCATE MED GAS ALARM PANELS
 - G RELOCATE PAR-EX SCANNER
 - H RELOCATE PAR-EX BIN PANELS

REV.	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	3/12/12

ISSUED FOR CONSTRUCTION
3/12/12

CURRENT ISSUE STATUS:

PROJECT NORTH

LICENSED ARCHITECT
CAROL F. GILLIS
No. 2841
Carol F. Gillis
STATE OF MAINE

DESIGN GROUP COLLABORATIVE
ARCHITECTURE DESIGN + PLANNING
22 FREE STREET
PORTLAND, MAINE 04101
(207) 899-3300

**MAINE MEDICAL CENTER
OB TRIAGE RENOVATIONS**
PORTLAND, MAINE

**FLOOR PLANS AND
REMOVAL PLANS**

SHEET TITLE:	DATE:	3/12/12	GRAPHIC SCALE:	0"
SCALE:	AS NOTED			
PROJECT NO.:	10007	SHEET No.:		
DRAWN BY:	CFG			
A/E OF RECORD:	CFG			

AE 101