PLUMBING FIXTURE SCHEDULE

TAG	DESCRIPTION	FIXTURE	FAUCET/DRAIN	TRIM	SUPPORT	CW	HW	WASTE	VENT	NOTES:
WC-A	WALL MOUNTED WATER CLOSET-ADA	AMERICAN STANDARD #2257.103 "AFWALL" VITREOUS CHINA SIPHON JET TYPE, 1-1/2" TOP SPUD, 1.6 GPF	SLOAN ROYAL #111-ES-S-YO EXPOSED, SENSORED FLUSH VALVE 1.6 GPF	CHURCH #9500-SSC SEAT - WHITE	ZURN #Z-1203 / 1204	1"	-	4"	2"	1,3
WC-B	WALL MOUNTED WATER CLOSET-ADA	AMERICAN STANDARD #2257.103 "AFWALL" VITREOUS CHINA SIPHON JET TYPE, 1-1/2" TOP SPUD, 1.6 GPF	SLOAN ROYAL #WES-111-YO EXPOSED FLUSH VALVE 1.6 GPF	CHURCH #9500-SSC SEAT - WHITE	ZURN #Z-1203 / 1204	1"	-	4"	2"	1
LAV-A	WALL MOUNTED LAVATORY-ADA-SENSORED	AMERICAN STANDARD # 0355.012 "LUCERNE" VITREOUS CHINA , CENTER HOLE FAUCET AND CONCEALED ARM SUPPORT	SLOAN OPTIMA #ETF-80-4-B-BDT ELECTRONIC FAUCET WITH #EL-248-40 TRANSFORMER AND #ETF-460-A STRAINER	MCGUIRE LOOSE KEY ANGLE STOPS, ESCUTCHEONS AND RISERS- CHROME PLATED	ZURN #Z-1231	1/2"	1/2"	1-1/2"	1-1/2"	1,3,4
LAV-B	WALL MOUNTED LAVATORY-ADA	AMERICAN STANDARD # 0355.012 "LUCERNE" VITREOUS CHINA (3) HOLES PUNCHED FOR FAUCET, 4" CENTERS AND CONCEALED ARM SUPPORT	CHICAGO #895-317RGD1CP FAUCET	MCGUIRE LOOSE KEY ANGLE STOPS, ESCUTCHEONS AND RISERS- CHROME PLATED	ZURN #Z-1231	1/2"	1/2"	1-1/2"	1-1/2"	1,3,4
LAV-C	INTERGRAL COUNTER LAVATORY	ONE PIECE VANITY TOP-DOUBLE BOWL, PROVIDED BY COUNTER SUPPLIER. CENTER HOLE FAUCET.	SLOAN OPTIMA #ETF-80-4-B-BDT ELECTRONIC FAUCET WITH #EL-248-40 TRANSFORMER AND #ETF-460-A STRAINER	MCGUIRE LOOSE KEY ANGLE STOPS, ESCUTCHEONS AND RISERS- CHROME PLATED	-	1/2"	1/2"	1-1/2"	1-1/2"	1,4
SK-A	GENERAL USE SINK COUNTER TOP DROP-IN-ADA	JUST #SL-ADA-1815-A-GR 304 SS SELF- RIMMING. 3 HOLES, CENTER DRAIN	CHICAGO #201-AGN8AE3-317XK FAUCET, JUST #J-ADA-35-FS DRAIN AND OFFSET TAIL	MCGUIRE LOOSE KEY ANGLE STOPS, ESCUTCHEONS AND RISERS- CHROME PLATED	-	1/2"	1/2"	1-1/2"	1-1/2"	2
SS-A	WALL MOUNTED CLINICAL SERVICE SINK	AMERICAN STANDARD #9512.013 VITREOUS CHINA FLUSHING RIM, 1-1/2" TOP SPUD	SLOAN ROYAL #117 FLUSH VALVE 6.5 GPF, AMERICAN STANDARD #7880.024 BEDPAN CLEANSER ASSEMBLY WITH HAND HELD SPRAY, DOUBLE PEDAL FOOT VALVE, AND VACUUM BREAKER		WADE #640 WITH #371 WASTE FITTING	1"	1/2"	2"	1-1/2"	1
SH-A	STAFF SHOWER-ADA	AQUARIUS #G3698-BF WHITE GELCOAT FINISH TRANSFER SHOWER - .5" NO RECESS THRESHOLD-INSIDE DIMENSIONS 36" X 36"	SYMMONS TEMPTROL C-96-500-B30-V PRESSURE BALANCING MIXING VALVE WITH HAND SPRAY	SMOOTH SS S-BAR, L-BAR AND WHITE HDPE FOLD-UP FULL DEPTH SEAT	-	1/2"	1/2"	-	-	2
UR-A	WALL MOUNTED URINAL-ADA	AMERICAN STANDARD #6601.012 "LYNBROOK" VITREOUS CHINA URINAL, 1-1/4" TOP SPUD, 1.0 GPF	SLOAN ROYAL #180-1 EXPOSED FLUSH VALVE 1.0 GPF		ZURN #Z-1222	1"	-	2"	1-1/2"	1,3
MR-A	MOP RECEPTOR	FIAT #MSB-2424 MOLDED STONE MOP RECEPTOR, #MSG-2424 WALL GUARDS, #E-77-AA BUMPER GUARDS AND #1453 BB STRAINER	CHICAGO #445-RC897SXKCP SERVICE SINK FAUCET INTEGRAL CHECK VALVES	FIAT #832-AA HOSE BRACKET, #889-CC MOP HANGAR, ALL WALL GUARDS	-	3/4"	3/4"	3"	2"	2

NOTES:
1. PROVIDE PDI SIZED SHOCK ABSORBER WITH ISOLATION VALVE, ACCESSIBLE
2. PROVIDE AIR CHAMBERS ON HW & CW CONNECTIONS
3. REFER TO ARCHITECTURAL DRAWINGS FOR MOUNTING HEIGHT
4. INSULATE EXPOSED PIPING - TRUEBRO #102G.

DRAIN SCHEDULE

TAG	APPLICATION	TYPICAL UNIT MFR & MODEL NO.	DESCRIPTION	NOTES:
FD-A	PATIENT BATHROOM & LOCKER RM	ZURN #ZN-415-6B-P	FLOOR AND SHOWER DRAIN COATED CAST IRON BODY, ADJUSTABLE CHROME PLATED STRAINER	1,2

NOTES:
1. 1/2" TRAP PRIMER CONNECTION. SINGLE DRAIN APPLICATIONS: PRECISION PLUMBING PRODUCTS #PO-500. MULTIPLE DRAIN APPLICATIONS: PRECISION PLUMBING PRODUCTS #PO-500, #SS-8 SUPPLY TUBE & #DU-2,3 OR 4 DISTRIBUTION UNIT. PROVIDE SHUTOFF AND UNION UPSTREAM OF EACH TRAP PRIMER VALVE.
2. NO HUB OUTLET

PLUMBING SPECIALTIES SCHEDULE

TAG	APPLICATION	TYPICAL UNIT MFR & MODEL NO.	DESCRIPTION	NOTES:
EE-A	EMERGENCY EYE/FACE WASH	GUARDIAN #G1724-T	WALL MOUNTED EYE/FACE WASH UBIT, STAY OPEN VALVE	1
EE-B	EMERGENCY EYE/FACE WASH MIXING VALVE	LEONARD #TA-350	FAIL COLD, 10 PSIG MAX. DROP AT 4 GPM FLOWING.	1
DU-A	DOCKING UNIT MIXING VALVE	LEONARD #370	FAIL COLD, 10 PSIG MAX. DROP AT 4 GPM FLOWING.	2
WB-A	WALL BOX - ICEMAKER	IPS-GUYGRAY #BIM875	1/2" CW SUPPLY WITH FOLLET #QC4-FL4S PLUMBED-IN WATER FILTER INSIDE CABINET-ACCESSIBLE. DRAIN TO INDIRECT WASTE.	-
VC-A	VENDING CONNECTION	CONTRACTOR INSTALLED CONNECTION FOR OWNER FURNISHED SODA DISPENSER	1/2" CW SUPPLY WITH FOLLET #QC4-FL4S PLUMBED-IN WATER FILTER INSIDE CABINET-ACCESSIBLE. DRAIN TO INDIRECT WASTE.	

NOTES:
1. PROVIDE SIGNAGE AND TEST EQUIPMENT, (GUARDIAN #AP250-008G & #AP250-005).
2. CONFIRM CONNECTIONS ON OWNER'S EQUIPMENT PRIOR TO INSTALLATION.

MEDICAL GAS VALVE BOX SCHEDULE

VALVE BOX No.	GAS				
	OXYGEN	VACUUM	MEDICAL AIR	NITROUS OXIDE	EVAC
MGVB-1	X	X	X	X	

NOTES:
1. "X" DESIGNATES GASES TO BE VALVES AT BOX
2. VALVE SIZES ARE SAME AS PIPING SIZES. (SEE DRAWINGS)

MEDICAL GAS ALARM PANEL SCHEDULE

VALVE BOX No.	SERVES	GAS				
		OXYGEN	VACUUM	MEDICAL AIR	NITROUS OXIDE	EVAC
MGAP-3	PACU-NORTH	X	X	X		
MGAP-4	PACU-SOUTH	X	X	X		

NOTES:

SHOCK ABSORBER SCHEDULE

TYPE	FIXTURE UNIT RATING	BASIS OF DESIGN	
		MANUF.	FIGURE NO.
'A'	1–10	ZURN	100
'B'	12–32	ZURN	200
'C'	33–60	ZURN	300
'D'	61–113	ZURN	400
'E'	114–154	ZURN	500
'F'	155–330	ZURN	600

REV.	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	9-12-08

ISSUED FOR CONSTRUCTION
9-12-08

CURRENT ISSUE STATUS:

STATE OF MAINE — CATHERINE M. EVERETT — No. 7291 — REGISTERED PROFESSIONAL ENGINEER

SMRT
ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING
144 Fore Street,P.O. Box 618
Portland, Maine 04104
tel. (207) 772-3846
fax. (207) 772-1070
www.smrtinc.com

MAINE MEDICAL CENTER - L.L. BEAN WING 2ND FLOOR SURGICAL SERVICES
PORTLAND, MAINE

SCHEDULES

SHEET TITLE:

SCALE:	NOT TO SCALE	DATE:	9-12-08
PROJECT MANAGER:	CDP	GRAPHIC SCALE:	0" 1"
JOB CAP/DRAWN:	BGG		
A/E OF RECORD:	KME	SHEET No.	
SMRT CAD FILE:	P-601-08098		P-601
PROJECT No.	08098		

© COPYRIGHT 2008 SMRT INC.