City of Portland, Maine – Buildir	ig or Use Permit Application	on 389 Congress S	Street, ()4101, Tel: (207) 87	74-8703, FAX: 874-8716
Location of Construction: 22 Branhall St	Owner: *		Phone:	871-2500	Permit No: 981213
Owner Address:	Lessee/Buyer's Name:	Phone:	Business		PERMIT ISSUED
Contractor Name: Langford & Low	Address: P.O. Box 662 Ptld, ME		797-	-5141	Permit Issued: OCT 2 6 1998
Past Use:	Proposed Use:	COST OF WORK		PERMIT FEE: \$ 70.00	
			TRE DEPT. Approved INSI		CITY OF PORTLAND
Office	Same	□ De Signature: 444	enied	Use Group: Type: Signature:	Zone: CBL: 053-D-007
Proposed Project Description:			TIVITIE	S DISTRICT (P.A.D.)	Zoning Approval:
Remodel office Space Action: Approved with Conditions: Image: Condition in the second					Special Zone or Reviews: Shoreland Wetland Flood Zone
Permit Taken By:	Date Applied For:	Signature:		Date:	□ Subdivision □ Site Plan maj □minor □mm □
 Building permits do not include plumbing, s Building permits are void if work is not started tion may invalidate a building permit and started tion may invalidate a building permit and started sta	Miscellaneous Conditional Use Interpretation Approved Denied Historic Preservation Not in District or Landmark				
	Does Not Require Review				
				ERMIT ISSUED REQUIREMENTS	Action:
I hereby certify that I am the owner of record of the authorized by the owner to make this application if a permit for work described in the application i areas covered by such permit at any reasonable h	Approved Approved with Conditions Denied Date				
SIGNATURE OF APPLICANT	ADDRESS:	20 October 1990 DATE:		PHONE:	-
RESPONSIBLE PERSON IN CHARGE OF WOR	K, TITLE			PHONE:	CEO DISTRICT
White-P	ermit Desk Green-Assessor's Ca	nary-D.P.W. Pink-Publ	lic File	vory Card-Inspector	. et

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

COMMENTS 1 72 Talked with Contractor Deno staty over weekend nut Monday 1000 AM Room 2731 ARea 11-2-98 ANNEX B goto by FI the Right up etuis t Worth Completed. muly Mor **Inspection Record** Туре Date Foundation: Framing: Plumbing: Final:

Other:

BUILDING PERMIT REPORT

D	DATE: 10/22/5/ ADDRESS: 22 Brembell St CBL \$53-D-\$\$					
R	REASON FOR PERMIT:					
B	BUILDING OWNER: mm c					
С	CONTRACTOR: Long Love + Low					
P	ERMIT APPLICANT:					
U	ise groupB BOCA 1996 CONSTRUCTION TYPE/B					
	CONDITION(S) OF APPROVAL					
	his Permit is being issued with the understanding that the following conditions are met:					
А	pproved with the following conditions: $\frac{\sqrt{1}}{\sqrt{18}} \frac{18 \times 19 \times 26 \times 24}{18 \times 19 \times 26}$					
X1	This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.					
₹ <u>1</u> . 2.	Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services					
	must be obtained. (A 24 hour notice is required prior to inspection)					
2.	5 Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the					
	bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The					
	top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used,					
	the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be					
	protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or					
2.	 crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2 Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of 					
۷.	foundations anchors shart be a minimum of 1/2 in diameter, 7 into the foundation wait, minimum of 1/2 inom corners of foundation and a maximum 6 'o.c. between bolts. (Section 2305.17)					
3.						
4.	• •					
	done to verify that the proper setbacks are maintained.					
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be sep						
	adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire					
	resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of $\frac{1}{2}$ inch gypsum board or the equivalent applied to the garage means of $\frac{1}{2}$					
	inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)					
6.						
	National Mechanical Code/1993). Chapter 12 & NFPA 211					
7.	Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's					
	building code.					
8.	Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated					
	walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower					
	level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-					
	1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that					
	would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be					
	less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at					
	least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)					
9.	Headroom in habitable space is a minimum of 7'6". (Section 1204.0)					
10.						
	minimum 11" tread. 7" maximum rise.(Section 1014.0)					
11.						

- 12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as <u>means of egress or rescue</u> they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)
- 13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1
- 14. All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0
- 15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1
- 16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements
 - In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2
- 17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. Section 921.0
- 18.) The Fire Alarm System shall be maintained to NFPA #72 Standard.
- The Sprinkler System shall maintained to NFPA #13 Standard.
- All exit signs. lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 23. Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)
- 4. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade.
- 25. All requirements must be met before a final Certificate of Occupancy is issued.
- 26. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).
- 27. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
- 28. Please read and implement the attached Land Use-Zoning report requirements.
- 29. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.3. of the City's building code.
- 30. Glass and glazing shall meet the requirements of Chapter 24 of the building code.
- 31.
- 32.

33. ig Inspector SES. - C Ayud cc: Lt. McDougall/PFD

Marge Schmuckal, Zoning Administrator

PSH 8-1-98

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application

Attached Single Family Dwellings/Two-Family Dwelling

Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building) :	ZZ BRAMHALL STREET	old Annex B.					
Total Square Footage of Proposed Structure	Square Footage of Lot	2 nd fl					
Tax Assessor's Chart, Block & Lot Number Chart# 053 Block# D Lot#007	Owner: MAINE MEDICAL CENTEN	Telephone#: 8712500					
Owner's Address: 22 BRAMAALL STREET PORTHAND MAINE	Lessee/Buyer's Name (If Applicable)	Cost Of Work: Fee \$ 10,000 & \$ 70 °					
Proposed Project Description: (Please be as specific as possible) REMODEL OFFIEC 3PACE							
Contractor's Name. Address & Telephone Rec'd By							
Current Use: OFFICE SPACE Proposed Use: OFFICE SPACE							

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

•All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.

•All plumbing must be conducted in compliance with the State of Maine Plumbing Code.

•All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.

•HVAC(Heating, Ventililation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code. You must include the following with you application:

1) ACopy of Your Deed or Purchase and Sale Agreement

2) A Copy of your Construction Contract, if available

3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered design professional.

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant:	CARALAN I	lowost	 Date: 10/	19/98

Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter. Additional Site review and related fees are attached on a separate addendum



