

NOTE:




- 1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

KEYED NOTES:

- 1 EXISTING TO REMAIN.
- 2 PROVIDE JUNCTION BOXES ON EACH SIDE OF DOORWAY FOR MOTORIZED DOOR MOTION SENSORS. PROVIDE 3/4" CONDUIT FROM EACH BOX TO CEILING SPACE FOR CONTROL WIRING.
- 3 POWER CONNECTION FOR MOTORIZED DOOR OPERATOR.
- 4 JUNCTION BOX (PROVIDED BY STERIS), ABOVE CEILING AT STERIS BOOM.
- 5 CONNECT NEW RECEPTACLE TO EXISTING NORMAL POWER CIRCUIT IN EQUIPMENT ROOM. (VIDEO MATRIX SWITCHER CONTROL POWER)
- 6 RELOCATED EXISTING PUSH BUTTON FOR MOTOR OPERATED DOOR.
- 7 CONNECT TO EXISTING 120V CIRCUIT.

144 Free Street P.O. Box 618
Portland, Maine 04104
Tel: (207) 772-3946
Fax: (207) 772-1070
www.smrtinc.com

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING



MAINE MEDICAL CENTER
CATH LAB #6
PORTLAND, ME

ISSUED FOR CONSTRUCTION
12-21-10

CURRENT ISSUE STATUS

NO.	DATE	DESCRIPTION
0	12-21-10	ISSUED FOR CONSTRUCTION
1		REV

GRAPHIC SCALE:
0" 1"

SCALE: 1/4" = 1'-0"
PROJECT MANAGER: ND
DRAWN BY: CDS
A/E OF RECORD: WRH
PROJECT NO: 10112-00
DATE: 12-21-10

SHEET TITLE:
CATH LAB#6
POWER PLAN

SHEET No. EP102

1 CATH LAB#6 POWER PLAN
1/4" = 1'-0"