

NO.	ISSUE	DATE
1	Addendum 1	05-22-15

Sheet Information

Date: MAY 1, 2015
Job Number: B140185-000
Drawn: GN
Checked: RAC
Approved: RAC

**ELECTRICAL
FLOOR PLAN
LEVEL 6 - FIRE ALARM**



GENERAL NOTES:
1. REFER TO DRAWING E05-01 FOR LEGEND, SYMBOLS, ABBREVIATIONS, AND ADDITIONAL GENERAL NOTES.

FIRE ALARM KEYED NOTES:
① NEW FIRE ALARM DEVICES SHALL BE MANUFACTURED BY BASE BUILDING FIRE ALARM MANUFACTURER. NEW DEVICES SHALL BE WIRED TO EXISTING FIRE ALARM LOOPS SERVING AREA. ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY POWER SUPPLIES, BOOSTERS, AND REPROGRAMMING OF SYSTEM TO ACCOMMODATE NEW DEVICES. COORDINATE WITH BUILDING FIRE ALARM VENDOR PRIOR TO SUBMITTING BID TO ENSURE SCOPE IS FULLY COVERED.