DRAWING NOTES:

- 1. REFER TO DRAWING E-000, E-500 AND E-501 FOR LEGEND, SYMBOLS, GENERAL NOTES AND SPECIFICATIONS.
- 2. ELECTRICAL CONTRACTOR SHALL COORDINATE NEMA RATINGS OF ALL DEVICES PRIOR TO INSTALLATION.
- 3. ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING AND CONFIRMING LOCATIONS AND MOUNTING HEIGHTS OF ALL LIGHTING FIXTURES, SWITCHES AND ELECTRICAL DEVICES WITH ARCHITECT AND ARCHITECTURAL
- 4. CIRCUIT NUMBERS ARE SHOWN FOR DESCRIPTIVE PURPOSES ONLY. EXACT NUMBERS SHALL BE DETERMINED IN FIELD AND SHALL BE NOTED ON THE CONTRACTOR'S AS-BUILT DRAWINGS.
- 5. REFER TO DRAWING E-400 FOR LIGHTING FIXTURE SCHEDULE AND ARCHITECTUREAL RCP DRAWINGS FOR ADDITIONAL INFORMATION.
- 6. ALL OCCUPANCY SENSOR LOCATIONS ARE APPROXIMATE. REFER TO
- 7. CONTRACTOR IS RESPONSIBLE FOR PROPER OCCUPANCY SENSOR SENSITIVITY AND TIME DELAY SETTINGS AND FIELD VERIFICATION OF CIRCUITS WITH RESPECT TO PROPER PLACEMENT.

MANUFACTURERS INSTALLATION INSTRUCTIONS PRIOR TO INSTALLATION.

- 8. ALL LIGHTING FIXTURES LOCATED IN ENCLOSED OFFICES, STORAGE ROOMS, UTILITY ROOMS, CONFERENCE ROOMS, ETC. SHALL BE CONTROLLED BY LOCAL DIMMER AND/OR SWITCHES VIA CEILING MOUNTED OCCUPANCY SENSORS OR WALL MOUNTED OCCUPANCY SENSORS.
- 9. PROVIDE COMMON FACE PLATE AND REQUIRED METAL INTERIOR BOX BARRIERS FOR ALL MULTIPLE GANG SWITCH LOCATIONS.

KEYED NOTES:

(1) CONNECT TO EXISTING EMERGENCY CIRCUIT SERVING AREA. TYPICAL FOR ALL FIXTURES DESIGNATED AS EMERGENCY AND EXIT SIGNS. ALL SWITCHED EMERGENCY FIXTURES SHALL BE POWERED VIA AN EMERGENCY BYPASS

225 Franklin Street, Suite 1100 Boston, MA 02110 t 617.478.0300 f 617.478.0321 www.perkinswill.com

CONSULTANTS

AKF GROUP LLC 99 Bedford St., 2nd Floor Boston, MA 02111 t 617.737.1111 f 617.737.4311


PROJECT ACCU RELOCATION 22 Bramhall Street Portland, Maine 04102



MAINE MEDICAL CENTER 22 Bramhall Street Portland, Maine 04102

ISSUED FOR CONSTRUCTION 05/02/2016

ISSUE CHART



Job Number

TITLE **ELECTRICAL** FLOOR PLAN -

LIGHTING

SHEET NUMBER

E-200