



PHASE 2 NEW LAYOUT
SCALE 1/4" = 1'-0"

ALL EXISTING UPRIGHTS TO REMAIN. HEADS BELOW DUCT TO BE REMOVED FOR EXISTING HVAC RENOVATION AND REINSTALLED ONCE HVAC RENOVATION IS COMPLETE.
ALL NEW TIE IN ARE AS NOTED ON LAYOUT.

HEAD LEGEND

- 15 RELIABLE MODEL F1FR56 UPRIGHT
- 155 155 DEGREE BRASS WITH HEAD CAGE
STANDARD RESPONSE, STANDARD COVERAGE
K=5.6, 1/2" NPT, SIN RA1425
- EXISTING 5.6K UPRIGHT HEAD
TO REMAIN

DEAN & ALLYN, INC.
FIRE PROTECTION • SPECIAL HAZARD
116 LEWISTON ROAD, GRAY, MAINE 04039
(207)657-5646 FAX:(207)657-5647

		DANA A. STEWART NICET IV - #064544		DRAWING TITLE: MMC AHU PHASE 2		SUBMITTAL	
APPROVED BY:		SURVEYED BY:		JOB:		NO. OF SPRINKLERS SHOWN ON THIS SHEET: 15	
DATE:		SEC:		MAINE MEDICAL CENTER BEAN BUILDING AHU REPLACEMENT PORTLAND, ME 04103		NO. OF SPRINKLERS ON JOB: 56	
CHECKED BY:		AT DEAN & ALLYN, INC		CONTRACT WITH:		CONTRACT NO.	
SUBMIT FOR APPROVAL: 9/22/15		SCALE: 1/4"=1'-0" U/N		HEBERT CONSTRUCTION 9 GOULD ROAD: LEWISTON, ME 04240		C151285	
REVISIONS:		SHEET NO. 2 OF 5					