



... Fire Protection by Computer Design

Dean and Allyn Inc
116 Lewiston Road
Gray ME, 04039
(207)657-5646

Job Name : MMC AHU REPLACEMENT
Building : BEAN BUILDING
Location : 4TH FLOOR AHU
System : ZONE 21
Contract : C151285
Data File : c1285.WXF

Hydraulic Design Information Sheet

Name - MAINE MEDICAL CENTER Date - 9/17/15
 Location - 4TH FLOOR AHU
 Building - BEAN BUILDING System No. - ZONE 21
 Contractor - DEAN AND ALLYN INC Contract No. - C151285
 Calculated By - S. COTE Drawing No. - 4
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 20'
 Occupancy - ORDINARY II

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 2500 System Type Sprinkler/Nozzle
 Density - .15 (X) Wet Make RELIABLE
 D Area Per Sprinkler - VAIRES () Dry Model F1FR56
 E Elevation at Highest Outlet - 13'4 () Deluge Size 1/2"
 S Hose Allowance - Inside - () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance - () Other Temp.Rat.155
 G Hose Allowance - Outside -

N Note

Calculation Flow Required - Press Required -
 Summary C-Factor Used: 140 Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 210 @ Press -
 R Residual Press - 180 Elev. - Well
 Flow - 1467 Proof Flow
 S Elevation -

U Location - BEAN FIRE PUMP

P Source of Information - DEAN AND ALLYN PUMP TEST

Y
 C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf

O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Pressure / Flow Summary - STANDARD

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 2
Date 9/17/15

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
10	195.543	5.6	19.62	na	24.8	0.15	117	7.0
11	195.543	5.6	20.19	na	25.17	0.15	117	7.0
12	195.543	5.6	20.62	na	25.43	0.15	136	7.0
13	195.543	5.6	18.37	na	24.0	0.15	160	7.0
14	195.543	5.6	18.31	na	23.96	0.15	119	7.0
15	195.543	5.6	19.33	na	24.62	0.15	83	7.0
16	195.543	5.6	22.15	na	26.35	0.15	93	7.0
17	195.543	5.6	22.73	na	26.7	0.15	66	7.0
18	195.543	5.6	22.34	na	26.47	0.15	69	7.0
19	195.543	5.6	16.24	na	22.57	0.15	72	7.0
20	195.543	5.6	16.79	na	22.94	0.15	43	7.0
20A	202.043	5.6	17.52	na	23.44	0.15	124	7.0
21	195.543	5.6	19.34	na	24.63	0.15	49	7.0
22	195.21	5.6	25.44	na	28.24	0.15	61	7.0
23	195.543	5.6	22.64	na	26.65	0.15	32	7.0
24	195.21	5.6	26.97	na	29.08	0.15	85	7.0
25	195.543	5.6	23.83	na	27.34	0.15	32	7.0
26	195.543	5.6	27.17	na	29.19	0.15	74	7.0
27	195.543	5.6	28.01	na	29.64	0.15	52	7.0
28	195.543	5.6	29.57	na	30.45	0.15	14	7.0
29	195.543	5.6	24.12	na	27.5	0.15	67	7.0
30	195.543	5.6	23.97	na	27.42	0.15	88	7.0
31	195.543	5.6	24.31	na	27.61	0.15	56	7.0
32	195.543	5.6	25.99	na	28.55	0.15	57	7.0
33	195.543	5.6	32.08	na	31.72	0.15	29	7.0
34	195.543	5.6	29.82	na	30.58	0.15	42	7.0
35	202.043	5.6	26.83	na	29.01	0.15	121	7.0
36	202.043	5.6	28.97	na	30.14	0.15	121	7.0
37	195.543	5.6	32.22	na	31.79	0.15	111	7.0
100	202.043		20.76	na				
101	202.043		21.19	na				
101A	202.043		22.34	na				
102	202.043		22.5	na				
103	202.043		20.07	na				
104	202.043		20.55	na				
105	202.043		21.83	na				
105A	202.043		22.25	na				
151A	202.043		24.88	na				
106	201.626		23.38	na				
107	202.043		24.12	na				
107A	202.043		24.2	na				
153A	202.043		24.53	na				
108	202.043		17.15	na				
109	202.043		18.07	na				
109A	202.043		20.62	na				
110	202.043		21.01	na				
111	202.043		23.82	na				
112	201.626		24.08	na				
114	202.043		25.43	na				
115	201.626		25.7	na				
116	202.043		27.53	na				
117	201.626		28.96	na				
118	202.043		32.03	na				
118A	202.043		32.14	na				
159A	202.043		32.56	na				
119	202.043		23.37	na				
120	202.043		24.62	na				
121	202.043		26.69	na				
122	201.626		28.64	na				
123	202.043		35.99	na				
123A	202.043		36.1	na				
126A	202.043		36.56	na				

Flow Summary - Standard

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 3
Date 9/17/15

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
35A	202.043		27.21	na				
36A	202.043		29.38	na				
124	202.043		34.54	na				
125	202.043		34.96	na				
126	202.043		35.12	na				
150	201.626		25.35	na				
151	201.626		25.61	na				
152	201.626		25.69	na				
153	201.626		26.09	na				
154	201.626		27.12	na				
155	201.626		27.49	na				
156	201.626		28.89	na				
157	201.626		29.67	na				
158	201.626		31.21	na				
159	201.626		32.85	na				
160	201.626		34.52	na				
161	201.626		37.62	na				
162	201.626		115.59	na				
163	107.794		158.22	na				
TR	107.794		164.68	na				
TEST	97.794		171.3	na	250.0			

The maximum velocity is 34.11 and it occurs in the pipe between nodes 161 and 162

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 4
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
10 to 100	24.80 24.8	1.049 120.0 0.1938	2E T	4.0 5.0 0.0	11.416 9.000 20.416	19.619 -2.815 3.956			K Factor = 5.60 Vel = 9.21	
	0.0 24.80						20.760		K Factor = 5.44	
11 to 101	25.16 25.16	1.049 120.0 0.1991	2E T	4.0 5.0 0.0	10.166 9.000 19.166	20.194 -2.815 3.815			K Factor = 5.60 Vel = 9.34	
	0.0 25.16						21.194		K Factor = 5.47	
12 to 102	25.43 25.43	1.049 120.0 0.2029	2E T	4.0 5.0 0.0	14.166 9.000 23.166	20.618 -2.815 4.700			K Factor = 5.60 Vel = 9.44	
	0.0 25.43						22.503		K Factor = 5.36	
13 to 103	24.00 24.0	1.049 120.0 0.1823	2E T	4.0 5.0 0.0	15.791 9.000 24.791	18.367 -2.815 4.520			K Factor = 5.60 Vel = 8.91	
	0.0 24.00						20.072		K Factor = 5.36	
14 to 104	23.96 23.96	1.049 120.0 0.1818	3E T	6.0 5.0 0.0	16.791 11.000 27.791	18.314 -2.815 5.053			K Factor = 5.60 Vel = 8.89	
	0.0 23.96						20.552		K Factor = 5.29	
15 to 105	24.62 24.62	1.049 120.0 0.1911	3E T	6.0 5.0 0.0	16.833 11.000 27.833	19.328 -2.815 5.319			K Factor = 5.60 Vel = 9.14	
	0.0 24.62						21.832		K Factor = 5.27	
16 to 106	26.35 26.35	1.049 120.0 0.2168	2E T	4.0 5.0 0.0	8.833 9.000 17.833	22.145 -2.635 3.866			K Factor = 5.60 Vel = 9.78	
	0.0 26.35						23.376		K Factor = 5.45	
17 to 106	26.70 26.7	1.049 120.0 0.2220	E T	2.0 5.0 0.0	7.791 7.000 14.791	22.727 -2.635 3.284			K Factor = 5.60 Vel = 9.91	
	0.0 26.70						23.376		K Factor = 5.52	
18 to 107	26.47 26.47	1.049 120.0 0.2186	3E T	6.0 5.0 0.0	10.000 11.000 21.000	22.344 -2.815 4.590			K Factor = 5.60 Vel = 9.83	
	0.0 26.47						24.119		K Factor = 5.39	
19 to 108	22.57 22.57	1.049 120.0 0.1628	3E T	6.0 5.0 0.0	11.875 11.000 22.875	16.245 -2.815 3.723			K Factor = 5.60 Vel = 8.38	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 5
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 22.57						17.153		K Factor = 5.45	
20 to 109	22.94 22.94	1.049 120.0 0.1678	3E T	6.0 5.0 0.0	13.416 11.000 24.416	16.788 -2.815 4.096			K Factor = 5.60	Vel = 8.52
	0.0 22.94						18.069		K Factor = 5.40	
20A to 109	46.01 46.01	1.38 120.0 0.1599		0.0 0.0 0.0	3.458 0.0 3.458	17.516 0.0 0.553			K Factor = 5.60	Vel = 9.87
	0.0 46.01						18.069		K Factor = 10.82	
21 to 110	24.63 24.63	1.049 120.0 0.1913	3E T	6.0 5.0 0.0	12.416 11.000 23.416	19.345 -2.815 4.479			K Factor = 5.60	Vel = 9.14
	0.0 24.63						21.009		K Factor = 5.37	
22 to 111	28.24 28.24	1.049 120.0 0.2462	E	2.0 0.0 0.0	3.458 2.000 5.458	25.437 -2.959 1.344			K Factor = 5.60	Vel = 10.48
	0.0 28.24						23.822		K Factor = 5.79	
23 to 112	26.65 26.65	1.049 120.0 0.2213	2E T	4.0 5.0 0.0	9.416 9.000 18.416	22.644 -2.635 4.076			K Factor = 5.60	Vel = 9.89
	0.0 26.65						24.085		K Factor = 5.43	
24 to 114	29.08 29.08	1.049 120.0 0.2600	E	2.0 0.0 0.0	3.458 2.000 5.458	26.970 -2.959 1.419			K Factor = 5.60	Vel = 10.80
	0.0 29.08						25.430		K Factor = 5.77	
25 to 115	27.34 27.34	1.049 120.0 0.2320	2E T	4.0 5.0 0.0	10.416 9.000 19.416	23.828 -2.635 4.505			K Factor = 5.60	Vel = 10.15
	0.0 27.34						25.698		K Factor = 5.39	
26 to 116	29.19 29.19	1.049 120.0 0.2619	2E	4.0 0.0 0.0	8.125 4.000 12.125	27.171 -2.815 3.176			K Factor = 5.60	Vel = 10.84
	0.0 29.19						27.532		K Factor = 5.56	
27 to 117	29.64 29.64	1.049 120.0 0.2694	E T	2.0 5.0 0.0	6.291 7.000 13.291	28.011 -2.635 3.581			K Factor = 5.60	Vel = 11.00
	0.0 29.64						28.957		K Factor = 5.51	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 6
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
28	30.45	1.049	2E	4.0	9.625	29.567			K Factor = 5.60	
to		120.0	T	5.0	9.000	-2.815				
118	30.45	0.2832		0.0	18.625	5.274			Vel = 11.30	
	0.0									
	30.45					32.026			K Factor = 5.38	
29	27.50	1.049	2E	4.0	4.791	24.121			K Factor = 5.60	
to		120.0		0.0	4.000	-2.815				
119	27.5	0.2346		0.0	8.791	2.062			Vel = 10.21	
	0.0									
	27.50					23.368			K Factor = 5.69	
30	27.42	1.049	E	2.0	7.833	23.974			K Factor = 5.60	
to		120.0	T	5.0	7.000	-2.815				
120	27.42	0.2333		0.0	14.833	3.461			Vel = 10.18	
	0.0									
	27.42					24.620			K Factor = 5.53	
31	27.61	1.049	3E	6.0	11.000	24.309			K Factor = 5.60	
to		120.0	T	5.0	11.000	-2.815				
121	27.61	0.2363		0.0	22.000	5.199			Vel = 10.25	
	0.0									
	27.61					26.693			K Factor = 5.34	
32	28.55	1.049	3E	6.0	10.000	25.995			K Factor = 5.60	
to		120.0	T	5.0	11.000	-2.635				
122	28.55	0.2514		0.0	21.000	5.280			Vel = 10.60	
	0.0									
	28.55					28.640			K Factor = 5.33	
33	31.72	1.049	3E	6.0	11.000	32.083			K Factor = 5.60	
to		120.0	T	5.0	11.000	-2.815				
123	31.72	0.3055		0.0	22.000	6.720			Vel = 11.78	
	0.0									
	31.72					35.988			K Factor = 5.29	
34	30.58	1.049	4E	8.0	15.416	29.824			K Factor = 5.60	
to		120.0	T	5.0	13.000	-2.815				
126	30.58	0.2855		0.0	28.416	8.113			Vel = 11.35	
	0.0									
	30.58					35.122			K Factor = 5.16	
35	29.01	1.61	T	8.0	4.000	26.827			K Factor = 5.60	
to		120.0		0.0	8.000	0.0				
35A	29.01	0.0322		0.0	12.000	0.386			Vel = 4.57	
	0.0									
	29.01					27.213			K Factor = 5.56	
36	30.14	1.61	T	8.0	4.000	28.966			K Factor = 5.60	
to		120.0		0.0	8.000	0.0				
36A	30.14	0.0345		0.0	12.000	0.414			Vel = 4.75	
	0.0									
	30.14					29.380			K Factor = 5.56	
37	31.78	1.049	2E	4.0	7.750	32.216			K Factor = 5.60	
to		120.0	T	5.0	9.000	-2.815				
124	31.78	0.3066		0.0	16.750	5.135			Vel = 11.80	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 7
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 31.78									
						34.536			K Factor =	5.41
100 to 101	24.80 24.8	1.38 120.0 0.0511		0.0 0.0 0.0	8.500 0.0 8.500	20.760 0.0 0.434			Vel =	5.32
101 to 101A	25.17 49.97	1.38 120.0 0.1862		0.0 0.0 0.0	6.166 0.0 6.166	21.194 0.0 1.148			Vel =	10.72
101A to 102	0.0 49.97	1.61 120.0 0.0878		0.0 0.0 0.0	1.833 0.0 1.833	22.342 0.0 0.161			Vel =	7.87
102 to 150	25.43 75.4	1.61 120.0 0.1881	E T	4.0 8.0 0.0	2.166 12.000 14.166	22.503 0.181 2.665			Vel =	11.88
	0.0 75.40									
						25.349			K Factor =	14.98
103 to 104	24.00 24.0	1.38 120.0 0.0480		0.0 0.0 0.0	10.000 0.0 10.000	20.072 0.0 0.480			Vel =	5.15
104 to 105	23.96 47.96	1.38 120.0 0.1726		0.0 0.0 0.0	7.416 0.0 7.416	20.552 0.0 1.280			Vel =	10.29
105 to 105A	24.62 72.58	1.38 120.0 0.3716		0.0 0.0 0.0	1.125 0.0 1.125	21.832 0.0 0.418			Vel =	15.57
105A to 151A	0.0 72.58	1.61 120.0 0.1754	T	8.0 0.0 0.0	7.000 8.000 15.000	22.250 0.0 2.631			Vel =	11.44
151A to 151	0.0 72.58	2.067 120.0 0.0519	T	10.0 0.0 0.0	0.500 10.000 10.500	24.881 0.181 0.545			Vel =	6.94
	0.0 72.58									
						25.607			K Factor =	14.34
106 to 152	53.05 53.05	1.38 120.0 0.2081	T	6.0 0.0 0.0	5.125 6.000 11.125	23.376 0.0 2.315			Vel =	11.38
	0.0 53.05									
						25.691			K Factor =	10.47
107 to 107A	26.47 26.47	1.38 120.0 0.0576		0.0 0.0 0.0	1.458 0.0 1.458	24.119 0.0 0.084			Vel =	5.68
107A to 153A	0.0 26.47	1.61 120.0 0.0271	T	8.0 0.0 0.0	4.000 8.000 12.000	24.203 0.0 0.325			Vel =	4.17
153A to 153	93.58 120.05	2.067 120.0 0.1318	T	10.0 0.0 0.0	0.500 10.000 10.500	24.528 0.181 1.384			Vel =	11.48

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 8
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftgng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 120.05				26.093			K Factor = 23.50	
108 to 20A	22.57	1.38 120.0 0.0427	0.0 0.0 0.0	8.500 0.0 8.500	17.153 0.0 0.363			Vel = 4.84	
	0.0 22.57				17.516			K Factor = 5.39	
109 to 109A	68.95	1.38 120.0 0.3379	0.0 0.0 0.0	7.541 0.0 7.541	18.069 0.0 2.548			Vel = 14.79	
109A to 110	0.0	1.61 120.0 0.1595	0.0 0.0 0.0	2.458 0.0 2.458	20.617 0.0 0.392			Vel = 10.87	
110 to 153A	24.63	1.61 120.0 0.2806	T 8.0 0.0 0.0	4.541 8.000 12.541	21.009 0.0 3.519			Vel = 14.75	
	0.0 93.58				24.528			K Factor = 18.90	
111 to 112	28.24	1.049 120.0 0.2462	0.0 0.0 0.0	0.333 0.0 0.333	23.822 0.181 0.082			Vel = 10.48	
112 to 154	26.65	1.38 120.0 0.2215	T 6.0 0.0 0.0	7.708 6.000 13.708	24.085 0.0 3.037			Vel = 11.77	
	0.0 54.89				27.122			K Factor = 10.54	
114 to 115	29.08	1.049 120.0 0.2613	0.0 0.0 0.0	0.333 0.0 0.333	25.430 0.181 0.087			Vel = 10.80	
115 to 156	27.34	1.38 120.0 0.2331	T 6.0 0.0 0.0	7.708 6.000 13.708	25.698 0.0 3.195			Vel = 12.10	
	0.0 56.42				28.893			K Factor = 10.50	
116 to 117	29.19	1.049 120.0 0.2619	0.0 0.0 0.0	4.750 0.0 4.750	27.532 0.181 1.244			Vel = 10.84	
117 to 158	29.64	1.38 120.0 0.2518	T 6.0 0.0 0.0	2.958 6.000 8.958	28.957 0.0 2.256			Vel = 12.62	
	0.0 58.83				31.213			K Factor = 10.53	
118 to 118A	30.45	1.38 120.0 0.0747	0.0 0.0 0.0	1.500 0.0 1.500	32.026 0.0 0.112			Vel = 6.53	
118A to 159A	0.0	1.61 120.0 0.0352	T 8.0 0.0 0.0	4.000 8.000 12.000	32.138 0.0 0.422			Vel = 4.80	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 9
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
159A to 159	0.0 30.45	2.067 120.0 0.0104	T	10.0 0.0 0.0	0.500 10.000 10.500	32.560 0.181 0.109				Vel = 2.91
	0.0 30.45						32.850			K Factor = 5.31
119 to 120	27.50 27.5	1.049 120.0 0.2348	T	5.0 0.0 0.0	0.333 5.000 5.333	23.368 0.0 1.252				Vel = 10.21
120 to 121	27.42 54.92	1.049 120.0 0.8434		0.0 0.0 0.0	2.458 0.0 2.458	24.620 0.0 2.073				Vel = 20.39
121 to 122	27.61 82.53	1.38 120.0 0.4709		0.0 0.0 0.0	3.750 0.0 3.750	26.693 0.181 1.766				Vel = 17.70
122 to 160	28.55 111.08	1.38 120.0 0.8165	T	6.0 0.0 0.0	1.208 6.000 7.208	28.640 0.0 5.885				Vel = 23.83
	0.0 111.08						34.525			K Factor = 18.90
123 to 123A	31.72 31.72	1.38 120.0 0.0805		0.0 0.0 0.0	1.416 0.0 1.416	35.988 0.0 0.114				Vel = 6.80
123A to 126A	0.0 31.72	1.61 120.0 0.0378	T	8.0 0.0 0.0	4.000 8.000 12.000	36.102 0.0 0.454				Vel = 5.00
126A to 161	62.37 94.09	2.067 120.0 0.0839	T	10.0 0.0 0.0	0.500 10.000 10.500	36.556 0.181 0.881				Vel = 9.00
	0.0 94.09						37.618			K Factor = 15.34
35A to 155	29.01 29.01	2.067 120.0 0.0095	T	10.0 0.0 0.0	0.500 10.000 10.500	27.213 0.181 0.100				Vel = 2.77
	0.0 29.01						27.494			K Factor = 5.53
36A to 157	30.14 30.14	2.067 120.0 0.0102	T	10.0 0.0 0.0	0.500 10.000 10.500	29.380 0.181 0.107				Vel = 2.88
	0.0 30.14						29.668			K Factor = 5.53
124 to 125	31.78 31.78	1.38 120.0 0.0808		0.0 0.0 0.0	5.250 0.0 5.250	34.536 0.0 0.424				Vel = 6.82
125 to 126	0.0 31.78	1.61 120.0 0.0381		0.0 0.0 0.0	4.250 0.0 4.250	34.960 0.0 0.162				Vel = 5.01
126 to 126A	30.59 62.37	1.61 120.0 0.1324	T	8.0 0.0 0.0	2.833 8.000 10.833	35.122 0.0 1.434				Vel = 9.83

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 10
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftgng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 62.37									
						36.556			K Factor = 10.32	
150 to 151	75.40 75.4	2.469 120.0 0.0235		0.0	11.000 0.0	25.349 0.0				Vel = 5.05
151 to 152	72.58 147.98	3.068 120.0 0.0284		0.0	2.958 0.0	25.607 0.0				Vel = 6.42
152 to 153	53.05 201.03	3.068 120.0 0.0500		0.0	8.041 0.0	25.691 0.0				Vel = 8.72
153 to 154	120.05 321.08	3.068 120.0 0.1187		0.0	8.666 0.0	26.093 0.0				Vel = 13.93
154 to 155	54.90 375.98	3.068 120.0 0.1595		0.0	2.333 0.0	27.122 0.0				Vel = 16.32
155 to 156	29.00 404.98	3.068 120.0 0.1825		0.0	7.666 0.0	27.494 0.0				Vel = 17.58
156 to 157	56.42 461.4	3.068 120.0 0.2325		0.0	3.333 0.0	28.893 0.0				Vel = 20.02
157 to 158	30.14 491.54	3.068 120.0 0.2612		0.0	5.916 0.0	29.668 0.0				Vel = 21.33
158 to 159	58.83 550.37	3.068 120.0 0.3221		0.0	5.083 0.0	31.213 0.0				Vel = 23.89
159 to 160	30.45 580.82	3.068 120.0 0.3558		0.0	4.708 0.0	32.850 0.0				Vel = 25.21
160 to 161	111.08 691.9	3.068 120.0 0.4917		0.0	6.291 0.0	34.525 0.0				Vel = 30.03
161 to 162	94.09 785.99	3.068 120.0 0.6226	Fsp B 5E F	0.0 10.0 35.0 3.0	72.416 48.000 120.416	37.618 3.000 74.968			** Fixed Loss = 3 Vel = 34.11	
162 to 163	0.0 785.99	6.065 120.0 0.0225	E	14.0 0.0	74.416 14.000 88.416	115.586 40.639				Vel = 8.73
163 to TR	0.0 785.99	6.065 120.0 0.0225	8E	112.0 0.0	175.000 112.000 287.000	158.217 0.0				Vel = 8.73
TR to TEST	0.0 785.99	6.065 120.0 0.0225	Bvca S Fsp	14.0 32.0 0.0	10.000 47.000 57.000	164.683 5.331 1.285			** Fixed Loss = 1 Vel = 8.73	

Final Calculations - Hazen-Williams

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 11
Date 9/17/15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
			Y 1.0						
	250.00 1035.99				171.299			Qa = 250.00 K Factor = 79.15	

Water Supply Curve C

Dean and Allyn Inc
MMC AHU REPLACEMENT

Page 12
Date 9/17/15

City Water Supply:
C1 - Static Pressure : 210
C2 - Residual Pressure: 180
C2 - Residual Flow : 1467

Demand:
D1 - Elevation : 42.335
D2 - System Flow : 785.99
D2 - System Pressure : 171.299
Hose (Demand) : 250
D3 - System Demand : 1035.99
Safety Margin : 22.939

