



CTICU  
SCALE 1/4" = 1'-0"

**HEAD LEGEND**

- 41 RELIABLE MODEL F1R56 WHITE PENDENT
- 155 SEMI RECESSED WHITE ESCUTCHEON MODEL F2
- STANDARD RESPONSE, STANDARD COVERAGE
- K=5.6, 1/2" NPT, SIN RA1314

**DEAN & ALLYN, INC.**  
 FIRE PROTECTION • SPECIAL HAZARD  
 116 LEWISTON ROAD, GRAY, MAINE 04039  
 (207)657-5646 FAX:(207)657-5647

		DANA A. STEWART NICET IV - #064544		DRAWING TITLE: SPRINKLER SYSTEM LAYOUT		REV. 0	
APPROVED BY: _____ DATE: //		SURVEYED BY: SEC _____ DATE: 4/26/16		JOB: MMC SCU2 & CTICU MMC GROUND FLOOR PORTLAND, ME 04103		NO. OF SPRINKLERS SHOWN ON THIS SHEET: 168	
CHECKED BY: DN _____ DATE: 4/26/16		AT DEAN & ALLYN, INC.		CONTRACT WITH: LANFORD & LOW CONSTRUCTION		NO. OF SPRINKLERS ON JOB: 168	
(C) SUBMIT FOR APPROVAL 4/26/16		SCALE 1/4"=1'-0" U/N		SHEET NO. 2 OF 2		CONTRACT NO. C151279	
REVISIONS: _____ DATE: //		DATE: 4/26/16		DATE: 4/26/16		DATE: 4/26/16	