Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/12/16

CTICU
SCALE 1/4" = 1'-0"

HEAD LEGEND

41 / 155° — RELIABLE MODEL F1FR56 WHITE PENDENT
SEMI RECESSED WHITE ESCUTCHEON MODEL F2
STANDARD RESPONSE, STANDARD COVERAGE
K=5.6, 1/2" NPT, SIN RA1314

DEAN & ALLYN, INC.
FIRE PROTECTION • SPECIAL HAZARD
116 LEWISTON ROAD, GRAY, MAINE 04039
(207)657-5646 FAX:(207)657-5647

SCALE 3/32"=1'-0" | SCALE 1/8"=1'-0" | SCALE 3/16"=1'-0" | SCALE 1/4"=1'-0"

DANA A. STEWART
NICET IV – #064544

					APPROVED BY	DATE	SURVEYED BY	SEC
						/ /	DRAWN BY	SEC 4/26/16
						/ /	CHECKED BY	DN 4/26/16
						/ /	AT DEAN & ALLYN, INC	
		0	SUBMIT FOR APPROVAL	4/26/16		/ /	SCALE 1/4"=1'-0" U/N	
			REVISIONS	DATE		/ /	SHEET NO. 2 OF 2	

DRAWING TITLE: SPRINKLER SYSTEM LAYOUT

REV. 0

JOB:
MMC SCU2 & CTICU
MMC GROUND FLOOR
PORTLAND, ME 04103

NO. OF SPRINKLERS SHOWN ON THIS SHEET: 168

NO. OF SPRINKLERS ON JOB: 168

CONTRACT WITH: LANFORD & LOW CONSTRUCTION

CONTRACT NO. C151279