

Sprinkler Systems Inc.

2-4 Avon Street
PO Box 1285
Lewiston, Me. 04240



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

December 15, 2014

Date: 01/05/15

State Fire Marshal
52 State House Station
Augusta, Me 04333-0052

Dear Gerald:

This letter is to inform you that Sprinkler Systems Inc. will be performing renovations on an existing light hazard hydraulically balanced wet sprinkler system at Maine Medical Center Retail Pharmacy located at 22 Bramhall Street Portland, Maine. The area being renovated consist of offices and pharmacy over 2340+- square feet of floor area. Work is to involve about 30 sprinkler head relocations from new 1" openings.

Sprinkler Systems Inc. will be installing pendent sprinkler heads into new suspended ceilings. All work will be done in accordance with all applicable codes and the requirements of the State Fire Marshals' office.

Please call with questions.

Sincerely,

Clayton Saucier
Design Manager