

## **ENGINEERS' SUBMITTAL REVIEW STAMP & COMMENTS**

Project No: B	140263-000	AKF Log No. H-14
	AKF Gro	up, LLC Submittal Stamp
	X No Exceptions Taken Make Corrections Note Revise and Resubmit Rejected Returned Without Activ Checking is only for general project and general complian documents. Any action show plans and specifications. Co shall be confirmed and corre techniques of construction; o trades; and the satisfactory p	ed - No Resubmission Required on conformance with the design concept of the ce with the information given in the contractor which is subject to the given requirements of the ontractor is responsible for: Dimensions which lated at the job site; fabrication processes and coordination of his work with that of all other erformance of his work.
		Date: 6/19/15
		By: DAC

**General Comments**: Review of submitted shop drawings is limited to system material and function compliance to issued plans, specifications, addendums and bulletins. Specific quantities of necessary material items to provide a complete and functioning system are not being confirmed as part of this review. Ultimate responsibility for quantities of necessary materials to provide a complete and functioning system shall be by the submitting contractor and equipment vendor.

#### **Review Comments:**



# Submittal #114.0 23 05 48 - Mechanical Vibration Isolation and Seismic Controls

# P/D: Mechanical Seismic Controls

APPROVERS:	Brandon Romano <b>(Maine Medical Center)</b> David Roberts <b>(AKF)</b>	CREATED BY:	Nick Munro(Consigli Construction Co., Inc.)
RESPONSIBLE CONTRACTOR:	Johnson & Jordan, Inc Dana Foote <b>(Johnson &amp; Jordan, Inc)</b>	STATUS:	Open
TYPE:		SPEC SECTION:	23 05 48 - Mechanical Vibration Isolation and Seismic Controls
COPIES TO:			
DESCRIPTION:			
ATTACHMENTS: # 12 - Bean A.H.U.	Replacement Project - Mechanical Seismic Controls	(4-30-2015).pdf	

#### ARCHITECT'S STAMP

#### CONTRACTOR'S STAMP

Consigli Construction Co., Inc.					
Approved for A/E Review Approved as Noted for A/E Rev	iew Revise & Resubmit Rejected				
Spec. Section: 23 05 48	Submittal No.: 114				
Date: 6/4/2015	By: Nick Munro				
If so marked, approval is given for design only. It does not relieve the subcontractor from complying with the requirements of the contract, contract drawings and specifications. The subcontractor shall be responsible for all dimensions, quantities, schedules and field conditions.					

#### SUBMITTAL WORKFLOW

#	NAME	SUBMITTER/ APPROVER	SENT DATE	DUE DATE	RETURNED DATE	RESPONSE	ATTACHMENTS	COMMENTS
1	Nick Munro	Submitter		6/4/2015	6/4/2015	Submitted		
2	David Roberts	Approver	6/4/2015	6/18/2015		Pending		
3	Brandon Romano	Approver		6/18/2015		Pending		

BY

# Johnson and Jordan Mechanical

# SUBMITTAL - # 12

PROJECT:	MMC – Bean Air Handler Replacement Project 22 Bramhall Street Portland, Maine 04102 JOB # 15035
Construction Managers:	Maine Medical Center Facilities Development P.M. – Brandon Romano 22 Bramhall Street Portland, Maine 04102
SUBMITTED BY:	JOHNSON & JORDAN, INC 18 MUSSEY RD. SCARBOROUGH, ME (207) 775–1169
SUBCONTRACTOR:	JOHNSON & JORDAN, INC 18 MUSSEY RD. SCARBOROUGH, ME (207) 775–1169
SUPPLIER:	Mechanical Control Systems 26-B Keeywadin Drive Salem, NH 03079 978-640-9994
SPECIFICATION SECTION:	<u>230548</u>
PARAGRAPH:	N/A
ITEM:	Mechanical Seismic Controls



APPROVED	APPROVED AS NOTED
REVIEWED	_RE-SUBMIT
SUBJECT TO ARC	CHITECTS APPROVAL
DATE 4/30/15	By: Jamie Evans

1 of 20		REV.	DESCRIPTION Initial Release	SOURCE of CHANGE	DATE 4/28/2015
<u>S</u>	EISMIC CA	<u>ALCU</u>	<u>LATION</u>	<u>S</u>	
	AHU Re	place	ement		
		MECHAN	VICAL CONTROL S	YSTEMS	
JOSEPH D. GEORGIS No. 6125	JOB: MMC	26 Bean - A	-B Keeywaydin Driv Salem, NH 03079 HU Replacem	ve nent	

CUSTOMER: Johnson and Jordan

JOB NUMBER: J5110



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		2 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

	TABLE I - SCHEDULE							
	MMC Bean - AHU Replacement							
TAG	QTY.	MFG.	MODEL	WT. (lbs.)	COMMENT			
AHU-065	1	Trane	Custom	22,500				
AHU-066	1	Trane	Custom	17,400				
AHU-067	1	Trane	Custom	30,400				
AHU-069	1	Trane	Custom	17,000				
See TABLE	II for Se	ismic Restraint	S					

TABLE II - SEISMIC SUMMARY						
		ММС веа	n - AHU Keplacer	nent		
		ANCHOR BOLTS	S per TAG			
	CI	ONCRETE	STEEL	RESTRAINT	MINIMUM EDGE	
TAG	Dia. (in.)	Embedment (in.)	Dia. (in.)		DISTANCE	
AHU-065	1/2" (28)	4"	1/2" (28)	N/A	5"	
AHU-066	1/2" (24)	4"	1/2" (24)	N/A	5"	
AHU-067	1/2" (28)	4"	1/2" (28)	N/A	5"	
AHU-069	1/2" (24)	4"	1/2" (24)	N/A	5"	



Table of Contents:	
I. Summary of Critical Assumptions and Directive Statements	4
II. Purpose	5
III. Scope	5
IV. Strategy & Assumptions	5
V. Exemptions	5
VI. Allowable Loads	6
VII. Seismic Forces	6
VIII. ANALYSES	
AHU	8



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		4 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

## I. Summary of Critical Assumptions and Directive Statements:

1. This analysis does <u>not</u> certify that the equipment is capable of handling the applied seismic loads. Any non-Mechanical Control Systems mounting supports, brackets or other means of attachment must be independently certified. Mechanical Control Systems assumes no responsibility for support structure - for its ability to withstand static or seismic loads, nor for its ability to distribute loads onto restraints.

2. Weight and dimensional data was provided by the customer. The values used in this analysis must be verified. If they vary, disregard these recommendations and notify Mechanical Control Systems of the changes.

3. These calculations will certify seismic restraints for seismic loads identified in Paragraph VI.

4. Housekeeping pads are by others. Per ICC Report ESR-1917, the minimum concrete thickness for Hilti Kwik Bolt TZ is 3-inches or 1.5 x anchor embedment – whichever is greater.

5. Bolt sizes and quantities are the minimum required to withstand the specified seismic forces as applied through the equipment center of gravity. This makes the standard seismic design assumption that all components and modules are connected to respond as a unitary lump mass. Any additional bolting required by the equipment manufacturer must also be installed.



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		5 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

### II. PURPOSE:

These calculations are submitted to Johnson and Jordan for MMC Bean - AHU Replacement, to certify that the seismic restraints provided or recommended by Mechanical Control Systems will safely accept loads resulting from seismic forces.

#### III. SCOPE:

These calculations are for the seismic restraints supplied or specified by Mechanical Control Systems for use on the equipment per the Table II. These calculations certify that the Mechanical Control Systems components and specified hardware, when <u>properly installed</u>, are capable of safely supporting the specified seismic loads. These calculations do not cover equipment supplied by vendors nor the superstructure or substructure to which the Mechanical Control Systems components or specified hardware are attached. If there are any specs that supersede these assumptions, this analysis is invalid.

#### IV. STRATEGY AND ASSUMPTIONS:

For the purposes of this analysis, we must assume that the building and its internal structure have been designed to perform safely in response to an earthquake and remain intact and functioning after such an event. The equipment must be restrained and not break away from its supports during an earthquake. Therefore, the sum of the forces and moments acting on the equipment must be equal to zero. The problem can be reduced to a static analysis.

The force generated by the earthquake is composed of a vertical component and a horizontal component which act simultaneously about the equipment's center of gravity. The vertical component is taken to be  $.2 \times S_{ds}$  multiplied by the equipment weight and added to the weight of the equipment. The compass orientation of the horizontal component is not known, therefore, assume an orientation that produces a worst case loading for a particular system. This information is based upon local and national codes.

#### V. EXEMPTIONS

#### PIPE

A. Pipe that passes through a wall or floor penetration. Provide positive attachment. No additional restraint required.

B. Top of pipe is within 12" of the support attachment to the structure. No additional restraint required.

C. Pipe is anchored and/or guided. No additional restraint required.



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		6 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

# VI. ALLOWABLE LOADS:

Unless otherwise specified, allowable bolt loads are per the Manual of Steel Construction - AISC 360-10. Concrete is assumed to be fc' = 3,000 psi (minimum) – normal weight. ACI 318

For Hilti TZ Anchors, ratings are based on ICC Report ESR-1917.

## **VII. SEISMIC FORCES:**

## **IBC / ASCE-7**

# Portland, ME

MCE Ground Motion Zip Code - 04102 (sec),(%g) 0.2 , <b>032.2</b> ,MCE Value of Ss 1.0 ,007.8,MCE Value of S1 Spectral Parameters for , Site Clas Fa = <b>1.55</b> Fv = 2.40	ss D
S <sub>S</sub> := .322	$F_A := 1.55$
$S_{DS} := \frac{2}{3} \cdot F_A \cdot S_S$	$S_{DS} = 0.333$ g
I <sub>p</sub> := 1.5	Component Importance Factor - 1.5 for life safety components, component containing certain quantities of hazardous or flammable materials, certain storage racks 1.0 for all other components
a <sub>p</sub> := 1	Component amplification factor -Table 13.6-1
$R_{p} := 2.5$	Component Response Modification Factor - Table 13.6-1
z := 1	Height in structure at point of attachment
h := 1	Average roof height relative to base
k is not required to be tak	ten as greater than $k := 1.6 \cdot S_{DS} \cdot I_p$ $k = 0.80$

k is not required to be taken as greater than $k := 1.6 \cdot S_{DS} \cdot I_p$ k = 0.80k shall not be taken as less than $k := .3 \cdot S_{DS} \cdot I_p$ k = 0.15



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		7 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

Spring isolated components and systems, and internally isolated components and systems - above grade

 $a_p \coloneqq 2.5 \qquad R_p \coloneqq 2.0 \qquad z \coloneqq 1$ 

$$\mathbf{k} \coloneqq \frac{.4 \cdot \mathbf{a}_{p} \cdot S_{DS}}{\frac{R_{p}}{I_{p}}} \cdot \left(1 + 2 \cdot \frac{z}{h}\right) \qquad \mathbf{k} = 0.75 \qquad \mathbf{F}_{p} \coloneqq 0.75 \cdot \mathbf{W}_{p}^{\blacksquare}$$



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		8 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			



# **ASSUMPTIONS:**

Equipment to be restrained has sufficient strength and stiffness to withstand the imposed forces and to transmit the forces to the restraints.

# FIND:

The shear force - V  $_{max}$ The tension force - T  $_{max}$ The compression force - C  $_{max}$ 



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		9 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

# ANALYSIS:

The horizontal component can occur in any axis. The maximum forces occur at an angle which is a function of the anchor spacing. The maximum forces occur for the following angle:

 $\Theta_{\max} := \operatorname{atan}\left(\frac{A}{D}\right) \cdot \left(\frac{360}{2 \cdot \pi}\right) \qquad \qquad \Theta_{\max} = 25.77 \qquad \text{,degrees}$  $\Theta_{\max} := \Theta_{\max} \cdot \frac{2 \cdot \pi}{360} \qquad \qquad \Theta_{\max} = 0.45 \qquad \text{, radians}$ 

Summing the Moments

$$M_{XT} := (F_{p} \cdot \sin(\Theta_{max}) \cdot H_{cg}) + (F_{pv} \cdot Zcg_{off}) \qquad M_{XT} = 90816$$

$$M_{ZT} := (F_{p} \cdot \cos(\Theta_{max}) \cdot H_{cg}) + (F_{pv} \cdot Xcg_{off}) \qquad M_{ZT} = 184890$$

$$M_{XC} := (F_{p} \cdot \sin(\Theta_{max}) \cdot H_{cg}) + (W_{p} + F_{pv}) \cdot Zcg_{off} \qquad M_{XC} = 119816$$

$$M_{ZC} := (F_{p} \cdot \cos(\Theta_{max}) \cdot H_{cg}) + (W_{p} + F_{pv}) \cdot Xcg_{off} \qquad M_{ZC} = 196490$$

Maximum tension (T max) is obtained from,

$$T_{max} := \left(\frac{F_{pv} - W_p}{4}\right) + \left(\frac{M_{XT}}{2 \cdot D}\right) + \left(\frac{M_{ZT}}{2 \cdot A}\right)$$

$$T_{max} = 280 , lbs.$$

Maximum compression (C max) is obtained from,

$$C_{\max} := \left(\frac{-W_p + F_{pv}}{4}\right) - \left(\frac{M_{XC}}{2 \cdot D}\right) - \left(\frac{M_{ZC}}{2 \cdot A}\right)$$

 $C_{max} = -3170$  , lbs.

Calculate the shear force (V max ) on each anchor

$$v_{max} := \frac{F_p}{4} \qquad \qquad \text{V}_{max} = 1088 \qquad \qquad \text{, lbs.}$$



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		10 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

SUMMARY: Each anchor m	nust be capable of wi	thstanding the follo	owing forces
Compression :	$C_{max} = -3170$	, Ibs.	
Tension:	$T_{max} = 280$	, Ibs.	
Shear:	$V_{max} = 1088$	, Ibs.	
Evaluate Bolte	ed Attachment to	Steel	
BOLT SUMMAR	Y - The maximum fo	rce imposed on the	single bolt attachment are:
Tension:	$T_{max} = 280$	, lbs.	
	$V_{max} = 1088$	, Ibs.	
Combined shear	and tension check for	r A325 Bolt per Als	SC
Root area of 1/2	2" dia bolt = .126 in	<sup>2</sup> - AISC ASD 9th	edition
f <sub>tb</sub> :=	$=\frac{T_{max}}{.126}$	$f_{tb} = 2225$	,psi
f <sub>vb</sub> :=	$=\frac{V_{max}}{.126}$	$f_{vb} = 8631$	,psi
Maximum allow	wable shear stress is 2	21,000 psi. OK	
The maximum	allowable tension str	ressis:	
$f_{t2} := \sqrt{44^2}$ -	$4.39 \cdot \left(\frac{f_{vb}}{1000}\right)^2$	$f_{t2} = 40.1$	ksi
$f_{tb}$ is less than f $_{t2,}$ so	the bolt is OK. Use	4 Bolts - 1/2-inch d	liameter - per ASTM A325
For concrete atta	chment æe Hilti Pro	fisreport	



PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		11 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

1 Input data		
Anchor type and diameter:	Kwik Bolt TZ - CS 1/2 (3 1/4)	
Effective embedment depth:	h <sub>ef</sub> = 3.250 in., h <sub>nom</sub> = 3.625 in.	
Material:	Carbon Steel	
Evaluation Service Report:	ESR-1917	
Issued I Valid:	5/1/2013   5/1/2015	
Proof:	Design method ACI 318 / AC193	
Stand-off installation:	- (Recommended plate thickness: not calculated)	
Profile:	no profile	
Base material:	cracked concrete, 3000, $f_c$ ' = 3000 psi; h = 6.000 in.	
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present	
	edge reinforcement: none or < No. 4 bar	
Seismic loads (cat. C, D, E, or F)	yes (D.3.3.6)	
Geometry [in.] & Loading [lb, in.lb]		
	z	





PROJECT		DWG NUMBER	REV. NO.	SHEET NO.
MMC Bean - AHU Replacement		J5110		12 OF 20
ORIGINATOR	DATE	CHECKED	DA	TE
TPL	4/28/2015			

#### 2 Proof I Utilization (Governing Cases)

			Design	values [lb]	Utilization	
Loading	Proof		Load	Capacity	β <sub>N</sub> / β <sub>V</sub> [%]	Status
Tension	Pullout Strength		280	1050	27/-	OK
Shear	Concrete edge failure	in direction x-	1088	1380	- / 79	ок
Loading		βN	βv	ζ	Utilization <sub>βN,V</sub> [%]	Status
Combined tensio	n and shear loads	0.267	0.789	5/3	79	ок

#### 3 Warnings

· Please consider all details and hints/warnings given in the detailed report!

## Fastening meets the design criteria!

#### 4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for he results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

#### Use HILTI KWIK BOLT TZ

- 1/2-inch diameter
- 4- inch embedment
- 3,000 psi concrete
- 5- inch minimum edge distance
- 6- inch minimum concrete thickness
- cracked or uncracked concrete

Install per Manufacturer's instructions and ESR-1917.















