Honeywell Inc. 501 County Road Westbrook, Me. 04092

## Honeywell Inc.

January 30, 2008

E.S. Boulos Co. 45 Bradley Dr. Westbrook, Maine 04092

Att'n: Mr. Mike Roy

Re: Maine Medical Center Central Utilities Plant Fire Alarm

Dear: Mr. Roy

This letter is to confirm that all fire alarm initiating devices (20 heats, 7 Smokes, 4 Duct Smokes, 9 pulls, 3 Flows and 5 Tampers) for the CUP at Maine Medical Center have been tested and found to operate properly. Also all 25 of the Horns and Strobes operate correctly.

Sincerely,

Gary Wood System Specialist