



- 1 DEMOLITION, RELOCATION OF EXISTING OR REPAIR/REPLACE WITH NEW EQUIPMENT OF THIS PROJECT MUST BE PLANNED AND SCHEDULED TO OCCUR PRIOR TO THE START OF CONSTRUCTION. ALL WORK SHALL BE COMPLETED WITH ALL EXCEPTIONS SHALL BE TAKEN.
- 2 AIR-119 IN NEW POSITION, SMALL CONNECTION AS EXISTING, COVER WITH ARCHITECTURAL AND STRUCTURAL STEAM PIPING TO SKIN DIRECTLY DOWN TO PIPING ASSEMBLY. INSULATE PIPING WITH 2" POLYISOCYANURATE (PIR) INSULATION AND ADD AIR PURIFICATION.
- 3 PROVIDE NEW EXTERIOR DUCT CONNECTIONS TO NEW AIR-119 EXHAUST THROUGH WEATHERPROOF WALL TO MATCH EXISTING.
- 4 EXISTING EXHAUST GRILLE TO REMAIN.
- 5 COORDINATE SUPPLY GRILLES AND RETURN RESISTERS WITH RCP.
- 6 DUCTS IN THIS CORRIDOR MOUNTED STRUCTURAL STEEL BEAMS.
- 7 PROVIDE FIRE DAMPERS AND SMOKE DAMPERS WITH DUCT ACCESS PANELS, EXISTING PANEL TO REMAIN, PROVIDE NEW DUCT ACCESS PANELS TO MATCH EXISTING.
- 8 VERIFY SIZE SUPPLY AND RETURN AIR DUCTWORK FOR FUTURE CONNECTION TO AIR SYSTEM, CHARLES STREET BUILDING.
- 9 NEW ARCHITECTURAL, FRESH AIR INTAKE LOWER BY ARCHITECT, REFER TO ARCHITECTURAL, OPEN.
- 10 3800 CFM FUTURE RETURN AIR, AMBULANCE COMMANDER EXHAUST FAN.
- 11 HAZMAT EXHAUST FAN.
- 12 GENERAL EXHAUST FAN.
- 13 UNCOMMONLY THIS FLOOR IS OCCUPIED BY THE PROJECT, VERIFY OCCUPANCY AND TO BE COMPLETED PRIOR TO THE START OF CONSTRUCTION.
- 14 ELECTRIC UNIT HEATER POWER BY SW 16.

NO.	SIZE	DATE	DESCRIPTION
1	1/2"	01/2023	ISSUED FOR PERMIT
2	1/2"	01/2023	ISSUED FOR PERMIT
3	1/2"	01/2023	ISSUED FOR PERMIT
4	1/2"	01/2023	ISSUED FOR PERMIT
5	1/2"	01/2023	ISSUED FOR PERMIT
6	1/2"	01/2023	ISSUED FOR PERMIT
7	1/2"	01/2023	ISSUED FOR PERMIT
8	1/2"	01/2023	ISSUED FOR PERMIT
9	1/2"	01/2023	ISSUED FOR PERMIT
10	1/2"	01/2023	ISSUED FOR PERMIT
11	1/2"	01/2023	ISSUED FOR PERMIT
12	1/2"	01/2023	ISSUED FOR PERMIT
13	1/2"	01/2023	ISSUED FOR PERMIT
14	1/2"	01/2023	ISSUED FOR PERMIT
15	1/2"	01/2023	ISSUED FOR PERMIT



Maine Medical Center
 Project - George Vanit Camp / Helport
 Portland, ME
 MAEC Project No. 2185

CONNECTOR
HVAC GROUND FLOOR PLAN
NEW DUCTWORK

H20G.2