


- Legend:
- 1 1 1/2" LMS AIR PIPING DOWN, PROVIDE SHUTOFF CIRCUIT AFTER BALANCE TO 10 GPM.
 - 2 INSTALL SPRING STEPS FOR ALL PIPING. FOR FLOOR, FLOOR AND ROOF AND PROVIDE FIRE STOPPING AS REQUIRED. FOR CONCRETE AS REQUIRED. FOR CORE CONCRETE AS REQUIRED.
 - 3 1" COMPRESSED AIR PIPE FOR HVAC CONTROLS.
 - 4 1" FANS AND VAVS. PROVIDE WITH CIRCUIT AFTER BALANCE TO 10 GPM.
 - 5 RELOCATED AHU-119.
 - 6 RELOCATED THERM AIR FOR LABORATORY AND CT SCAN.

DATE: 04/11/19
 DRAWN BY: JLM
 CHECKED BY: JLM
 PROJECT: MAINE MEDICAL CENTER
 FLOOR: GROUND FLOOR
 SYSTEM: HVAC PIPING



TRO
 ARCHITECTURE
 135 BOSTON STREET
 PORTLAND, ME 04101
 TEL: (603) 734-1000
 WWW.TROARCHITECTURE.COM

Maine Medical Center
 CONNECTOR
 HVAC GROUND FLOOR PLAN
 NEW PIPING
H30G.2

0 1" = 1'-0" (SCALE)
 0 1" = 1'-0" (SCALE)
 0 1" = 1'-0" (SCALE)