POWER SYMBOLS CIRCUIT BREAKER GROUND CONNECTION LP1-2 HOME RUN TO PANEL (CKT. NO. AS SHOWN) TRANSFORMER CURRENT TRANSFORMER POTENTIAL TRANSFORMER 20 AMPERE, 120 VOLT DUPLEX \Rightarrow RECEPTACLE, +18" AFF 20 AMPERE, 120 VOLT DUPLEX HOSPITAL GRADE RECEPTACLE, +18" AFF 20 AMPERE, 120 VOLT DUPLEX SWITCHED RECEPTACLE, +18" AFF 20 AMPERE, 120 VOLT DOUBLE DUPLEX RECEPTACLE, +18" AFF 20 AMPERE, 120 VOLT DOUBLE DUPLEX HOSPITAL GRADE RECEPTACLE, +18" AFF 20 AMPERE, 120 VOLT SINGLE - RECEPTACLE 20 AMPERE, 120 VOLT DUPLEX HOSPITAL GRADE GFCI RECEPTACLE 20 AMPERE, 120 VOLT DUPLEX GFCI RECEPTACLE, +18" AFF OTHER POWER RECEPTACLE NEMA DESIGNATION AS NOTED MOTOR JUNCTION BOX TRANSFORMER CIRCUIT BREAKER SIZED AS NOTED PANELBOARD NORMAL POWER **PANELBOARD** EMERGENCY POWER BUS DUCT AMPERE RATING AS NOTED BUS DUCT 20A FUSE ASSEMBLY W/ 10' DROP CORD & NEMA 5-20 QUAD RECEPTACLE BUS DUCT 20A FUSE ASSEMBLY W/ 10' DROP CORD & 2- OR 3-POLE TWIST LOCK RECEPTACLE AS SHOWN UNFUSED SAFETY SWITCH, RATING AS NOTED POLES - AMPERES FUSED SAFETY SWITCH, FH200/3 RATING AS NOTED POLES ---- AMPERES MAGNETIC MOTOR STARTER, RATING AS NOTED MANUAL TOGGLE OPERATED MOTOR STARTER ELECTRIC ACTUATED VALVE MOTOR CONTACTOR CONTACT NORMALLY OPEN CONTACT NORMALLY CLOSED

SELECTOR SWITCH

PILOT LIGHT

TEMPERATURE SWITCH

LIGHTING SYMBOLS				
O A	FLUORESCENT LIGHT FIXTURE			
/////////////////////// x	FLUORESCENT LIGHT FIXTURE ON UNSWITCHED NIGHT LIGHT CIRCUIT			
x x	FLUORESCENT WALL MOUNTED FIXTURE			
├ - ० _x	FLUORESCENT STRIP FIXTURE			
□x	EXTERIOR H.I.D. WALL-PACK			
α^{x}	ROUND RECESSED CEILING MOUNTED FIXTURE			
© _x	PENDANT MOUNTED FIXTURE			
Д×	WALL MOUNTED INCANDESCENT LIGHTING FIXTURE			
⊥x	WALL SCONCE			
[]+¤×	TRACK LIGHTING FIXTURE (TRACK MOUNTED FIXTURE TYPE MAY VARY)			
	EMERGENCY LED EXIT SIGN			
	COMBINATION EMERGENCY EXIT SIGN & LIGHTING FIXTURE WITH DUAL LAMPS HEADS BATTERY AND CHARGER			
44	EMERGENCY LIGHTING FIXTURE WITH DUAL LAMPS HEADS BATTERY AND CHARGER			
\triangleright	REMOTE EMERGENCY LIGHTING LAMP HEAD			
S _{Pa}	LIGHT SWITCH DENOTES FIXTURE SWITCHED P = PILOT LIGHT (WHERE NOTED) 3 = 3-WAY (WHERE NOTED) 4 = 4-WAY (WHERE NOTED)			
⇔ _X	ULTRASONIC/INFRARED OCCUPANCY SENSOR			

- C = CEILING MOUNTED

LIGHTING CONTACTOR

LIGHTING TIME CLOCK

W = WALL MOUNTED 48" AFF (TO TOP)

<u>FIR</u>	E ALARM SYMBOLS
E	PULL STATION
H Z	FIRE ALARM AUDIBLE/VISIBLE NOTIFICATION APPLIANCE (GENERAL EVACUATION)
:	STROBE UNIT XX= CANDELA
	NON-SYSTEM STROBE UNIT
H	MINI HORN UNIT
\$	SMOKE DETECTOR
135 CR	FIXED TEMP HEAT DETECTOR (135F OR 200F)
FACE	FIRE ALARM CONTROL PANEL
727	ANNUNCIATOR
МВ	MASTER BOX
0	DIGITAL COMMUNICATOR
\$	DUCT SMOKE DETECTOR
	REMOTE TEST STATION
TS	SPRINKLER TAMPER SWITCH
FS	SPRINKLER FLOW SWITCH
[PS]	SPRINKLER PRESSURE SWITCH
MM	MONITOR MODULE
CM]	CONTROL MODULE
S ₁₂₀	NON-SYSTEM SMOKE DETECTOR STR = DENOTES INTEGRAL STROBE FOR H/C UNITS
O _R	RED MASTER BOX LIGHT
KB	KNOX BOX, FBO
EXT	HOOD EXT SYSTEM
DH	DOOR HOLDER
FCPS	SIGNAL POWER EXTENDER

SYSTEMS SYMBOLS

DATA SYSTEM WALL JACK

NURSE CALL — CALL LIGHT

■ NURSE CALL — PUSH BUTTON

NCP NURSE CALL - MASTER STATION

DO DOOR OPERATOR SWITCH

SP INTERCOM SYSTEM SPEAKER

INT INTERCOM MASTER STATION

CR CARD READER (EQUIP. BY OTHERS)

NURSE CALL — PULL CORD STATION

SECURITY SYSTEM DOOR SWITCH

SECURITY SYSTEM CARD ACCESS PAD

ELECTRIC DOOR STRIKE (EQUIP. BY OTHERS)

TV CATV JACK

TELEPHONE SYSTEM WALL JACK

COMBINATION VOICE/DATA SYSTEM OUTLET

^			LOW VOLIAGE
AC	ALTERNATING CURRENT	MCB	MAIN CIRCUIT BREAKER
AFF	ABOVE FINISHED FLOOR	MCC	MOTOR CONTROL CENTER
AFG	ABOVE FINISHED GRADE	MCP	MOTOR CIRCUIT PROTECTION
AIC	AMPERES INTERRUPTING CAPACITY	MH	METAL HALIDE
AL	ALUMINUM	EMH	ELECTRICAL MANHOLE
ASYM	ASYMMETRICAL	MLO	MAIN LUGS ONLY
ATS	AUTOMATIC TRANSFER SWITCH	МО	MECHANICALLY OPERATED
AUX	AUXILIARY	MOD	MOTOR OPERATED DAMPER
AWG	AMERICAN WIRE GAUGE	MTS	MANUAL TRANSFER SWITCH
BKR	BREAKER	MV	MERCURY VAPOR
C		MVA	MEGAVOLT—AMPERE
CAB	CONDUIT	NC	NORMALLY CLOSED
	CABINET	NO	NORMALLY OPENED
CB	CIRCUIT BREAKER	OH	i i
CKT	CIRCUIT	OL	OVERHEAD
CT	CURRENT TRANSFORMER	OOA	OVER LOAD
CU	COPPER	OSY	ON-OFF-AUTOMATIC
DC	DIRECT CURRENT		OUTSIDE STEM & YOKE VALVE (FA SYSTEM
DISC	DISCONNECT	P	POLE
EG	EQUIPMENT GROUND	PB	PUSH BUTTON
EH	ELECTRICALLY HELD	PF	POWER FACTOR
EM	EMERGENCY	PH	PHASE
EMT	ELECTRICAL METALLIC TUBING	PNL	PANEL
EO	ELECTRICALLY OPERATED	PRI	PRIMARY
EPR	ETHYLENE PROPYLENE RUBBER	PT	POTENTIAL TRANSFORMER
EQUIP	EQUIPMENT	PVC	POLYVINYL CHLORIDE
EX	EXTERIOR	RGSÇ	RIGID GALVANIZED STEEL CONDUIT
FA	FIRE ALARM	RVSS	REDUCED VOLTAGE SOLID STATE
FC	FOOT-CANDLE	RSC	RIGID STEEL CONDUIT
FDR	FEEDER	RVAT	REDUCED VOLTAGE AUTO TRANSFORMER
FLUOR	FLUORESCENT	S	SIGNAL
FS	FLOW SWITCH (FA SYSTEM)	SEC	SECONDARY
FVNR	FULL VOLTAGE NON REVERSING	SHLD	SHIELDED CABLE
FVR	FULL VOLTAGE REVERSING	SW	SWITCH
GEN	GENERATOR	SWBD	SWITCHBOARD
GF	GROUND FAULT	SYM	SYMMETRICAL
GFI	GROUND FAULT CIRCUIT INTERRUPTER	T	TELEPHONE
GND	GROUND	TR	TRANSFORMER
Н	HAND HOLE	TBD	TO BE DETERMINED
HOA	HAND-OFF-AUTOMATIC	TD	TELEDIALER
HP	HORSE POWER	TDR	TIME DELAY RELAY
HPS	HIGH PRESSURE SODIUM	TEL	TELEPHONE
HV	HIGH VOLTAGE	TM	TELEMETRY
HZ	HERTZ	UG	UNDERGROUND
IG	ISOLATED GROUND	UT	
IMC	INTERMEDIATE METAL CONDUIT		UTILITY
INCAND	INCANDESCENT	٧	VOLT
JB		VA	VOLT-AMPERE
KCMIL	JUNCTION BOX	VFD	VARIABLE FREQUENCY DRIVE
KV	THOUSAND CIRCULAR MILS	W	WATT
KVA	KILOVOLT	WH	WATT HOUR
KW	KILO VOLT—AMPERE	WP	WEATHERPROOF
	KILOWATT	XFMR	TRANSFORMER
KWH	KILOWATT HOUR	XLP	CROSS LINKED POLYETHYLENE
LPS	LOW PRESSURE SODIUM	XP	EXPLOSION PROOF
LTG			

GENERAL NOTES

ABBREVIATIONS

AMPERE

- 1. ALL WORK SHALL BE IN COMPLIANCE WITH NFPA-70, NATIONAL ELECTRICAL CODE.
- 2. ALL MOTOR SAFETY SWITCHES, DISCONNECTS AND MOTOR STARTERS ARE FURNISHED BY DIVISION 16000 UNLESS NOTED AS FURNISHED WITH EQUIPMENT (FWE).
- 3. UNLESS OTHERWISE NOTED, MOUNTING HEIGHTS SHALL BE AS FOLLOWS: CONVENIENCE RECEPTACLES: 18" AFF VOICE/DATA JACKS: 18" AFF LIGHTING TOGGLE SWITCHES: 48" AFF TO TOP OF DEVICE
 - FIRE ALARM HORN AND STROBE UNITS: 80" AFF OR 6" BELOW CEILING (WHICHEVER IS LOWER) 48" TO TOP OF DEVICE FIRE ALARM PULL STATION:

SIDE WIRED, AS MANUFACTURED BY LEVITON, PASS & SEYMOUR, OR APPROVED EQUAL.

SEALANT METERIAL TO MAINTAIN THE RATING OF THE SEPARATION. 5. LIGHTING TOGGLE SWITCHES SHALL BE COMMERCIAL SPECIFICATION GRADE, 120 VOLT, SIDE WIRED AS MANUFACTURED

4. ALL PENETRATIONS THROUGH FLOORS, RATED WALLS AND PARTITIONS SHALL BE SEALED WITH A UL APPROVED FIRE

- BY LEVITON, PASS & SEYMOUR, OR APPROVED EQUAL. 6. CONVENIENCE RECEPTACLES SHALL BE HOSPITAL GRADE UNLESS SHOWN OTHERWISE, GROUNDING TYPE, NEMA 5-20R,
- 7. UNLESS OTHERWISE NOTED ALL HOMERUNS FOR 15 OR 20A CIRCUITS SHALL BE 2#12AWG & #12 GND. HOMERUNS FED FROM 20A, 1P CIRCUITS IN EXCESS OF 100 FEET SHALL BE #10AWG. ALL WIRING SHALL BE COPPER.

LOW VOLTAGE

8. CONDUIT SYSTEMS: EXPOSED INTERIOR CONDUITS SHALL BE EMT, 3/4" MINIMUM. PROPERLY SUPPORTED HOSPITAL GRADE MC CABLE ASSEMBLIES WITH SECOND LISTED GROUND PATH MAY BE USED ABOVE CEILINGS AND IN WALLS.



Richards Wing

Ninth Floor

Renovations

Maine Medical Center Portland, Maine 04102

Architect Winton Scott Architects

Portland, Maine

Mechanical Engineering Mechanical Sytems Engineers

Yarmouth, Maine

Electrical Engineering Swiftcurrent Engineering Services Yarmouth, Maine

Electrical Legend and **General Notes**

E0

Scale: Not to Scale

March 16, 2009