


NOTES:

1. SEE DRAWING E0 FOR GENERAL NOTES AND LEGEND.
2. ALL WIRING TO BE CONCEALED. COORDINATE DROPS TO SWITCHES WITH ACM CONTRACTOR.
3. MAINTAIN CONTINUITY OF SERVICE AT ALL TIMES. FIELD VERIFY AREAS SERVED BY EXISTING BRANCH CIRCUITS.
4. VERIFY EXISTING CIRCUITS. REWIRE TO EXISTING CIRCUITS WHERE POSSIBLE. ADDITIONAL LIGHTING CIRCUITS IF REQUIRED SHALL ORIGINATE FROM EXISTING SPARE 20A CIRCUITS.
5. VERIFY EXTENT OF EXISTING LIFE SAFETY AND CRITICAL CARE POWER. MAINTAIN SEPARATION OF SERVICES. PROVIDE LIGHTING SHOWN FROM LIFE SAFETY EMERGENCY POWER PANEL.
6. THIS DRAWING IS FOR DIAGRAMMATIC CONTROL GROUPS ONLY. MAINTAIN AN AS-BUILT DRAWING ON SITE WITH ACTUAL HOME RUNS AND CIRCUIT DESIGNATIONS.



KEYED NOTES:

- ① REMOVE EXISTING CAN LIGHT AND REINSTALL IN NEW GRID TYPE ACT CEILING.
- ② REUSE EXISTING FIXTURES REMOVED FROM THIS AREA AND CONNECT TO LOCAL CORRIDOR LIGHTING CIRCUIT.
- ③ RELOCATE LIGHT TO THIS LOCATION (SEE NOTE 4) AND RECONNECT TO DIMMING CIRCUIT.
- ④ REMOVE LIGHT AND RELOCATE (SEE NOTE 3).
- ⑤ DIMMER SWITCH TO BE LUTRON ADRIANI AYF-103P WITH ELVI-1000 ELECTRONIC LOW VOLTAGE INTERFACE.
- ⑥ REMOVE AND REINSTALL EXISTING LIGHTING SWITCHES AND DIMMING SWITCHES ON EXISTING COLUMN.

1 LIGHTING PLAN
SCALE: 1/8" = 1'-0"

LIGHTING SCHEDULE

TYPE	DESCRIPTION	MANUFACTURER	LAMPS	MOUNTING	NOTES
A	1' X 4' SPECIFICATION GRADE ACRYLIC TROFFER. 120V	COLUMBIA LIGHTING	(3) - 32W SUPER T8	CEILING GRID	CAT #: ST814-332
B	2' X 4' SPECIFICATION GRADE ACRYLIC TROFFER. 120V	METALUX LIGHTING	(4) - 32W SUPER T8	CEILING GRID	CAT #: 2GC432
C1	2' X 2' CENTER PERFORATED BASKET TYPE DIRECT/INDIRECT 120V	LIGHTOLIER	(2) - 40W TT5	CEILING GRID	CAT #: QVS2GPFOS2FT120SO
C2	2' X 4' CENTER PERFORATED BASKET TYPE DIRECT/INDIRECT 120V	LIGHTOLIER	(3) - 32W SUPER T8	CEILING GRID	CAT #: QVS2GPFOS332 FURNISH WITH DUAL BALLAST WHERE REQUIRED FOR DUAL LEVEL SWITCHING
C3	2' X 2' SEMI-RECESSED CENTER PERFORATED BASKET TYPE DIRECT/INDIRECT. 120V	LIGHTOLIER	(2) - 40W TT5	CEILING GRID	CAT #: QVH2GPFOS2FT120SO
D	1' X 4' WET AREA RECESSED ACRYLIC TROFFER 120V	LIGHTOLIER	(2) - 32W SUPER T8	CEILING GRID	CAT #: WES1GRAVA232
E	8" DIAMETER HORIZONTAL OPEN DOWNLIGHT 120V	PRESCOLITE	(1) - 26W TRIPLE TUBE CF	CEILING RECESSED	CAT #: CFT832HEB (HOUSING) STF802H (REFLECTOR)

LIGHTING SCHEDULE

TYPE	DESCRIPTION	MANUFACTURER	LAMPS	MOUNTING	NOTES
F	8" DIAMETER HORIZONTAL DOWNLIGHT WITH REGRESSED PRISMATIC LENS. WET LOCATION LISTED. 120V	PRESCOLITE	(1) - 26W TRIPLE TUBE CF	CEILING RECESSED	CAT #: CFT832HEB (HOUSING) STF802H-DL (REFLECTOR)
G	18" DIAMETER BATHROOM LIGHT. 120V	SPI LIGHTING	(2) - 26W CF	CEILING SURFACE (4" OCTAGONAL BOX)	CAT #: AIC1060
H	4' PARABOLIC LINEAR WALL WASH FIXTURE 120V	LINEAR LIGHTING	(2) - 32W SUPER T8	CEILING GRID	CAT #: WW2D2ET8120PBLRBW
J	15" DECORATIVE WALL SCONCE - SATIN NICKEL/BLACK WALNUT FINISH. 120V	CORONET RIDGEWOOD	100W A-LAMP INCD	WALL SURFACE	CAT #: 1499
K	DIMMABLE RECESSED DOWNLIGHT FOR NIGHTTIME USE. FURNISH WITH ELECTRONIC TRANSFORMER AND DIMMING SYSTEM. 120V	LIGHTOLIER	(1) - 37W MR16 IR FL	CEILING RECESSED	CAT #: 372CHX/302MREX
L	SURFACE MOUNTED ACRYLIC WRAPAROUND FIXTURE 120V	LIGHTOLIER	(1) - 32W SUPER T8	WALL SURFACE (ABOVE DOOR)	CAT #: JS4C132120SO

Richards Wing
Ninth Floor
Renovations

Maine Medical Center
Portland, Maine 04102

Architect
Winton Scott Architects
Portland, Maine

Mechanical Engineering
Mechanical Systems Engineers
Yarmouth, Maine

Electrical Engineering
Swiftcurrent Engineering Services
Yarmouth, Maine

Electrical
Lighting Plan
E2

Scale: 1/8" = 1'-0"
March 16, 2009