


**NOTES:**

1. SEE DRAWING E0 FOR GENERAL NOTES AND LEGEND.
2. ALL WIRING TO BE CONCEALED. COORDINATE DROPS TO DEVICES.
3. MAINTAIN CONTINUITY OF SERVICE AT ALL TIMES.
4. THIS DRAWING IS FOR DIAGRAMMATIC CONTROL GROUPS ONLY. MAINTAIN AN AS-BUILT DRAWING ON SITE WITH ACTUAL HOME RUNS AND CIRCUIT DESIGNATIONS.

**KEYED NOTES:**

- ① DATA JACK FOR PARX SYSTEM. MOUNT ABOVE RECEPTACLE.
- ② PYX SYSTEM.
- ③ FAX.
- ④ MULTI-PRINTER.
- ⑤ REMOVE AND REINSTALL IN LOCATION SHOWN.
- ⑥ REMOVE WIREMOLD WITH PHONE JACKS AS SHOWN.
- ⑦ CARD READER AND DOOR STRIKE. INSTALL PATHWAYS ONLY. EQUIPMENT BY OTHERS. COORDINATE DOOR STRIKE LOCATION WITH EQUIPMENT FURNISHED.
- ⑧ FEEDS TO THIS SMALL DESK SHALL BE FROM THE 8TH FLOOR.
- ⑨ DATA OUTLET FOR PHYSIOLOGIC MONITORING EQUIPMENT CABINET MOUNTED IN CABINET FURNISHED BY OWNER. SEE KEY NOTE 18 ON DRAWING E1 FOR DESCRIPTION.
- ⑩ IN EACH OF THE PATIENT ROOMS WHERE DIRECTED, RELOCATE TWO OF THE TELEPHONE JACKS ON THE HEADBOARD WALLS FROM THEIR EXISTING LOCATION TO 40" AFF.
- ⑪ EXISTING TO REMAIN.



Richards Wing  
Ninth Floor

Renovations

Maine Medical Center  
Portland, Maine 04102

Architect  
Winton Scott Architects  
Portland, Maine

Mechanical Engineering  
Mechanical Systems Engineers  
Yarmouth, Maine

Electrical Engineering  
Swiftcurrent Engineering Services  
Yarmouth, Maine

Electrical  
Systems Plan  
**E3**

Scale: 1/8" = 1' - 0"  
March 16, 2009