



... Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : MMC 2CND FLOOR RICHARDS
Building : Richards Building
Location : Maine Medical Center-22 Bramhall St-Portland, Me
System : WX4
Contract : C0810818
Data File : MMC---2C.WX4

Hydraulic Design Information Sheet

Name - Second Floor Fire Protection Upgrade Date - 11/7/08
 Location - Maine Medical Center-22 Bramhall St-Portland, Me
 Building - Richards Building System No. - WX4
 Contractor - Dean & Allyn, Inc Contract No. - C0810818
 Calculated By - James R White Drawing No. - 1 of 1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 8'-0"
 Occupancy - Hospital- typical patient room

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 5 HEADS System Type Sprinkler/Nozzle
 Density - .1 (X) Wet Make VIKING
 D Area Per Sprinkler - 138 () Dry Model VK606/VK304
 E Elevation at Highest Outlet - 8'-0" () Deluge Size 3/4"/1/2"
 S Hose Allowance - Inside - 100 () Preaction K-Factor 8.0/5.6
 I Rack Sprinkler Allowance - 0 () Other Temp.Rat.155 deg
 G Hose Allowance - Outside - 0
 N Note SAFETY MARGIN= 68.96 PSI - LARGEST ROOM + 2 (5 HEADS) (EXT COVERAGE)

Calculation Flow Required - 265.80 Press Required - 94.82
 Summary C-Factor Used: 120 Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 10/11/07 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 170 @ Press -
 R Residual Press - 75 Elev. - Well
 Flow - 1160 Proof Flow
 S Elevation - 0

U
 P Location - RICHARDS FIRE PUMP
 P
 L Source of Information - ANNUAL PUMP TEST
 Y

C Commodity N/A Class Location
 O Storage Ht. N/A Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf
 O C
 R K Flue Spacing N/A Clearance:Storage to Ceiling
 A Longitudinal N/A Transverse N/A
 G
 E Horizontal Barriers Provided: N/A

Fittings Used Summary

DEAN & ALLYN, INC.
MMC 2CND FLOOR RICHARDS

Page 2
Date 110408

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
Mbb	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
N	CPVC 90'EI Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
MMC 2CND FLOOR RICHARDS

Page 3
Date 110408

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D301	30.083	5.6	47.47	na	38.58	0.1	112	7.0
D302	30.083	5.6	51.6	na	40.23	0.1	96	7.0
69	29.083	5.6	20.15	na	25.14	0.1	70	7.0
71	0.0		62.33	na				
9	31.08		58.95	na				
10	31.083		71.63	na				
11	31.083		74.65	na				
12	31.083		77.03	na				
13	31.083		82.19	na				
14	11.5		90.68	na				
72	29.083	8	20.3	na	36.04	0.1	207	20.3
137	29.083		20.71	na				
68	29.083	5.6	21.25	na	25.82	0.1	70	7.0
138	31.08		31.18	na				
139	31.08		40.47	na				
140	31.08		48.9	na				
70	31.083		52.66	na				
64	31.08		64.07	na				
21	31.08		71.53	na				
20	31.08		71.52	na				
19	31.08		70.49	na				
18	31.083		70.39	na				
17	31.08		70.26	na				
5	31.08		70.23	na				
6	31.08		70.2	na				
7	31.08		70.05	na				
42	31.08		69.96	na				
43	31.08		69.81	na				
44	31.08		69.62	na				
41	31.08		69.58	na				
8	31.083		69.03	na				
15	31.083		73.44	na	100.0			
16	31.083		81.91	na				
14B	11.5		90.46	na				
14A	3.0		94.5	na				
TEST	3.0		94.82	na				

The maximum velocity is 29.32 and it occurs in the pipe between nodes 68 and 138

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
MMC 2CND FLOOR RICHARDS

Page 4
Date 110408

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D301 to 71	38.58 38.58	1.101 150 0.2294	1N 7.0 0.0 0.0	1.000 7.000 8.000	47.470 13.029 1.835		K Factor = 5.60		
	0.0 38.58				62.334		K Factor = 4.89		
D302 to 70	40.23 40.23	1.101 150 0.2478	1O 5.0 0.0 0.0	1.000 5.000 6.000	51.603 -0.433 1.487		K Factor = 5.60		
	0.0 40.23				52.657		K Factor = 5.54		
69 to 137	25.14 25.14	1.101 150 0.1039	1O 5.0 0.0 0.0	0.410 5.000 5.410	20.151 0.0 0.562		K Factor = 5.60		
	0.0 25.14				20.713		K Factor = 5.52		
71 to 140	38.58 38.58	1.598 150 0.0379	0.0 0.0 0.0	0.660 0.0 0.660	62.334 -13.461 0.025		Vel = 6.17		
	0.0 38.58				48.898		K Factor = 5.52		
9 to 8	106.91 106.91	1.598 150 0.2464	2O 16.0 0.0 0.0	24.950 16.000 40.950	58.945 -0.001 10.090		Vel = 17.10		
	0.0 106.91				69.034		K Factor = 12.87		
10 to 11	83.28 83.28	1.598 150 0.1552	1O 8.0 0.0 0.0	11.450 8.000 19.450	71.627 0.0 3.019		Vel = 13.32		
11 to 12	0.0 83.28	1.598 150 0.1553	1N 9.0 0.0 0.0	6.330 9.000 15.330	74.646 0.0 2.380		Vel = 13.32		
12 to 13	0.0 83.28	2.067 120 0.0670	3E 15.0 1Mbb 2.25 1S 11.0 1Fsp 0.0	4.020 28.250 32.270	77.026 3.000 2.161		* Fixed loss = 3 Vel = 7.96		
13 to 14	0.0 83.28	6.065 120 0.0004	1E 14.0 0.0 0.0	31.100 14.000 45.100	82.187 8.481 0.016		Vel = 0.92		
14 to 14A	0.0 83.28	6.065 120 0.0004	7E 98.0 2T 60.0 2G 6.0	207.000 164.000 371.000	90.684 3.681 0.132		Vel = 0.92		
	0.0 83.28				94.497		K Factor = 8.57		
72 to 137	36.04 36.04	1.101 150 0.2025	0.0 0.0 0.0	2.040 0.0 2.040	20.300 0.0 0.413		K Factor = 8.00		
							Vel = 12.15		
137 to 68	25.14 61.18	1.101 150 0.5380	0.0 0.0 0.0	1.000 0.0 1.000	20.713 0.0 0.538		Vel = 20.62		

Final Calculations - Standard

DEAN & ALLYN, INC.
MMC 2CND FLOOR RICHARDS

Page 5
Date 110408

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
68 to 138	25.82 87.0	1.101 150 1.0327	1N	7.0 0.0	3.450 7.000 10.450	21.251 -0.865 10.792			K Factor = 5.60 Vel = 29.32	
138 to 139	0.0 87.0	1.101 150 1.0327	1N	7.0 0.0	2.000 7.000 9.000	31.178 0.0 9.294			Vel = 29.32	
139 to 140	0.0 87.0	1.101 150 1.0326	1O	5.0 0.0	3.160 5.000 8.160	40.472 0.0 8.426			Vel = 29.32	
140 to 70	38.58 125.58	1.598 150 0.3319		0.0 0.0	11.330 0.0 11.330	48.898 -0.001 3.760			Vel = 20.09	
70 to 9	40.23 165.81	1.598 150 0.5549		0.0 0.0	11.330 0.0 11.330	52.657 0.001 6.287			Vel = 26.52	
9 to 64	-106.92 58.89	1.598 150 0.0818		0.0 0.0	62.660 0.0 62.660	58.945 0.0 5.124			Vel = 9.42	
64 to 10	0.0 58.89	1.598 150 0.0818	2N 1O	18.0 8.0	66.450 26.000 92.450	64.069 -0.001 7.559			Vel = 9.42	
10 to 21	-83.27 -24.38	1.598 150 -0.0160		0.0 0.0	6.370 0.0 6.370	71.627 0.001 -0.102			Vel = 3.90	
21 to 20	0.0 -24.38	1.598 150 -0.0152		0.0 0.0	0.330 0.0 0.330	71.526 0.0 -0.005			Vel = 3.90	
20 to 19	0.0 -24.38	1.598 150 -0.0160	1O	8.0 0.0	56.700 8.000 64.700	71.521 0.0 -1.035			Vel = 3.90	
19 to 18	0.0 -24.38	1.598 150 -0.0160		0.0 0.0	6.000 0.0 6.000	70.486 -0.001 -0.096			Vel = 3.90	
18 to 17	0.0 -24.38	1.598 150 -0.0160		0.0 0.0	8.000 0.0 8.000	70.389 0.001 -0.128			Vel = 3.90	
17 to 5	0.0 -24.38	1.598 150 -0.0159		0.0 0.0	2.080 0.0 2.080	70.262 0.0 -0.033			Vel = 3.90	
5 to 6	0.0 -24.38	1.598 150 -0.0162		0.0 0.0	1.910 0.0 1.910	70.229 0.0 -0.031			Vel = 3.90	
6 to 7	0.0 -24.38	1.598 150 -0.0160		0.0 0.0	9.000 0.0 9.000	70.198 0.0 -0.144			Vel = 3.90	
7 to 42	0.0 -24.38	1.598 150 -0.0159		0.0 0.0	5.910 0.0 5.910	70.054 0.0 -0.094			Vel = 3.90	

Final Calculations - Standard

DEAN & ALLYN, INC.
MMC 2CND FLOOR RICHARDS

Page 6
Date 110408

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
42	0.0	1.598		9.080	69.960				
to		150		0.0	0.0				
43	-24.38	-0.0161		9.080	-0.146		Vel = 3.90		
43	0.0	1.598		12.000	69.814				
to		150		0.0	0.0				
44	-24.38	-0.0160		12.000	-0.192		Vel = 3.90		
44	0.0	1.598		2.750	69.622				
to		150		0.0	0.0				
41	-24.38	-0.0160		2.750	-0.044		Vel = 3.90		
41	0.0	1.598		33.910	69.578				
to		150		0.0	-0.001				
8	-24.38	-0.0160		33.910	-0.543		Vel = 3.90		
8	106.91	1.598	2O 16.0	12.830	69.034				
to		150		16.000	0.0				
15	82.53	0.1527		28.830	4.401		Vel = 13.20		
15	100.00	2.469	3E 18.0	6.450	73.435		Qa = 100		
to		120	1B 7.0	39.000	3.000		* Fixed loss = 3		
16	182.53	0.1204	1Fsp 0.0 1S 14.0	45.450	5.471		Vel = 12.23		
16	0.0	6.065	1E 14.0	31.100	81.906				
to		120		14.000	8.481				
14B	182.53	0.0015		45.100	0.069		Vel = 2.03		
14B	0.0	6.065	6E 84.0	91.000	90.456				
to		120	2T 60.0	147.000	3.681				
14A	182.53	0.0015	1G 3.0	238.000	0.360		Vel = 2.03		
14A	83.28	6.065	2E 28.0	12.000	94.497				
to		120	1T 30.0	93.000	0.0				
TEST	265.81	0.0030	1G 3.0 1S 32.0	105.000	0.319		Vel = 2.95		
	0.0								
	265.81				94.816		K Factor = 27.30		

Water Supply Curve (C)

DEAN & ALLYN, INC.
MMC 2CND FLOOR RICHARDS

Page 7
Date 110408

City Water Supply:
C1 - Static Pressure : 170
C2 - Residual Pressure: 75
C2 - Residual Flow : 1160

Demand:
D1 - Elevation : 11.297
D2 - System Flow : 165.809
D2 - System Pressure : 94.816
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 265.809
Safety Margin : 68.962

