

- TEMPERATURE AND PRESSURE TAP (TYP.)

3 WAY MODULATING CONTROL VALVE

- AUTOMATIC FLOW CONTROL VALVE (TYP.)

W/BLOWDOWN

2. CONNECT THE WATER SUPPLY TO THE AIR LEAVING SIDE AND THE WATER RETURN TO THE ENTERING SIDE OF THE COIL.

5. CONFIGURE PIPE RUNOUTS AND PROVIDE UNIONS OR FLANGES TO ALLOW PIPING REMOVAL FOR COIL REMOVAL CLEARANCE.

1. SHUT OFF VALVES: BALL VALVES FOR 2" AND SMALLER PIPING, BUTTERFLY VALVES FOR 2-1/2" AND LARGER PIPING.

ISSUED FOR CONSTRU 12-21-10 MAINE MEDICAL CENTER
CATH LAB #1 GRAPHIC SCALE: PROJECT MANAGER: JC/DRAWN BY: A/E OF RECORD: PROJECT NO: 10113-00 12-21-10 SHEET TITLE:
DETAILS M-502