#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

MAINE MEDICAL CENTER /Party Plus Maine

Located at

22 BRAMHALL ST

**PERMIT ID:** 2013-01562

**ISSUE DATE:** 08/21/2013

CBL: 053 D007001

has permission to

Tent event; 9/11 & 12 take down 9/13.

**Maine Medical Center** 

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

**Building Official** 

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

Hospital

**PERMIT ID:** 2013-01562 **Located at:** 22 BRAMHALL ST **CBL:** 053 D007001

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

#### **REQUIRED INSPECTIONS:**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

**PERMIT ID:** 2013-01562 **Located at:** 22 BRAMHALL ST **CBL:** 053 D007001

	·	Maine - Building or Use Permi	Permit No: 2013-01562	<b>Date Applied For:</b> 07/22/2013	CBL:		
		04101 Tel: (207) 874-8703, Fax:			053 D007001		
Proposed Use: Same: Hospital			Tent ev	Proposed Project Description: Tent event; 9/11 & 12 take down 9/13. Maine Medical Center			
No	pt: Zoning ote: onditions:	Status: Approved	Reviewer:	Marge Schmucka	l Approval D	Oate: 07/24/2013 Ok to Issue: ✓	
No	ept: Building ote: onditions:	Status: Approved	Reviewer:	Tammy Munson	Approval D	Oate: 08/20/2013 Ok to Issue: ✓	
De No	pt: Fire	Status: Approved w/Conditions	Reviewer:	Chris Pirone	Approval D	Oate: 07/26/2013 Ok to Issue:	
Co	onditions:						
	All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf						
2)	The cooking equipment arrangement and type shall be evaluated at the inspection.						
3)	□ Fire extinguishers will be required per NFPA 10.						
	Emergency lighting and approved illuminated EXIT signs are required for events held outside of day light hours. A back up generator with transfer switch shall meet this requirement if the following is met:  a. □ All lighting is powered from the generator circuit.  B. □ The lighting illuminates the face of the EXIT signs.  C. □ An auto transfer and start shall be provided or dedicated staff shall be provided for that purpose.						
	All tents shall meet the flame propagation performance criteria contained in NFPA 701. A certificate or other evidence of acceptance by an organization acceptable to the AHJ shall serve as evidence that the tent fabric materials have the required flame propagation performance.						
6)	Cooking within the tents has not been reviewed and approved.						
7)	Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not with 5 feet of the tents or an exit discharge.						

**PERMIT ID:** 2013-01562 **Located at:** 22 BRAMHALL ST **CBL:** 053 D007001

8) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.