CODE PLAN LEGEND:

- EXIT SIGN
- FIRE ALARM SYSTEM HORN / STROBE
- FIRE ALARM SYSTEM STROBE
- FIRE ALARM SYSTEM BELL
- EMERGENCY LIGHT
- SMOKE DETECTOR
- FIRE ALARM PULL STATION
- F.E. FIRE EXTINGUISHER

BUILDING DESIGN CODES:

AMERICANS WITH DISABILITIES ACT (ADA 2010)
NFPA 101 LIFE SAFETY CODE (2009)
INTERNATIONAL BUILDING CODE (2009)
NFPA 70 NATIONAL ELECTRIC CODE
NFPA 13

OCCUPANCY CLASSIFICATION:

EXISTING OCCUPANCIES - NO CHANGE
NFPA: ASSEMBLY / MERCANTILE
IBC: ASSEMBLY A3 / MERCANTILE

CONSTRUCTION TYPE:

NFPA: TYPE 5 (000)
IBC: TYPE VB

AREA:

TOTAL AREA:	27,515 SF
AREA OF RENOVATION:	5,000 SF

FIRE SUPPRESSION:

SUPERVISED AUTOMATIC SPRINKLER SYSTEM PER NFPA 13.3.5 AND 9.7

OCCUPANT LOADS:

ASSEMBLY W/O SEATS:	7 SF NET
ASSEMLBY W/ SEATS:	15 SF NET
MERCANTILE:	30 SF GROSS
OFFICE:	100 SF GROSS
MECHANICAL:	300 SF GROSS
STORAGE	300 SF GROSS

MEANS OF EGRESS:

MAX TRAVEL DISTRANCE:	250 FT (NFPA)
DEAD END CORRIDOR:	50 FT
COMMON PATH OF TRAVEL:	75 FT OL<50
	20 FT OL>50
MIN CORRIDOR WIDTH:	44 IN OL >50
EXIT CAPACITY	.3"/OCCUPANT (VERTICAL)
	.2"/OCCUPANT (HORIZ)

1 CODE PLAN LEGEND AND SUMMARY
SCALE: 1/8" = 1'-0"

Reviewed for Code Compliance
Fire Prevention Division
Approved with Conditions
Date: 01/27/14

HARRIMAN
AUBURN PORTLAND MANCHESTER

UNIVERSITY OF SOUTHERN MAINE WOODBURY CAMPUS CENTER BOOKSTORE RENOVATIONS

PORTLAND, ME

Harriman Project No.	13659

Key Plan

Issues and Revisions

Mark	Date	Description
-	01-17-14	PERMIT SUBMISSION

LICENSED ARCHITECT MARK D. LEE #3849 STATE OF MAINE

Drawing Scales As indicated	0 2' 4' 6' 1/4" = 1'-0"
PA / PE: MDL	© 2014 Harriman Associates
Drawn By: MDL	

LIFE SAFETY PLAN

LS-10.1